NRL Series Circuit Protectors

Miniature circuit protectors with hydraulic-magnetic tripping system, allow for space and cost savings. Long life also reduces maintenance costs.

- Compact size (only 36.6H × 16.8W × 42D mm)
- One-lever (one-rocker) for 2-poles, ensures proper interruption to both poles when one pole is tripped.
- Low, middle, and high speed response
- Variety of rated currents and internal circuits
- Available with auxiliary contacts and inertia delay
- Over 20,000 mechanical operations

- Hydraulic-magnetic tripping system
- Safe trip-free mechanism
- Vibration-proof design

This product is recognized by Underwriters Laboratories under UL1077 as a "Supplementary Protector."













PSE (relay and switch type only) UL (AC type only)

Specifications

Model	NRLT	NRLY	NRLR				
Shape	9						
Operator Style	Lever (lever color: black)	Rocker (non-illuminated), Illuminated rock	er				
Protection Method	Hydraulic-magnetic tripping system						
Internal Circuit	Series trip (Current trip), Relay trip (Voltaç with auxiliary contact	ge trip)* Series trip (Current trip) with aux	ciliary contacts, Switch only, Switch only				
No. of Poles	1-pole, 2-pole (1-lever)	1-pole, 2-pole (1-rocker)					
Rated Voltage	250V AC 50/60Hz, 50V DC						
Minimum Applicable Load	24V AC/DC, 100 mA (reference value)						
Rated Current	Current trip: 0.1A, 0.5A, 1A, 2A, 3A, 4A, 5	A, 7.5A, 10A, 12.5A, 15A, 20A					
Trip Voltage (Voltage trip)	100V AC 50/60Hz,24V DC (operating at 90% of the rated voltage or higher, at 25°C) Voltage application duration: 1 sec maximum Trip time: 0.05 sec maximum (at the rated voltage)						
Rated Interrupting Current	250V AC 50/60Hz, 750A PC1 (UL rating: 1 50V DC, 500A PC1	250V AC 50/60Hz, 750A PC1 (UL rating: 1000A) 50V DC, 500A PC1					
Auxiliary Contact	SPDT microswitch 125V AC · 3A (resis	tive load), 30V DC · 2A (resistive load)					
Reference Temperature	+25°C						
Operating Temperature	-40 to +60°C (no freezing)						
Storage Temperature	-40 to +85°C (no freezing)						
Operating Humidity	45 to 85% RH (no condensation)						
Storage Humidity	45 to 85% RH (no condensation)						
Insulation Resistance	100 MΩ minimum (500V DC megger)						
Dielectric Strength	2000V AC, 1 minute (between live part and ground, between terminals of different poles, between terminals of the same pole when main contacts are open, between main circuit and auxiliary contact)						
Vibration Resistance	100 m/s ² (10 to 55 Hz), with the rated curr	rent applied					
Shock Resistance	500 m/s ² (operating extremes and damag	ge limits), with the rated current applied (au	ıxiliary contact: 360 m/s²)				
Life	Electrical: Over 10,000 operations minimum (6 operations/min) Mechanical: Over 20,000 operations minimum (6 operations/min)						
Terminal Style (Note)	Main terminal: Tab terminal #250 Auxiliary contact terminal: Solder terminal Indicator terminal [Illuminated rocker]: Tab terminal #110						
Mounting Style	Ring mounting	Snap-on mounting	Screw mounting				
Weight (Approx.)	1-pole: 30g, 2-pole: 60g (NRLT series trip	0)					

[•] Do not use the NRL circuit protectors in environments where they are exposed to extreme temperature, humidity, dust, corrosive gases, vibration, shock, or in a circuit where inrush current may be present, otherwise unnecessary operations and damage may occur.

• The ratings of switch only type are 250V AC/50V DC and 20A, without protection function.

Note: Indicator terminal of 1-pole illuminated rocker with auxiliary contact is a lead wire.

Indicator Ratings (Illuminated Rocker)

Indicator	Voltage			
Neon	100 to 125V AC			
LED	6V, 12V, 24V, 48V AC/DC ±10%			

Note: Both neon and LED indicators have a built-in current limiting resis-


Standard Color

Housing		Black			
Lever (NRLT)		Black			
Rocker and In	dicator	Rocker Color Indicator Color			
(NRLY)	Non-illuminated	Black, red, green	-		
(NRLR)	Neon	Transparent red	Red		
	LED	Transparent red	Red		



NRL Series Circuit Protectors

Part No. Development



NRLT (Lever)

Specify a rated current or voltage, and time delay curve in place of 6 7.

Package Quantity: 1

Internal	No. of	Inertia	Auxiliary Contact	Part No.	Designation Code		
Circuit	Poles	Delay	Auxiliary Contact	Part No.	6 Rated Current or Voltage	7 Time Delay Curve	
		Without	Without	NRLT1100- 6 7		AA, AD, BA, BD, EA, ED	
	1	Without	With	NRLT1111- 6 7		AA, AD, BA, BD, EA, ED	
Series	'	With	Without	NRLT1100F- 6 7		AA, AD, BA, BD	
Trip		VVILII	With	NRLT1111F- 6 7	0.1A, 0.5A, 1A, 2A, 3A, 4A, 5A, 7.5A, 10A, 12.5A, 15A,	AA, AD, DA, DD	
Current Trip		Without	Without	NRLT2100- 6 7	20A	AA, AD, BA, BD, EA, ED	
IIIP	2	villiout	With	NRLT2111- 6 7		AA, AD, DA, DD, EA, ED	
	2	With	Without	NRLT2100F- 6 7		AA, AD, BA, BD	
			With	NRLT2111F- 6 7		7,7,7,10, 0,7, 00	
Relay Trip	1	Without	Without	NRLT1500- 6	100V AC		
Voltage Trip	2	without	Without	NRLT2500- 6	24V DC	_	
	1 Switch		Without	NRLT1000			
Switch		NACUL	With	NRLT1011			
Only	2	Without	Without	NRLT2000	_	_	
	2		With	NRLT2011			

NRLY (Rocker)

[Snap-on Mounting Part]

Specify a rated current or voltage, time delay curve, and indicator or rocker color in place of 6 78. Package Quantity: 1


							Designa	tion Code	
Illumination	Internal Circuit	No. of Poles	Inertia Delay	Auxiliary Contact	Part No.	6 Rated Current and Volt- age	7 Time Delay Curve	8 Indicator	9 Rocker Color
			Without	Without	NRLY1100- 6 7 - 8	0.1A	AA, AD, BA,		
		1	Williout	With	NRLY1111- 6 7 - 8	0.5A 1A	BD, EA, ED		
	Series	'	With	Without	NRLY1100F- 6 7 - 8	2A 3A	AA, AD, BA,		
	Trip		VVILII	With	NRLY1111F- 6 7 - 8	4A	BD	1: Neon	
	Current Trip		Without	Without	NRLY2100- 6 7 - 8	5A 7.5A	AA, AD, BA,	125V AC 50/60Hz	
	ПР	2	Without	With	NRLY2111- 6 7 - 8	10A	BD, EA, ED	2. I ED	
		_	With	Without	NRLY2100F- 6 7 - 8	12.5A 15A	AA, AD, BA,	3: LED 6V AC/DC	
Illuminated			VVIIII	With	NRLY2111F- 6 7 - 8	20A	BD	4: LED	_
marmiatod	Relay Trip	1		Without	NRLY1500- 6 - 8	100V AC		12V AC/DC	
	Voltage	2	Without	Without	NRLY2500- 6 - 8	24V DC	-	5: LED 24V AC/DC 7: LED	
				Without	NRLY1000- 8		-	48V AC/DC	
	Switch		\\\(\frac{1}{2} \tau_{1} \tau_{2} \tau_{1} \tau_{2} \tau_{1} \tau_{2} \tau_{2} \tau_{1} \tau_{2} \tau_	With	NRLY1011- 8				
	Only		Without	Without	NRLY2000-8	_			
				With	NRLY2011- 8				
		1 Series Trip	Without	Without	NRLY1100-67-8	0.1A	AA, AD, BA, BD, EA, ED AA, AD, BA, BD		
			Williout	With	NRLY1111- 6 7 - 8	0.5A 1A			
	Sorioo		With	Without	NRLY1100F- 6 7 - 8	2A 3A 4A			
	Trip		VVILII	With	NRLY1111F- 6 7 - 8				
	Current Trip		Without	Without	NRLY2100- 6 7 - 8	5A 7.5A	AA, AD, BA,		
	p	2	Without	With	NRLY2111- 6 7 - 8	10A	BD, EA, ED		
		_	With	Without	NRLY2100F- 6 7 - 8	12.5A 15A	AA, AD, BA,		
Non-			***************************************	With	NRLY2111F- 6 7 - 8	20A	BD	_	B, G, R
illuminated	Relay Trip	1	M/ith and	Without	NRLY1500- 6 - 8	100V AC		_	р, G, K
	Voltage Trip	2	Without	Without NRLY2500- 6 - 8		24V DC	_		
		1		Without	NRLY1000- 8				
	Switch	'	\\/i+h a : :+	With	NRLY1011- 8		-		
	Only	2	Without	Without	NRLY2000-8	_			
	2		With	NRLY2011- 8					

NRLR (Rocker) [Screw Mounting]

Specify a rated current or voltage, time delay curve, and indicator or rocker color in place of 6 78. Package Quantity: 1

				Designat	Designation Code							
Illumination	Internal Circuit	No. of Poles	Inertia Delay	Auxiliary Contact	Part No.	6 Rated Current and Voltage	7 Time Delay Curve	8 Indicator	9 Rocker Color			
			Without	Without	NRLR1100-67-8	0.1A	AA, AD, BA,					
		1	VVILLIOUT	With	NRLR1111- 6 7 - 8	0.5A 1A	BD, EA, ED					
		'	With	Without	NRLR1100F- 6 7 - 8	2A 3A	AA, AD, BA,					
	Series Trip		VVIIII	With	NRLR1111F- 6 7 - 8	4A	BD	1: Neon				
	Current Trip		Without	Without	NRLR2100-67-8	5A 7.5A	AA, AD, BA,	125V AC 50/60Hz				
	ПР	2	VVIIIIOUT	With	NRLR2111- 6 7 - 8	10A	BD, EA, ED	2.150				
		_	With	Without	NRLR2100F- 6 7 - 8	12.5A 15A	AA, AD, BA,	3: LED 6V AC/DC				
Illuminated			VVICII	With	NRLR2111F- 6 7 - 8	20A	BD	4: LED	_			
illullillated	Relay Trip	1	Without	Without	NRLR1500- 6 - 8	100V AC	_	12V AC/DC 5: LED				
	Voltage Trip	2	Without	Without	NRLR2500- 6 - 8	24V DC	_	24V AC/DC 7: LED 48V AC/DC				
			Without	Without	NRLR1000- 8		-					
	Switch			With	NRLR1011- 8	_						
	Only		VVIIIIOUT	Without	NRLR2000- 8							
				With	NRLR2011- 8							
	Series Trip	Trip	Without	Without	NRLR1100-67-8	0.1A 0.5A	AA, AD, BA,					
				With	NRLR1111-67-8	1A	AA, AD, BA, BD					
				Without	NRLR1100F- 6 7 - 8	2A 3A						
				With	NRLR1111F- 6 7 - 8	4A						
	Current Trip					Without	Without	NRLR2100-67-8	5A 7.5A	AA, AD, BA,		
		2		With	NRLR2111- 6 7 - 8	10A 12.5A	BD, EA, ED					
			With	Without	NRLR2100F- 6 7 - 8	15A	AA, AD, BA,					
Non-				With	NRLR2111F- 6 7 - 8	20A	BD	_	B, G, R			
iliuminated	illuminated Relay Trip Voltage Trip	1	Without	Without	NRLR1500- 6 - 8	100V AC	_		5, G, 11			
		2	minout	Without	NRLR2500- 6 - 8	24V DC						
		1		Without	NRLR1000- 8							
	Switch		Without	With	NRLR1011- 8	_	-					
	Only	2	vvitilout	Without	NRLR2000- 8	_			_			
		2		With	NRLR2011- 8							

Internal Circuits




Overcurrent - Time Delay Characteristics (sec at 25°C)

Time Delay Curves		Percent of Rated Current							
AC 50/60Hz	DC	100%	135%	150%	200%	400%	600%	800%	
AA ★	AD ★	No Trip	3-70	2-40	1-15	0.1-4	0.01-2	0.007-0.8	
BA ★	BD ★	No Trip	0.3-7	0.2-5	0.1-2	0.03-0.5	0.01-0.3	0.007-0.15	
EA	ED	No Trip	0.015-0.5	0.01-0.25	0.009-0.1	0.006-0.03	0.005-0.02	0.004-0.02	

Note: Curves marked with ★ are also available with inertia delay. (Inertia delay is not available for Curves ED and EA)


Time Delay Curves Note: Curves marked with ★ are also available with inertia delay.



Circuit Protector with Inertia Delay


Inertia delay is designed not to trip on a non-repeating single pulse of 12 times the rated current (peak value) for duration of 8 ms. In addition, circuit protectors equipped with inertia delay do not respond to high inrush currents caused by transformer or lamp loads, but perform the specified interruption on the subsequent overcurrents.

Curves EA and ED are not available with inertia delay.



Temperature Correction Curve

The time delay curves on the preceding page are at 25°C. With reference to the following curves, time delays can be corrected according to the ambient temperature.



Operation of Auxiliary Contacts

At tripping or manual ON-OFF operation, there is a lag in time between the operation of the main contact and the auxiliary contact.

Impedance and Coil Resistance (at 25°C)

[Current Trip] (initial value)


Rated Current	For AC 50/60Hz Impedance (Ω)	For DC, Impedance between Terminals (Ω)
	Curves AA, BA, and EA	Curves AD, BD, and ED
0.1A	97.0	96.0
0.5A	3.2	3.1
1A	0.81	0.78
2A	0.19	0.18
3A	0.086	0.085
4A	0.051	0.050
5A	0.034	0.034
7.5A	0.017	0.016
10A	0.0092	0.0087
12.5A	0.0068	0.0065
15A	0.0052	0.0050
20A	0.0033	0.0031


Note: Tolerance: ±25% (up to 5A), ±50% (7.5A or higher)

[Voltage trip] (initial value)

	For AC 50/60Hz Impedance (Ω)	For DC, Impedance between Terminals (Ω)
100V AC	3000	_
24V DC	_	370

Note: Tolerance: ±25%






Rated Current (Trip Current) by Installation Angle

Overcurrent tripping method is hydraulic magnetic. Minimum operating currents vary with installation angle because operating currents are influenced by the weight of the iron core. With reference to the following figure, correct the rated current.

Note 1:The rated current does not change depending on the installation angle.


Note 2: The minimum operating current is calculated from the following formula:

(Minimum operating current) = (Rated current) \times 135% \times (Correction factor by installation angle)




Dimensions All dimensions in mm.


NRLT (Lever) Note: The dashed lines show the 2-pole type.




NRLY (Snap-on Mounting, Rocker) Note: The dashed lines show the 2-pole type.




Illuminated Rocker (without auxiliary contact) Series Trip, Switch Only



Rocker (Non-illuminated) Relay Trip (4-terminal)




Illuminated Rocker (1-pole, with auxiliary contact) Series Trip, Switch Only




Lead wire length: Approx. 100 mm

Illuminated Rocker (1-pole) Relay Trip (4-terminal)




Lead wire length: Approx. 100 mm

Illuminated Rocker (2-pole, with auxiliary contact) Series Trip, Switch Only




Illuminated Rocker (2-pole) Relay Trip (4-terminal)



Lead wire length: Approx. 100 mm

NRLR (Screw Mounting, Rocker) Note: The dashed lines show the 2-pole type.



Instructions

One-pole circuit protectors cannot be combined to make 2- or 3-pole units due to their characteristics. Order multi-poles from IDEC.

Recommended Soldering Conditions


Solder the main terminal at a temperature of 390°C within 10 seconds using a 60W soldering iron.

Solder the auxiliary/alarm terminal at a temperature of 350°C within 3 seconds using a 60W soldering iron. (Sn-Ag-Cu lead-free solder is recommended.)

When soldering, do not touch the circuit protector housing, auxiliary and alarm contacts with the soldering iron, and do not bend the terminals or pull the wires.

Check your actual soldering conditions before soldering.

Mounting Hole Layout




NRL Series Circuit Protectors

Accessories

Name and S	hape	Part No.	Ordering No.	Package Quantity	Description and Dimensions
Decorative Bezel	NRL-R	NRL-RPN05	5	The decorative bezel can be used in place of the standard bezel. Note that the maximum panel thickness differs from that with the standard bezel. Material: Chromeplated metal (See "Mounting Hole Layout".)	
Anti-rotation Ring	NRL-L	NRL-LPN05	5	The anti-rotation ring is intended to ensure firm rotation prevention. (See "Mounting Hole Layout".) Metal ring Old Old Old Old Old Old Old	
Nameplate	(Legend) ON I OFF	NRL-N1	NRL-N1PN05	5	Aluminum plate (Aluminum colored) with black legend
		NRL-N3	NRL-N3PN05	J	
O L	O F - N F N	NRL-N2	NRL-N2PN05	5	OFF N
N)	0 - 1	NRL-N4	NRL-N4PN05	J	15.2

Package Quantity: 1



EP5444 NRL November 2021

Ordering Terms and Conditions

Thank you for using IDEC Products.

By purchasing products listed in our catalogs, datasheets, and the like (hereinafter referred to as "Catalogs") you agree to be bound by these terms and conditions. Please read and agree to the terms and conditions before placing your order.

1. Notes on contents of Catalogs

- (1) Rated values, performance values, and specification values of IDEC products listed in this Catalog are values acquired under respective conditions in independent testing, and do not guarantee values gained in combined conditions.
 - Also, durability varies depending on the usage environment and usage conditions.
- (2) Reference data and reference values listed in Catalogs are for reference purposes only, and do not guarantee that the product will always operate appropriately in that range.
- (3) The specifications / appearance and accessories of IDEC products listed in Catalogs are subject to change or termination of sales without notice, for improvement or other reasons.
- (4) The content of Catalogs is subject to change without notice.

2. Note on applications

- If using IDEC products in combination with other products, confirm the applicable laws / regulations and standards.
 - Also, confirm that IDEC products are compatible with your systems, machines, devices, and the like by using under the actual conditions. IDEC shall bear no liability whatsoever regarding the compatibility with IDEC products.
- (2) The usage examples and application examples listed in Catalogs are for reference purposes only. Therefore, when introducing a product, confirm the performance and safety of the instruments, devices, and the like before use. Furthermore, regarding these examples, IDEC does not grant license to use IDEC products to you, and IDEC offers no warranties regarding the ownership of intellectual property rights or non-infringement upon the intellectual property rights of third parties.
- (3) When using IDEC products, be cautious when implementing the following.
 - i. Use of IDEC products with sufficient allowance for rating and performance
 - Safety design, including redundant design and malfunction prevention design that prevents other danger and damage even in the event that an IDEC product fails
 - Wiring and installation that ensures the IDEC product used in your system, machine, device, or the like can perform and function according to its specifications
- (4) Continuing to use an IDEC product even after the performance has deteriorated can result in abnormal heat, smoke, fires, and the like due to insulation deterioration or the like. Perform periodic maintenance for IDEC products and the systems, machines, devices, and the like in which they are used.
- (5) IDEC products are developed and manufactured as general-purpose products for general industrial products. They are not intended for use in the following applications, and in the event that you use an IDEC product for these applications, unless otherwise agreed upon between you and IDEC, IDEC shall provide no guarantees whatsoever regarding IDEC products.
 - i. Use in applications that require a high degree of safety, including nuclear power control equipment, transportation equipment (railroads / airplanes / ships / vehicles / vehicle instruments, etc.), equipment for use in outer space, elevating equipment, medical instruments, safety devices, or any other equipment, instruments, or the like that could endanger life or human health
 - Use in applications that require a high degree of reliability, such as provision systems for gas / waterworks / electricity, etc., systems that operate continuously for 24 hours, and settlement systems
 - iii. Use in applications where the product may be handled or used deviating from the specifications or conditions / environment listed in the Catalogs, such as equipment used outdoors or applications in environments subject to chemical pollution or electromagnetic interference If you would like to use IDEC products in the above applications, be sure to consult with an IDEC sales representative.

3. Inspections

We ask that you implement inspections for IDEC products you purchase without delay, as well as thoroughly keep in mind management/maintenance regarding handling of the product before and during the inspection.

4. Warranty

(1) Warranty period

The warranty period for IDEC products shall be one (1) year after purchase or delivery to the specified location. However, this shall not apply in cases where there is a different specification in the Catalogs or there is another agreement in place between you and IDEC.

(2) Warranty scope

Should a failure occur in an IDEC product during the above warranty period for reasons attributable to IDEC, then IDEC shall replace or repair that product, free of charge, at the purchase location / delivery location of the product, or an IDEC service base. However, failures caused by the following reasons shall be deemed outside the scope of this warranty.

- i. The product was handled or used deviating from the conditions / environment listed in the Catalogs
- ii. The failure was caused by reasons other than an IDEC product
- iii. Modification or repair was performed by a party other than IDEC
- iv. The failure was caused by a software program of a party other than $\ensuremath{\mathsf{IDEC}}$
- v. The product was used outside of its original purpose
- Replacement of maintenance parts, installation of accessories, or the like was not performed properly in accordance with the user's manual and Catalogs
- vii. The failure could not have been predicted with the scientific and technical standards at the time when the product was shipped from IDEC
- viii. The failure was due to other causes not attributable to IDEC (including cases of force majeure such as natural disasters and other disasters)

 Furthermore, the warranty described here refers to a warranty on the IDEC product as a unit, and damages induced by the failure of an IDEC product are excluded from this warranty.

5. Limitation of liability

The warranty listed in this Agreement is the full and complete warranty for IDEC products, and IDEC shall bear no liability whatsoever regarding special damages, indirect damages, incidental damages, or passive damages that occurred due to an IDEC product.

6. Service scope

The prices of IDEC products do not include the cost of services, such as dispatching technicians. Therefore, separate fees are required in the following cases.

- (1) Instructions for installation / adjustment and accompaniment at test operation (including creating application software and testing operation, etc.)
- (2) Maintenance inspections, adjustments, and repairs
- (3) Technical instructions and technical training
- (4) Product tests or inspections specified by you

The above content assumes transactions and usage within your region. Please consult with an IDEC sales representative regarding transactions and usage outside of your region. Also, IDEC provides no guarantees whatsoever regarding IDEC products sold outside your region.

IDEC CORPORATION

I Office 6-64, Nishi-Miyahara-2-Chome, Yodogawa-ku, Osaka 532-0004, Japan

Singapore

Thailand India IDEC Izumi Asia Pte 1 td

IDEC Asia (Thailand) Co., Ltd.

IDEC Controls India Private Ltd.

China IDEC (Shanghai) Corporation IDEC Izumi (H.K.) Co., Ltd.

Taiwan IDEC Taiwan Corporation

Japan IDEC Corporation

☐ www.idec.com

Specifications and other descriptions in this brochure are subject to change without notice.

2021 IDEC Corporation, All Rights Reserved.

IDFC Corporation

APEM SAS

IISΔ

EMEA

