

CERTIFICATE OF COMPLIANCE

Certificate Number E68961
Report Reference E68961-19970618
Date 2020-December-06

Issued to: IDEC CORP
6-64 NISHIMIYAHARA 2-CHOME
YODOGAWA-KUOSAKA 532-0004 JP

This is to certify that representative samples of AUXILIARY DEVICES
See Addendum Page for Product Designation(s).

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 508 STANDARD FOR INDUSTRIAL CONTROL EQUIPMENT

CSA C22.2 NO. 14-13 INDUSTRIAL CONTROL EQUIPMENT

Additional Information: See the UL Online Certifications Directory at <https://iq.ulprospector.com> for additional information

This Certificate of Compliance does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/about/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number E68961
Report Reference E68961-19970618
Date 2020-December-06

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

Safety Switches, Types HS1B, HS1C, HS1L, HS2B, HS5B, HS1E and HS5D Series. May be followed by additional numbers or letters.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/about/locations/>

