



Product Service

CERTIFICATE

No. B 013332 0522 Rev. 00

Holder of Certificate: IDEC CORPORATION

2-6-64 Nishimiyahara, Yodogawa-Ku
Osaka
532-0004 JAPAN

Certification Mark:



Product:

**Switches
Safety Door Switch**

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 73587303

Valid until: 2026-08-10

Date, 2021-08-11

(Shigehisa Ishikawa)



Product Service

CERTIFICATE

No. B 013332 0522 Rev. 00

Model(s): HS6B Series

Nomenclature:

HS6B - 1 1 *
(1) (2) (3) (4)

(1) Series HS6B

(2) NO contact assignment
0, 1, 2, 3

(3) NC contact assignment
0, 1, 2, 3

(4) Manufacturer Control Number (s) (Optional):
Alphanumeric may be included hyphens. No effect on construction or performance.

Parameters:

Utilization category: AC15: 0.75 A, 240 V AC
DC13: 0.27A, 250 V DC
DC13: 2.3 A, 30 V DC

Rated insulated voltage: 300 V

Rated conventional free

Air thermal current: 2.5 A

Pollution degree: 3

Degree of protection : IP 67

Remark:

When installing / inserting the equipment, all requirements of the mentioned test standard must be fulfilled.

Tested according to: EN 60947-5-1:2017
GS-ET-15E:2019