

CERTIFICATE OF COMPLIANCE

Certificate Number E68029
Report Reference E68029-20071023
Date 2020-December-07

Issued to: IDEC CORP
6-64 NISHIMIYAHARA 2-CHOME
YODOGAWA-KUOSAKA 532-0004 JP

**This is to certify that
representative samples of**

PROTECTORS, SUPPLEMENTARY - COMPONENT
See Addendum Page for Product Designation(s).

Have been investigated by UL in accordance with the component requirements in the Standard(s) indicated on this Certificate. UL Recognized components are incomplete in certain constructional features or restricted in performance capabilities and are intended for installation in complete equipment submitted for investigation to UL LLC.


Standard(s) for Safety: UL 1077 Standard for Supplementary Protectors

Additional Information: See the UL Online Certifications Directory at <https://iq.ulprospector.com> for additional information

This *Certificate of Compliance* does not provide authorization to apply the UL Recognized Component Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Recognized Component Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Recognized Component Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/about/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number E68029
Report Reference E68029-20071023
Date 2020-December-07

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

Component - Supplementary Protectors, Overcurrent Type, Cat. No. NC1V, followed by -1, -2, or -3, followed by 1, followed by 00, 11 or, 21, may be followed by F, may be followed by -0.1A to -30A, may be followed by S, A or M.

Component - Supplementary Protectors, Shunt Protector, Voltage Type, Cat. No. NC1V, followed by -1, -2, or -3 followed by 5, followed by 00, followed by -DC24V.

Cat. No. NC1V, followed by -2 or -3, followed by 1, followed by 00, 11, or 21, may be followed by F, may be followed by -0.1A, may be followed by S, A, or M. Contact rating: 0.1 A, 250 V ac, 50/60 Hz; Short circuit rating: 250 V ac, 2500 A.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/about/locations/>

