



# Certificate of Compliance

**Certificate:** 2604407 (LR 35144)

**Master Contract:** 166730

**Project:** 2666251

**Date Issued:** October 4, 2013

**Issued to:** IDEC Corporation  
6-64 Nishimiyahara 2-Chome  
Yodogawa-Ku, Osaka 532-0004  
Japan

*The products listed below are eligible to bear the CSA Mark shown*



*Rowell Manipula*

**Issued by:** Rowell Manipula

## **PRODUCTS**

**CLASS 3211 07** - INDUSTRIAL CONTROL EQUIPMENT - Miscellaneous Apparatus

Relays, Series RF2S and RF2V with suffixes, open type with dust cover, 2-pole, 6A (NO), 3A (NC), resistive, 277V ac; 6A(NO), 3A (NC), resistive, 30V dc. Coil rated 5 through 125V dc.

Note: Open type devices are Certified as components only for use in other Certified equipment where the suitability of the combination is to be determined by CSA International

## **APPLICABLE REQUIREMENTS**

CSA Std C22.2 No. 14 - Industrial Control Equipment