



Certificate of Compliance

Certificate: 1124239 (LR 35144-109)

Master Contract: 166730

Project: 70010108

Date Issued: August 26, 2014

Issued to: IDEC Corporation

6-64 Nishimiyahara 2-Chome
Yodogawa-Ku, Osaka 532-0004
Japan
Attention: Lanny Schuberg

The products listed below are eligible to bear the CSA Mark shown



Areez Lalani

Issued by: Areez Lalani

PRODUCTS

CLASS 3211 07 - INDUSTRIAL CONTROL EQUIPMENT - Miscellaneous Apparatus

Relays, open type with dust cover, Model Nos RY4S, RY4V and RY4V1; -U, -UT, -UL, -UL1, -UC, -ULC, -UL1C, -UR, -ULR, -UCR, -ULCR may be followed by suffix D, D1, E, 4-pole, double-throw contacts, max ratings as follows: same polarity; 240V ac, 5A, 5A (res); 100V dc, 0.2A; 30V dc, 1.5A 5A (res); coils 240V ac max, 110V dc max.

Relays, open type with dust cover, Cat Nos RY2S, RY2V, -U, -UT, -UL, -UC, -ULC, -UR, -ULR, -UCR, -ULCR may be followed by suffix D, E, 2pdt contacts 240 V ac, 0.8 A, 3 A (res); 120 V ac, 1.5 A, 3 A (res); 100 V dc, 0.2 A; 30 V dc, 1.5 A, 3 A (res); coils 240V ac max, 110V dc max for RY2S, RY2V.

Notes:

Open type relays are Certified for use only as components in other equipment where the suitability of the combination is determined by the CSA International.

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No.14 - Industrial Control Equipment