



Product Service

CERTIFICATE

No. B 013332 0262 Rev. 01

Holder of Certificate: IDEC CORPORATION

2-6-64 Nishimiyahara, Yodogawa-Ku
Osaka
532-0004 JAPAN

Certification Mark:



Product: **Sockets**

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 73583253

Valid until: 2027-07-25

Date, 2022-07-27

(Shigehisa Ishikawa)



CERTIFICATE

No. B 013332 0262 Rev. 01

Model(s): SR2P, SR3P, SH1B, SH2B, SH3B, SH4B, SM2S, SY2S, SY4S with suffix letters -05A, -05B, -06A, -06B, -05, -06, -05C, -05U, -06U, SR3B-05, -05U, SH2B-62

Parameters:

	Model	Current	Voltage
Contact part:	SR2P, SR3P:	10 A	300 V
	SH1B:	10 A	300 V
	SH2B, SH3B, SH4B:	10 A	300 V
	SM2S:	10 A	300 V
	SY2S, SY4S:	7 A	300 V
	SR3B-05, -05U:	15 A	300 V
	SH2B-62:	10 A	300 V; 250 V
Protection class:	IP20 (Suffix -05C models only)		

Protection against electric shock has to be guaranteed by installation.

Remark:

When installing / inserting the equipment, all requirements of the mentioned test standard must be fulfilled.

Tested according to: EN 61810-1:2015/A1:2020