ø22 Switches & Pilot Lights

HW Series



Complete with finger-safe contact blocks. Ensure safety and save wiring time.















- DC-DC converter types are not approved by standards.
- · See website for details on approvals and standards.

First in the industry! Six different colors with a single LED (LSRD)

IS03864-4 safety color compliant

The bright and clears colors are suited for emergency situations

• Illuminated selector switches (illumination color: S (Blue), PW (Pure white))


Safety colors are defined with ISO standards.

• Illuminated pushbuttons (illumination color: S (Blue)) · Pilot lights - round flush (illumination color: S (Blue))

*Except for products below

Previously, 5 different color LEDs were required but with the new illuminated unit, only a single LED is used. Only the lens needs to be replaced to change the illumination color.

The new LED reduces maintenance time, makes stock control easier, and is environmentally friendly.



High visibility with new LED (LSRD)

Brighter and clearer compared to conventional LEDS



HW Series Selection Guide

Function	Pushbutton							
Catagory	Flush	Extended	ø29mm Mushroom	ø40mm Mushroom	ø60mm Mushroom			
Category	Momentary/Maintained	Momentary/Maintained	Momentary/Maintained	Momentary/Maintained	Momentary			
Shape								
Model	HW1B-M1 HW1B-A1	HW1B-M2 HW1B-A2	HW1B-M3 HW1B-A3	HW1B-M4 HW1B-A4	HW1B-M5			
Page	B-187	B-187	B-187	B-187	B-187			

Function	Pushbutton						
Category	Square Flush	Square Extended	Round Flush w/Square Bezel	Round Extended w/Square Bezel	ø29mm Mushroom w/Square Bezel		
	Momentary/Maintained	Momentary/Maintained	Momentary/Maintained	Momentary/Maintained	Momentary/Maintained		
Shape							
Model	HW2B-M1 HW2B-A1	HW2B-M2 HW2B-A2	HW3B-M1 HW3B-A1	HW3B-M2 HW3B-A2	HW3B-M3 HW3B-A3		
Page	B-188	B-188	B-189	B-189	B-189		

Function	Pilot Light								
Category	Flush (Marking)	Flush (Marking) Extended (Dome) Square Flush (Jumbo Dome					
Shape									
Model	HW1P-1	HW1P-2	HW2P-1	HW1P-5					
Page	B-190	B-190	B-190	B-190					

Function		Illuminated Pushbutton							
Category	Flush	Extended	Extended w/Full Shroud	Square Flush	Flush w/Square Bezel				
Galegory	Momentary/Maintained	Momentary/Maintained	Momentary/Maintained	Momentary/Maintained	Momentary/Maintained				
Shape									
Model	HW1L-M1 HW1L-A1	HW1L-M2 HW1L-A2	HW1L-MF2 HW1L-AF2	HW2L-M1 HW2L-A1	HW3L-M1 HW3L-A1				
Page	B-192	B-192	B-193	B-194	B-194				

Function	Illuminated Pushbutton			Short-body pilot light (LED)			
Category	Flush	Extended			Extended (Dome)	Causas Flush	
Category	Momentary/Maintained	Momentary/Maintained	Momentary/Maintained	Flush	Extended (Dome)	Square Flush	
Shape							
Model	HW1L-M3 HW1L-A3	HW3L-M3 HW3L-A3	HW1L-M4 HW1L-A4	HW1P-1J	HW1P-2J	HW2P-1J	
Page	B-195	B-195	B-196	Web	Web	Web	

APEM

Switches &

Control Boxes

Emergency Stop Switches Enabling Switches

Safety Products

Explosion Proof

Terminal Blocks

Relays & Sockets

Circuit Protectors

Power Supplies

LED Illumination

Controllers

Operator Interfaces

Sensors

AUTO-ID

Flush Silhouette

ø16

ø22

ø30 Miniature

Pilot Lights

tw

TW

HW Series Selection Guide

Function	Dual Pushbutton					
	w/o Pil	ot Light	w/ Pilo	t Light		
Category	Flush (top) Flush (top) Flush (bottom) Extended (bottom)		Flush (top) Flush (bottom)	Flush (top) Flush (bottom)		
	Momentary/Interlocking	Momentary/Interlocking	Momentary/Interlocking	Momentary/Interlocking		
Shape		08				
Model	HW7D-B11 HW7D-B21	HW7D-B12 HW7D-B22	HW7D-L11 HW7D-L21	HW7D-L12 HW7D-L22		
Page	B-199	B-199	B-200	B-200		

Function	Selector Switch			Illuminate	Pushbutton Selector	
Category	Selector	Pin Tumbler Key	Disc Tumbler Key	Knob Operator	Lever Operator	rusiibullon selectoi
Shape						
Model	HW1S	HW1K-□P	HW1K	HW1F	HW1F-□L	HW1R
Page	B-203	B-204	B-206	B-208	B-209	B-214

Function	Mono-Lever Switch				
Category	Standard	Interlocking			
Shape					
Model	HW1M	HW1M-L			
Page	B-215	B-215			

APEM

Switches & Pilot Lights

Control Boxes

Emergency Stop Switches Enabling Switches

Safety Products

Explosion Proof

Terminal Blocks

Relays & Sockets

Circuit Protectors

Power Supplies

LED Illumination

Controllers

Operator Interfaces

Sensors

AUTO-ID

Flush Silhouette

ø16

ø22

ø30

Miniature

Pilot Lights

HW

TW

Ø22 HW Series Switches & Pilot Lights

Complete with finger-safe contact blocks Ensure safety and save wiring time

- Finger-safe terminal blocks
- Self-cleaning rolling action contacts.
- Degree of protection: IP65 (except dual pushbutton: IP40)
- Dual pushbutton switches available with two pushbuttons and a pilot light integrated into one space-saving unit.
- A wide range of operating voltages for worldwide application.
- Six different colors with a single LED (LSRD). Only the lens needs to be replaced to change the illumination color.
- ISO3864-4 safety color compliant The bright and clears colors are suited for emergency situations



Application for dual pushbuttons:

Ideal for use as power switches and start/stop switches (available with I/ON and O/OFF markings on the buttons and a pilot light in the center).

Interlock type prevents two pushbuttons from being pressed at the same time, providing the best solution for up/down switches.

APEM

Control Boxes

Emergency Stop Switches Enabling

Switches

Safety Products

Explosion Proof

Terminal Blocks

Relays & Sockets

Circuit Protectors

Power Supplies

LED Illumination

Controllers

Operator

Sensors

AUTO-ID

Specifications and Ratings

Contact Ratings by Utilization Category

HW-U10 (NO contact), HW-U01 (NC contact)

50/60 Hz

DC

Contact Ratings

Operating Voltage

Operating Current

Pushbuttons	Rated insulation voltage	600V
Illuminated Pushbuttons Dual Pushbuttons	Rated continuous current	10A
Selector Switches Illuminated Selector Switches Selector Pushbuttons	Contact ratings by utilization category IEC60947-5-1	AC-15 (A600) DC-13

Flush Silhouette

ø16

ø30

Miniature

Pilot Lights

TW

HW-U10R (EM contact/NO contact), HW-U01R (LB contact/NC contact)

Operating Voltage		24V	48V	50V	110V	220V	440V	
AC	AC-12 Control of resistive loads and solid state loads	5A	_	5A	5A	3A	1A	
Operating	Operating 50/60 Hz Current	AC-15 Control of electromagnetic loads (> 72 VA)	5A	_	3.5A	2.5A	1.5A	0.5A
Current		DC-12 Control of resistive loads and solid state loads	5A	2.5A	_	1.1A	0.55A	_
	DC	DC-13 Control of electromagnets	2.5A	1A	_	0.55A	0.3A	_

24V

10A

10A

10A

5A

48V

5A

2A

50V

10A

7A

110V

10A

5A

2.2A

1.1A

220V

6A

ЗА

1.1A

0.6A

440V

2A

1A

• The operating current represents the classification by making and breaking currents (IEC 60947-5-1).

DC-13 Control of electromagnets

- · Contact materials: Silver contacts
- Minimum applicable load: 3V AC/DC, 5 mA (applicable range may vary with operating conditions and load types)

AC-12 Control of resistive loads and solid state loads

DC-12 Control of resistive loads and solid state loads

AC-15 Control of electromagnetic loads (> 72 VA)

ø22 HW Series Switches & Pilot Lights

HW-U Contact Block

IP20 construction No terminal cover necessary Snap-fit latch (To install/remove the contact block) Terminal Housing Terminal No. 4 No. 2 Two-way wiring Terminal Terminal No. 3 Push rod Terminal screw (M3.5)HW-U10 HW-U01 (NO contact) (NC contact)

Part No.	HW-U10	HW-U01	HW-U10R	HW-U01R			
Contact	_/_	7	_/_	7			
Contact	1NO	1NC	EM (NO) (early make)	LB (NC) (late break)			
Contact No.	3-4	1-2	3-4	1-2			
Housing	Blue	Purple red	Blue	Purple red			
Push Rod	Green	Red	Black	White			
Weight	Approx. 11g						

- Up to 2 layers (4 blocks) can be attached.
- Gold contacts available (gold-plated silver)

LED Illuminated Part Specifications

Unit				LED lamp		
UIIIL	Rated Volta	Rated Voltage		Operating Voltage		Part No.
	6V AC/DC		6V AC/DC			LSRD-6
	12V AC/DC		12V AC/DC			LSRD-1
	24V AC/DC		24V AC/DC		BA9S/13	LSRD-2
Illuminated pushbutton	100/110V AC		100/110V AC			LSRD-6
Illuminated selector switch	115/120V AC		115/120V AC (*1)	±10%		
Pilot light	200/220V AC		200/220V AC	±1070		
Dual pushbutton	230/240V AC	50/60 Hz	230/240V AC (*1)			
(with pilot light)	380V AC		380V AC			LOND-0
	400/440V AC		400/440V AC			
	480V AC		480V AC			
	110V DC		90 to 140V DC			

- See B-182. for details on LED lamp ratings.
- For the LED lamp used in jumbo dome pilot lights and dual pushbutton switches (with pilot light), see B-182.
- Yellow (Y) cannot be used with dual pushbuttons.

Illuminated Part Type and Shape

		Illuminated Unit	Pilot Light				
Power Unit	Full voltage adapter	Transformer		DC-DC converter	Full voltage adapter	Transformer	DC-DC converter
Rated Voltage	6, 12, 24V AC/DC	100 to 240V AC	380V AC min.	110V DC	6, 12, 24V AC/DC	100 to 480V AC	110V DC
Polarity	None	None None		X1 (+) X2 (–)	None	None	X1 (+) X2 (–)
Shape/Terminal	X1 X2	X1 X2		X1 X2	X1 X2	F	X1 X2

APEM
Switches &
Pilot Lights

Control Boxes

Emergency Stop Switches Enabling Switches

Safety Products

Explosion Proof

Terminal Blocks

Relays & Sockets
Circuit

Protectors
Power Supplies

LED Illumination

Controllers

Operator Interfaces

Sensors AUTO-ID

Flush Silhouette

ø16

ø30

Miniature

Pilot Lights

HW TW

Control Boxes

LED Lamp Ratings

LSRD - Except jumbo dome pilot lights (except colors R, A, and G)

Part No.		LSRD-6	LSRD-1	LSRD-2					
Lamp Base		BA9S/13							
Rated Voltage	9	6V AC/DC	12V AC/DC	24V AC/DC					
Voltage Rang	je	6V AC/DC ±10%	12V AC/DC ±10%	24V AC/DC ±10%					
Current	DC	10mA	7mA	7mA					
Draw	AC	14mA	8mA	8mA					
Voltage Mark	ing	Die stamped on the base)ie stamped on the base						
Life (reference value)		Approx. 50,000 hours (The luminance is reduced to 50% the initial intensity when used on complete DC at 25°C.)							
Internal Circuit		X1 — Limited current circuit Noise protection circuit Rectifier circuit Dimmer protection circuit	Example: LSRD-2	2					
Weight		Approx. 2g							

- Only one color is available for LSRD so there are no codes to specify the color in the part no.
- Use a LSRD-2 lamp for dome pilot lights with Y (yellow), S (blue), or PW (pure white) illumination.
- For G (green) dual pushbuttons (with pilot light), use a LSRD lamp and an attachment lens.

LSTDB - For jumbo dome pilot lights HW1P-5Q4 only (except colors Y, S, and PW)

Part No.	LSTDB-2AN	LSTDB-2GN				
Lamp Base	BA9S/13					
Voltage Range	24V AC/DC±10%					
Current Draw	14mA	8mA				
Rated Voltage	24V AC/DC					
Life (reference value)	Approx. 20,000 hours (The luminance is reduced to 50% the initial intensity when used on complete DC at 25°C.)					
Internal Circuit	X1 — Limited current circuit Noise protection circuit Rectifier circuit Dimmer protection circui	G G	LED chip Rectifier diode Zener diode Resistor			

- Use an A (amber) LED for (R) red illumination.
- $\bullet \ \ \text{Use a LSRD-2 lamp for dome pilot lights with Y (yellow), S (blue), or PW (pure \ white) illumination.}$

Emergency
Stop Switches
Enabling
Switches
Safety Products
Explosion Proof
Terminal Blocks
Relays & Sockets
Circuit
Protectors
Power Supplies
LED Illumination
Controllers
Operator
Interfaces
Sensors
AUTO-ID
Flush Silhouette
ø16

HW	
TW	
YW	

Pilot Lights

ø30 Miniature

Pilot Lights

TW

YW

Specifications

×	- 1 - 1 - 1 - 1 - 1 - 1 - 1 - 1 - 1 - 1				
Pilot Li	Operating Temperature	Non-illuminated: -25 to +60°C (no freezing) Illuminated: -25 to +50°C (no freezing) Jumbo dome pilot lights: -25 to +55°C (no freezing)			
ghts	Operating Humidity	45 to 85% RH (no condensation)			
0,	Storage Temperature	-40 to +80°C (no freezing)			
	Contact Resistance	50 mΩ maximum (initial value)			
APEM	Insulation Resistance	100 MΩ minimum (500V DC megger)			
Switches & Pilot Lights	Dielectric Strength	Between live and dead metal parts: 2,500V AC, 1 minute (Full voltage and illuminated units: 2,000V AC, 1 minute) (*1)			
Control Boxes	Vibration Resistance	Damage limits: 30 Hz, amplitude 1.5 mm			
Emergency	VIDIATION NOSISTANCE	Operating extremes: 5 to 55 Hz, amplitude 0.5 mm			
Stop Switches Enabling	Shock Resistance	Damage limits: 1,000m/s ²			
Switches	SHOCK HESISTATICE	Operating extremes: 100m/s ²			
Safety Products		Pushbutton, Illuminated pushbutton Momentary············5,000,000			
Explosion Proof		Maintained			
Terminal Blocks	Mechanical Life (minimum	Selector switch 500,000 Key selector switch (Disc tumbler) 500,000			
Relays & Sockets	operations)	Key selector switch (Pin tumbler)			
Circuit Protectors		Pushbutton selector 250,000 Mono-lever switches 250,000			
Power Supplies		Pushbutton, Illuminated pushbutton			
LED Illumination		Momentary			
Controllers		Dual pushbutton500,000 (*2)			
Operator Interfaces	Electrical Life (*5)	Selector switch			
Sensors		Illuminated selector switch 500,000 (*3)			
AUTO-ID		Pushbutton selector 250,000 (*3) Mono-lever switches 250,000 (*4)			
		66g (HW1B-M122) 20g (HW1P-1Q4) 84g (HW1L-M122Q4)			
Flush Silhouette		66g (HW1S-2T22) 94g (HW1K-2A22)			
ø16	Weight (Apporox.)	72g (HW1K-2JPC11) 84g (HW1F-222Q4)			
ø22		71g (HW1R-2A22) 82g (HW1M-2222-22N9)			
ø30		72g (HW7D-B1111111) 90g (HW7D-L111111Q4)			
Miniature	*1) Dielectric strength f	for dual pushbuttons are as follows:			

*1) Dielectric strength for dual pushbuttons are as follows:


Full voltage type: 1,000V AC, 1 minute (between live and dead metal parts) Transformer and DC-DC converter types: 2,000V AC, 1 minute (between live and dead metal parts)

- *2) Switching frequency 1,800 operations/h, duty ratio 40%
- *3) Switching frequency 1,200 operations/h, duty ratio 40%
- *4) Switching frequency 900 operations/h, duty ratio 40%
- *5) Load condition 220V AC, 3A (AC-15)

Mounting Hole Layout

All dimensions in mm.

Panel Cut (IEC60947-5-1)



- . The minimum mounting centers are applicable to switches with one layer of contact blocks (one to two contact blocks). When two layers of contact blocks are mounted, determine the minimum mounting centers in consideration of convenience for wiring.
- · When high temperature is expected, take necessary measures such as securing sufficient mounting centers or using a cooling fan.

Minimum Mounting Centers

(Dimensions in mm)

Unit	A (*6)	B (*7)
ø40mm mushroom button	50	40
Pushbutton selector	50	50
Mono-lever switch	72	72
Pilot light	30	30
Jumbo dome pilot light	85	85
Dual pushbutton switch	55	30
Illuminated selector switch	50	50

- When using the safety lever lock, determine the vertical spacing (*6) in consideration of convenience for installing and removing the safety lever lock. (Recommended vertical spacing: 100 mm)
- The minimum length of vertical spacing (*6) is 45 mm when safety lever lock is not used.
- . The 3.2 mm recess is for preventing rotation and is not necessary when the nameplate or anti-rotation ring is not used.

Degree of Protection

Unit	IEC 60529
All units except dual pushbutton switches	IP65 (*8)
Dual pushbutton switches	IP40 (*9)

- *8) When using a nameplate with the HW series, IP65 protection degree is achieved only when nameplates shown on B-216 are used. (IP40 when other ø22 namplates such as NWA are used)
- *9) IP65 protection degree when HW9Z-D7D button cover is used.

Ordering Information

Standard models

- . Specify Ordering No. when ordering.
- Specify a button or lens color code in place of *.
- · Pilot lights, illuminated pushbuttons, and illuminated selector switches have an LED lamp installed unless otherwise specified.
- Nameplates and accessories for mono-lever switch are ordered separately. See B-216 to B-218.

Ordering Information

Pushbuttons (B-187 to B-189)

When specifying gold-plated silver contact and contact configuration:

```
HW1B-M1 <u>11</u> R -<u>MAU</u>
                                   Optional contact
                                                         MAU: Gold contact
                                   Contact configuration
                                                         10:
                                                               1N0
                                                         01:
                                                                1NC
                                                               1N01NC
                                                         11:
                                                         20:
                                                               2N0
                                                         02:
                                                               2NC
                                                         22:
                                                               2N02NC
                                                         40:
                                                               4N0
                                                         04:
                                                               4NC
                                                         13:
                                                               1N03NC
                                                               3N01NC
                                                         31:
                                                         30:
                                                               3N0
                                                         03:
                                                               3NC
                                                               1N02NC
                                                         12:
                                                         21:
                                                               2N01NC
```

Pilot Lights (B-190)

When specifying LED operating voltage:

```
HW1P-1 <u>H2</u> R
                                  Operating voltage
                                                        Q0:
                                                              Without LED lamp
                                                        Q2:
                                                              6V AC/DC
                                                        Q3:
                                                              12V AC/DC
                                                              24V AC/DC
                                                        04:
                                                        H2:
                                                              100/110V AC
                                                        H22:
                                                              115/120V AC
                                                        M2:
                                                              200/220V AC
                                                        M42:
                                                              230/240V AC
                                                        S2:
                                                              380V AC
                                                        T2:
                                                              400/440V AC
```

T82:

D2:

480V AC

110V DC

Illuminated Pushbuttons (B-192 to B-196)

When specifying gold-plated silver contact, contact configuration, and LED operating voltage:

```
HW1L-M1 <u>11</u> <u>H2</u> R - <u>MAU</u>
                                                              Gold contact
                                   Optional contact
                                                        MAU
                                  Operating Voltage
                                                        OO:
                                                              Without LED lamp
                                                        Q2:
                                                              6V AC/DC
                                                              12V AC/DC
                                                        Q4:
                                                              24V AC/DC
                                                               100/110V AC
                                                        H2:
                                                        H22:
                                                              115/120V AC
                                                        M2:
                                                              200/220V AC
                                                        M42:
                                                              230/240V AC
                                                        S2:
                                                               380V AC
                                                               400/440V AC
                                                        T2:
                                                        T82:
                                                              480V AC
                                                        D2:
                                                               110V DC
                                   Contact configuration
                                                        10:
                                                               1N0
                                                               1NC
                                                        01:
                                                               1N01NC
                                                        11:
                                                        20:
                                                              2N0
                                                        02:
                                                               2NC
                                                        22:
                                                               2N02NC
                                                        40:
                                                              4N0
                                                        04:
                                                              4NC
                                                        13:
                                                               1N03NC
                                                        31:
                                                               3N01NC
                                                               3N0
                                                        30:
                                                        03:
                                                               3NC
                                                               1NO2NC
                                                        12:
                                                        21:
                                                              2N01NC
```

Note:

• Odd number of contact blocks, such as 1NO, 1NC, 3NO, 2NO-1NC, 1NO-2NC, and 3NC, is not available for transformer type or DC-DC converter type.

APEM

Switches & Pilot Lights

Control Boxes

Emergency Stop Switches Enabling Switches

Safety Products

Explosion Proof

Terminal Blocks

Relays & Sockets

Circuit

Protectors
Power Supplies

LED Illumination

Controllers

Operator Interfaces

Sensors

AUTO-ID

Flush Silhouette

ø16

ø22

ø30

Miniature

Pilot Lights

HW

TW

Control Boxes

Stop Switches Enabling

Safety Products

Explosion Proof Terminal Blocks

Relays & Sockets

LED Illumination

Controllers

Operator Interfaces

Sensors

AUTO-ID

Flush Silhouette

ø16

ø30

TW

YW

Miniature

Pilot Lights

Circuit

Protectors **Power Supplies**


Emergency

Switches

Ordering Information


Dual Pushbutton Switches [without pilot light] (B-199)

When specifying gold-plated silver contact and contact configuration:



Dual Pushbutton Switches [with pilot light] (B-200)

When specifying gold-plated silver contact, contact configuration, and LED operating voltage:




Only the below combinations are possible.

Contact configuration						
Top button	Button button					
1NO	1NC					
1NO	1NO					
1NO-1NC	1NO-1NC					
2N0	2NC					
2NU	2NC					

Ordering Information

Key Selector Switches (Pin Tumbler Key) (B-204 to B-205)

When specifying gold-plated silver contact, key removal position, and key number:



MAU: Gold-plated silver

-501 - 515

3-position

2-position A: Removable in all positions

B: Removable in the left only

C: Removable in the right only

A: Removable in all positions

B: Removable in the left and center

C: Removable in the right and center D: Removable in center only

E: Removable in right and left

G: Removable in left only

H: Removable in right only

Blank, J, or S

2: 2-position, maintained

21: 2-position, spring return from right

3: 3-position, maintained

31: 3-position, spring return from right

32: 3-position, spring return from left


33: 3-position, spring return two way

Note:

- The key cannot be removed in a spring return position.
- The key number is engraved on the key cylinder. (default key is not engraved with a number)

Key Selector Switches (Disc Tumbler Key) (B-206 to B-207)

When specifying gold-plated silver contact, key removal position, and key number:




Note:

- \bullet The key cannot be removed in a spring return position.
- \bullet The key number is engraved on the key cylinder. (default key is not engraved with a number)

Illuminated Selector Switches (B-208 to B-209)

When specifying gold-plated silver contact and LED operating voltage:



MAU: Gold-plated silver

Q0: Without LED lamp 200/220V AC M2: 6V AC/DC M42: 230/240V AC Q2: Q3: 12V AC/DC S2: 380V AC 24V AC/DC 400/440V AC 04: T2: H2: 100/110V AC 480V AC

H22: 115/120V AC

Blank (Knob), L (Lever)

Blank, J, or S $\,$

2: 2-position, maintained

21: 2-position, spring return from right

3: 3-position, maintained

31: 3-position, spring return from right

32: 3-position, spring return from left

33: 3-position, spring return two way

Selector Switches (B-203)

When specifying gold-plated silver contact

HW1S- 2T11 - MAU Ontional contact

Optional contact MAU: Gold-plated silver

• See B-203 for operator position.

0---

APEM

Control Boxes

Emergency Stop Switches

Enabling Switches

Safety Products

Explosion Proof

Terminal Blocks

Relays & Sockets

Circuit Protectors

Power Supplies

LED Illumination

Controllers Operator

Interfaces

Sensors

AUTO-ID

Flush Silhouette

ø16

ø22

ø30 Miniature

Pilot Lights

HW

TW

Flush / Extended / Mushroom Pushbuttons

Package Quantity: 1

<u> </u>							i ackage Quantity. I
ot Lights	Shape	Operation	Contact	Part No.	Color Code	Dimensions (mm)	
ght	Flush		1N0	HW1B-M110*			
S	HW1B-M1		1NC	HW1B-M101*			
	HW1B-A1	Momentary	1NO-1NC	HW1B-M111*		Gasket Locking Ring Panel Thickness 0.8 to 6	
		Momentary	2N0	HW1B-M120*			LOCK
APEM			2NC	HW1B-M102*	B G		
Switches &			2NO-2NC	HW1B-M122*	R		
Pilot Lights			1NO	HW1B-A110*	Y		
Control Boxes			1NC	HW1B-A101*	S		
Emergency	a a		1NO-1NC	HW1B-A111*	W	49.4 (1 or 2 blocks) 0.5	ø23.6 29.4
Stop Switches		Maintained	2N0	HW1B-A120*		69.4 (3 or 4 blocks)	
Enabling Switches	Extended		2NC HW1B-A102*				
Safety Products			2NO-2NC	HW1B-A122*			
			1NO	HW1B-M210*			
Explosion Proof	HW1B-M2		1NC	HW1B-M201*			
Terminal Blocks	HW1B-A2		1NO-1NC	HW1B-M211*			
		Momentary	2N0	HW1B-M220*		Gasket Locking Ring Panel Thickness 0.8 to 6	
Relays & Sockets	_		2NC	HW1B-M202*	В	T .	LOCK TOOK
Circuit			2NO-2NC	HW1B-M222*	. G R		
Protectors			1NO	HW1B-A210*	Y		
Power Supplies			1NC	HW1B-A201*	S		
LED Illumination			1NO-1NC	HW1B-A211*	W	10.5	
LED IIIUIIIIIauoii		Maintained	2N0	HW1B-A220*		49.4 (1 or 2 blocks) 13 69.4 (3 or 4 blocks) 19	29.4
Controllers			2NC	HW1B-A202*			
Operator			2NO-2NC	HW1B-A222*			
Interfaces	.00 . 14 . 1		1NO	HW1B-M310*			
Sensors	ø29mm Mushroom HW1B-M3		1NC	HW1B-M301*			
AUTO ID	HW1B-A3		1NO-1NC	HW1B-M311*		Gasket Locking Ring Panel Thickness 0.8 to 6	
AUTO-ID		Momentary	2N0	HW1B-M320*		Panel Thickness 0.8 to 6	LOCK
			2NC		В		
			2NO-2NC	HW1B-M302* HW1B-M322*	G		
			1NO	HW1B-A310*	R Y	 	\(\(\frac{1}{2}\)
Flush Silhouette			1NC	HW1B-A301*	S		
ø16	T G		1NO-1NC	HW1B-A311*	W	49.4 (1 or 2 blocks) 0.5	
		Maintained	2NO	HW1B-A320*		69.4 (3 or 4 blocks) 23.2	< 29.4
ø22			2NC	HW1B-A302*			
ø30			2NO-2NC	HW1B-A322*			
			1NO				
Miniature	ø40mm Mushroom HW1B-M4		1NC	HW1B-M410* HW1B-M401*			
Pilot Lights	HW1B-A4		1NO-1NC	HW1B-M411*		October	
		Momentary	2N0	HW1B-M420*		Gasket Locking Ring Panel Thickness 0.8 to 6	1 /0
			2NC	HW1B-M402*	В		TOP!
			2NO-2NC	HW1B-M422*	G		
HW			1NO	HW1B-A410*	R Y	□ -	
77.4			1NC	HW1B-A410*	Š		
TW			1NO-1NC	HW1B-A411*	W	0.5	
YW		Maintained	2N0	HW1B-A420*		49.4 (1 or 2 blocks) 3 3 69.4 (3 or 4 blocks) 23.2	29.4
			2NC	HW1B-A420*		< 	
			2NO-2NC	HW1B-A422*			
	aCOmena Mustinia						
	ø60mm Mushroom HW1B-M5		1NO	HW1B-M510*		Gasket Panel Thickness 0.8 to 6 Locking Ring	LOCK
	CINI-OI MAII		1NC	HW1B-M501*			
		Momentary	1NO-1NC	HW1B-M511*	B G		-(
		IVIOIIICIIIAIY	2N0	HW1B-M520*	R		
			2NC	HW1B-M502*		49.4 (1 or 2 blocks)	29.4

49.4 (1 or 2 blocks)

69.4 (3 or 4 blocks)

29.4

• Specify a color code in place of * in Part No. B (black), G (green), R (red), Y (yellow), S (blue), W (white)

2NO-2NC

HW1B-M522*

- Pushbuttons with 1 or 3 contact blocks have a dummy block.
- See B-184 for other contact configurations and gold-plated silver contacts.
- Pushbuttons: M3.5 Terminal screws integrated terminal cover

IDEC


Square Flush / Square Flush Pushbuttons

Package Quantity: 1


Shape	Operation	Contact	Part No.	Color Code	Dimensions (mm)
Square Flush		1NO	HW2B-M110*		
HW2B-M1		1NC	HW2B-M101*	1	
HW2B-A1	Momentony	1NO-1NC	HW2B-M111*	1	Gasket Locking Ring Panel Thickness 0.9 to 6
	Momentary	2N0	HW2B-M120*	1 ,	Panel Thickness 0.8 to 6
		2NC	HW2B-M102*	B G	
		2NO-2NC	HW2B-M122*	R	
		1NO	HW2B-A110*	Y	
		1NC	HW2B-A101*	S W	
	Maintained	1NO-1NC	HW2B-A111*] vv	49.4 (1 or 2 blocks) 24.8
	iviaiiitaiiieU	2N0	HW2B-A120*]	69.4 (3 or 4 blocks) 13
		2NC HW2B-A102*			
		2NO-2NC	HW2B-A122*		
Square Extended		1NO	HW2B-M210*		
HW2B-M2		1NC	HW2B-M201*		
HW2B-A2	Momentary	1NO-1NC	HW2B-M211*		Gasket
_	Wiorrieritary	2N0	HW2B-M220*	В	Panel Thickness 0.8 to 6
		2NC	HW2B-M202*	G	
		2NO-2NC	HW2B-M222*	R	
		1NO	HW2B-A210*	Y	
		1NC	HW2B-A201*	S W	
Car Carlot	Maintained	1NO-1NC	HW2B-A211*] "	0.5
	Widintallied	2N0	HW2B-A220*]	49.4 (1 or 2 blocks) 13 69.4 (3 or 4 blocks) 19
		2NC	HW2B-A202*]	
		2NO-2NC	HW2B-A222*		

- Specify a color code in place of * in Part No. B (black), G (green), R (red), Y (yellow), S (blue), W (white)
- Pushbuttons with 1 or 3 contact blocks have a dummy block.
- See B-184 for other contact configurations and gold-plated silver contacts.
- Pushbuttons: M3.5 Terminal screws


Bottom View



1NO contact block



3 contact blocks



2/4 contact blocks

- \bullet For 1NC contact, the contact block will mount on the opposite side.
- See B-227 for wiring.
- Integrated terminal cover

APEM

Switches &

Control Boxes

Emergency Stop Switches Enabling Switches

Safety Products

Explosion Proof

Terminal Blocks
Relays & Sockets

Circuit

Protectors

Power Supplies

LED Illumination

Controllers Operator

Interfaces
Sensors

AUTO-ID

Flush Silhouette

ø16

022

ø30 Miniature

Pilot Lights

- not Eighto

TW

Control Boxes Emergency Stop Switches Enabling Switches Safety Products **Explosion Proof** Terminal Blocks Relays & Sockets Circuit Protectors Power Supplies LED Illumination Controllers Operator Interfaces Sensors AUTO-ID

Round Flush / Round Extended / Mushroom with Square Bezel

Package Quantity: 1

			-			Tabhago Quantry.
	Shape	Operation	Contact	Part No.	Color Code	Dimensions (mm)
	Round Flush with Square Bezel		1NO	HW3B-M110*		
	HW3B-M1		1NC	HW3B-M101*		
	HW3B-A1	Momentary	1NO-1NC	HW3B-M111*		Gasket Locking Ring Panel Thickness 0.8 to 6
		Wiomontary	2N0	HW3B-M120*	В	Locking Ring Panel Thickness 0.8 to 6
			2NC	HW3B-M102*	G	
			2NO-2NC	HW3B-M122*	R	
			1NO	HW3B-A110*	Y	
			1NC	HW3B-A101*	S W	
		Maintained	1NO-1NC	HW3B-A111*	VV	49.4 (1 or 2 blocks) Ø23.6
		Wallitallieu	2N0	HW3B-A120*		69.4 (3 or 4 blocks) 13
			2NC	HW3B-A102*		
			2NO-2NC	HW3B-A122*		
	Round Extended		1N0	HW3B-M210*		
V H	with Square Bezel	Momentary	1NC	HW3B-M201*	B G R Y S	
	HW3B-M2		1NO-1NC	HW3B-M211*		Gasket Locking Ring Panel Thickness 0.8 to 6
	HW3B-A2		2N0	HW3B-M220*		LOCK LOCK
			2NC	HW3B-M202*		
			2NO-2NC	HW3B-M222*		
		Maintained	1N0	HW3B-A210*		
			1NC	HW3B-A201*		
			1NO-1NC	HW3B-A211*		923.6 49.4 (1 or 2 blocks) 13
			2N0	HW3B-A220*		69.4 (3 or 4 blocks) 19
			2NC	HW3B-A202*		
			2NO-2NC	HW3B-A222*		
	ø29mm Mushroom		1NO	HW3B-M310*		
	with Square Bezel		1NC	HW3B-M301*		
	HW3B-M3	Momentary	1NO-1NC	HW3B-M311*		Gasket
	HW3B-A3	Widifieritary	2N0	HW3B-M320*		Locking Ring Panel Thickness 0.8 to 6
			2NC	HW3B-M302*	B G	
			2NO-2NC	HW3B-M322*	Ř	
			1NO	HW3B-A310*	Y	F11
	1		1NC HW3B-A301*	HW3B-A301*	S	
l		Maintained	1NO-1NC	HW3B-A311*	W	49.4 (1 or 2 blocks) 13
		Maintained	2N0	HW3B-A320*	1	69.4 (3 or 4 blocks) 23.2
			2NC	HW3B-A302*	1	
					1	I .

- Miniature

ø16

ø30

Flush Silhouette

Pilot Lights

 $\bullet \ Specify \ a \ color \ code \ in \ place \ of * in \ Part \ No. \ B \ (black), \ G \ (green), \ R \ (red), \ Y \ (yellow), \ S \ (blue), \ W \ (white)$


2NO-2NC


HW3B-A322*

- Pushbuttons with 1 or 3 contact blocks have a dummy block.
- See B-184 for other contact configurations and gold-plated silver contacts.
- Pushbuttons: M3.5 Terminal screws

Bottom View

TW Dummy block





3 contact blocks

2/4 contact blocks

- For 1NC contact, the contact block will mount on the opposite side.
- See B-227 for wiring.
- Integrated terminal cover

1NO contact block

Round Flush / Dome / Square Flush / Jumbo Dome Pilot Lights

				Package Quantity: 1	Pilo:
Shape	Lamp	Operating Voltage	Part No.	Color Code	Ę
Round Flush (marking type) HW1P-1		24V AC/DC	HW1P-1Q4*		Pilot Lights
					APEM
241/ 00/00				R G	Switches & Pilot Lights
24V AC/DC	LED	100/110V AC	HW1P-1H2*	Y A S	Control Boxes
				PW	Emergency Stop Switches
					Enabling Switches
		200/220V AC	HW1P-1M2*		Safety Products
With transformer (100/110V AC)					Explosion Proof
Dome HW1P-2					Terminal Blocks
		24V AC/DC	HW1P-2Q4*		Relays & Sockets
					Circuit Protectors
				R G	Power Supplies
(24V AC/DC)	LED	100/110V AC	HW1P-2H2*	Y A	LED Illumination
and the same of th				S PW	Controllers
		200/220V AC			Operator Interfaces
			HW1P-2M2*		Sensors
With transformer (100/110V AC)					AUTO-ID
Square Flush (marking type)					
HW2P-1		24V AC/DC	HW2P-1Q4*		Flush Silhouette
					ø16
	LED	100/110V AC	HW2P-1H2*	R	ø22
(24V AC/DC)				G Y	ø30
3.50				A S	Miniature
				PW	Pilot Lights
		200/220V AC	HW2P-1M2*		
With transformer (100/110V AC)					
Jumbo Dome Pilot Light (*1)					HW
HW1P-5					TW
				R G	YW
	LED	24V AC/DC	HW1P-5Q4*	Y A S PW	

- Specify a color code in place of * in Part No. R (red), G (green), Y (yellow), A (amber), S (blue), PW (pure white)
- Pilot lights have an LED lamp installed unless otherwise specified.
- See B-184 for other operating voltages.
- See B-191 for bottom view.
- See B-191 for how to specify units without LED lamps.
- *1) Jumbo dome pilot lights contain an exclusive LED. See B-182 and B-221.



Control Boxes

Emergency Stop Switches Enabling

Switches

Safety Products

Explosion Proof

Terminal Blocks Relays & Sockets Circuit

Protectors **Power Supplies**

LED Illumination

Controllers

Operator

Interfaces Sensors AUTO-ID

Flush Silhouette

ø16

ø30 Miniature

TW

YW


Pilot Lights

Dimensions All dimensions in mm.


Pilot Lights

Round Flush Terminal screws: M3.5, integrated terminal cover


6, 12, 24V AC/DC, Without LED lamp



100/110V AC, 200/220V AC (240V AC maximum)




110V DC, 380V AC minumum



Extended Terminal screws: M3.5, integrated terminal cover


6, 12, 24V AC/DC, Without LED lamp Locking Ring






60.8


110V DC, 380V AC minimum




Square Flush Terminal screws: M3.5, integrated terminal cover











110V DC, 380V AC minimum




Jumbo Dome Pilot Light Terminal screws: M3.5, integrated terminal cover




Panel Cut-Out

Mounting Centers (Except jumbo dome) Close mounting on 30 mm centers



When mounting 100/110V AC, 200/220V AC, 110V DC units on 30mm centers vertically and horizontally, keep the ambient temperature below 40°C.

Mounting Centers (Jumbo dome)




Determine the minimum mounting centers in consideration of convenience for wiring.

Pilot Light Bottom View

6, 12, 24V AC/DC Without LED lamp

100/110V AC, 200/220V, 110V DC





- For DC-DC Converter types, terminal X1 is ⊕, X2 is ⊖.
- See B-228 for wiring.

Control Boxes

Emergency
Stop Switches

Enabling
Switches

Safety Products

Explosion Proof

Terminal Blocks

Relays & Sockets

Circuit
Protectors

Power Supplies

LED Illumination

Controllers

Operator

Sensors AUTO-ID

Flush Silhouette

ø16

ø30 Miniature Pilot Lights

TW

LED

Round Flush / Round Extended (Marking Type)

						Package Quantity: 1	
Shape	Illumination	Operation	Rated Voltage	Contact Configuration	Part No.	Color Code	
Round Flush (Marking type)				1NO	HW1L-M110Q4*		
HW1L-M1				1NC	HW1L-M101Q4*		
HW1L-A1			24V AC/DC	1NO-1NC	HW1L-M111Q4*		
			24V AG/DG	2N0	HW1L-M120Q4*		
_				2NC	HW1L-M102Q4*	R	
				2NO-2NC	HW1L-M122Q4*	G	
		Momentary		1NO-1NC	HW1L-M111H2*	Υ	
		Momentary	100/110// 40	2N0	HW1L-M120H2*	A	
			100/110V AC	2NC	HW1L-M102H2*	S	
				2NO-2NC	HW1L-M122H2*	PW	
				1NO-1NC	HW1L-M111M2*		
(24V AC/DC)			000/0001/40	2N0	HW1L-M120M2*		
(247 /10/20)			200/220V AC	2NC	HW1L-M102M2*		
				2NO-2NC	HW1L-M122M2*		
	LED -			1NO	HW1L-A110Q4*		
				1NC	HW1L-A101Q4*		
				1NO-1NC	HW1L-A111Q4*		
The same of the sa			24V AC/DC	2N0	HW1L-A120Q4*		
				2NC	HW1L-A102Q4*		
				2NO-2NC	HW1L-A122Q4*	— R	
				1NO-1NC	HW1L-A111H2*	G Y	
		Maintained		2N0	HW1L-A120H2*	Ä	
			100/110V AC	2NC	HW1L-A102H2*	S	
				2NO-2NC	HW1L-A122H2*	PW	
With transformer				1NO-1NC	HW1L-A111M2*		
(100/110V AC)				2N0	HW1L-A120M2*		
			200/220V AC	2NC	HW1L-A102M2*	_	
				2NO-2NC	HW1L-A122M2*	_	
				1NO	HW1L-M210Q4*		
ound Extended (Marking type)				1NC	HW1L-M201Q4*		
W1L-M2 W1L-A2				1NO-1NC	HW1L-M211Q4*	_	
WIL-AZ			24V AC/DC	2NO	HW1L-M220Q4*		
				2NC	HW1L-M202Q4*		
				2NO-2NC	HW1L-M222Q4*	R	
1				1NO-1NC	HW1L-M211H2*	G	
		Momentary				Y	
			100/110V AC	2NO 2NC	HW1L-M220H2* HW1L-M202H2*	A S	
				2NC-2NC		PW	
				2NO-2NC 1NO-1NC	HW1L-M222H2*	_	
				2NO	HW1L-M211M2* HW1L-M220M2*	_	
(24V AC/DC)			200/220V AC			_	
				2NC	HW1L-M202M2* HW1L-M222M2*	_	
	LED -			2NO-2NC			
				1NO	HW1L-A210Q4*	_	
				1NC	HW1L-A201Q4*	_	
and the same of th			24V AC/DC	1NO-1NC	HW1L-A211Q4*	_	
N. P. B.				2NO	HW1L-A220Q4*	_	
				2NC	HW1L-A202Q4*	R	
				2NO-2NC	HW1L-A222Q4*	G	
		Maintained		1NO-1NC	HW1L-A211H2*	Y	
			100/110V AC	2N0	HW1L-A220H2*	A e	
				2NC	HW1L-A202H2*	S PW	
With transformer				2NO-2NC	HW1L-A222H2*		
(100/110V AC)				1NO-1NC	HW1L-A211M2*		
			200/220VAC	2N0	HW1L-A220M2*		
			200,220 170	2NC	HW1L-A202M2*		
				2NO-2NC	HW1L-A222M2*		

- Specify a color code in place of * in Part No. R (red), G (green), Y (yellow), A (amber), S (blue), PW (pure white)
- \bullet Illuminated pushbuttons have an LED lamp installed unless otherwise specified.
- \bullet See B-184 for other operating voltage such as 6V AC/DC, 12V AC/DC, and 110V DC.
- See B-184 for other contact configurations and gold-plated silver contacts.
- Illuminated pushbutttons of 24V AC/DC or below with 2 or 4 contact blocks have a dummy block.
- See B-198 for bottom view.
- See B-184 for how to specify units without LED lamps.



Control Boxes Emergency Stop Switches Enabling Switches Safety Products **Explosion Proof** Terminal Blocks Relays & Sockets Circuit Protectors Power Supplies LED Illumination Controllers Operator Interfaces Sensors AUTO-ID

LED

Round Extended with Full Shroud (Marking Type)

Package Quantity: 1

Shape	Illumination	Operation	Rated Voltage	Contact	Part No.	Color Code
Round Extended with Full Shroud				1NO	HW1L-MF210Q4*	
(Marking type)				1NC	HW1L-MF201Q4*	
HW1L-MF2			0.41/ A.C/D.C	1NO-1NC	HW1L-MF211Q4*	
HW1L-AF2			24V AC/DC	2N0	HW1L-MF220Q4*	
				2NC	HW1L-MF202Q4*	
				2NO-2NC	HW1L-MF222Q4*	R G
		Mamantani		1NO-1NC	HW1L-MF211H2*	Ϋ́
		Momentary	100/110V AC	2N0	HW1L-MF220H2*	A
			100/110V AC	2NC	HW1L-MF202H2*	S PW
				2NO-2NC	HW1L-MF222H2*	PVV
				1NO-1NC	HW1L-MF211M2*	
(24V AC/DC)	LED -		200/220V AC	2N0	HW1L-MF220M2*	
(247 /10/30)			200/220V AG	2NC	HW1L-MF202M2*	
				2NO-2NC	HW1L-MF222M2*	
	LLD			1NO	HW1L-AF210Q4*	
				1NC	HW1L-AF201Q4*	
			24V AC/DC	1NO-1NC	HW1L-AF211Q4*	
1			24V AU/DU	2N0	HW1L-AF220Q4*	
				2NC	HW1L-AF202Q4*	R
				2NO-2NC	HW1L-AF222Q4*	G
		Maintained		1NO-1NC	HW1L-AF211H2*	Ϋ́
		Manitanieu	100/110V AC	2N0	HW1L-AF220H2*	A
			100/110V AC	2NC	HW1L-AF202H2*	S PW
With transformer				2NO-2NC	HW1L-AF222H2*	- FVV
(100/110V AC)				1NO-1NC	HW1L-AF211M2*	
			200/220V AC	2N0	HW1L-AF220M2*	
			200/220V AC	2NC	HW1L-AF202M2*	
				2NO-2NC	HW1L-AF222M2*	

Flush Silhouette

ø16

ø30

Miniature

Pilot Lights

HW TW

- Specify a color code in place of * in Part No. R (red), G (green), Y (yellow), A (amber), S (blue), PW (pure white)
- \bullet Illuminated pushbuttons have an LED lamp installed unless otherwise specified.
- See B-184 for other operating voltage such as 6V AC/DC, 12V AC/DC, and 110V DC.
- See B-184 for other contact configurations and gold-plated silver contacts.
- Illuminated pushbutttons of 24V AC/DC or below with 2 or 4 contact blocks have a dummy block.
- See B-198 for bottom view.

LED

Square Flush / Round Flush with Square Bezel (Marking Type)

						Package Quantity: 1	;
Shape	Illumination	Operation	Illumination	Contact	Part No.	Color Code	Pilot Lights
Square Flush (Marking type)				1NO	HW2L-M110Q4*		igh
HW2L-M1				1NC	HW2L-M101Q4*		S
HW2L-A1			24V AC/DC	1NO-1NC	HW2L-M111Q4*		
			24V AG/DG	2N0	HW2L-M120Q4*		
				2NC	HW2L-M102Q4*	— R	APEM
April 1				2NO-2NC	HW2L-M122Q4*	G	Switches &
		Momentary		1NO-1NC	HW2L-M111H2*	Υ Υ	Pilot Lights
		momoritary	100/110V AC	2N0	HW2L-M120H2*	A C	Control Boxes
				2NC	HW2L-M102H2*	S PW	Emergency
The state of the s				2NO-2NC	HW2L-M122H2*		Stop Switches
				1NO-1NC	HW2L-M111M2*		Enabling
(24V AC/DC)			200/220V AC	2N0	HW2L-M120M2*	_	Switches
(247 A0/80)				2NC	HW2L-M102M2*	_	Safety Products
	LED			2NO-2NC	HW2L-M122M2*		Explosion Proof
				1NO	HW2L-A110Q4*	_	- Explosion 1 1001
				1NC	HW2L-A101Q4*	_	Terminal Block
Acres of the Control			24V AC/DC	1NO-1NC	HW2L-A111Q4*		Relays & Socke
				2N0	HW2L-A120Q4*		
				2NC 2NO-2NC	HW2L-A102Q4*	R G	Circuit Protectors
				1NO-1NC	HW2L-A122Q4* HW2L-A111H2*	Ϋ́	
O B		Maintained		2N0	HW2L-A111H2*	— А	Power Supplies
			100/110V AC	2NC	HW2L-A102H2*	S S	LED Illuminatio
With transformer				2NO-2NC	HW2L-A122H2*	PW	
With transformer (100/110V AC)				1NO-1NC	HW2L-A111M2*		Controllers
(100/1104 A0)				2N0	HW2L-A120M2*	_	Operator
			200/220V AC	2NC	HW2L-A102M2*		Interfaces
				2NO-2NC	HW2L-A122M2*	_	Sensors
Round Flush with Square Bezel				1NO	HW3L-M110Q4*		AUTO-ID
Marking type)				1NC	HW3L-M101Q4*		
W3L-M1				1NO-1NC	HW3L-M111Q4*		
lW3L-A1			24V AC/DC	2N0	HW3L-M120Q4*		
				2NC	HW3L-M102Q4*	R	Fluck Cilbanati
_				2NO-2NC	HW3L-M122Q4*	G	Flush Silhouet
The state of the s				1NO-1NC	HW3L-M111H2*	Y	ø16
		Momentary	100/110/110	2N0	HW3L-M120H2*	A S	
			100/110V AC	2NC	HW3L-M102H2*	PW	ø22
				2NO-2NC	HW3L-M122H2*		ø30
The second second				1NO-1NC	HW3L-M111M2*		
			200/220V AC	2N0	HW3L-M120M2*		Miniature
(24V AC/DC)			200/220V AC	2NC	HW3L-M102M2*		Pilot Lights
(24V AO/DO)	LED			2NO-2NC	HW3L-M122M2*		- not Eighto
				1NO	HW3L-A110Q4*		
				1NC	HW3L-A101Q4*		
			24V AC/DC	1NO-1NC	HW3L-A111Q4*		HW
AUGUS .			24V AU/DU	2N0	HW3L-A120Q4*		HW
				2NC	HW3L-A102Q4*	R R	TW
				2NO-2NC	HW3L-A122Q4*	G	
		Maintained		1NO-1NC	HW3L-A111H2*	Y	YW
The state of the s		aiuiiou	100/110V AC	2N0	HW3L-A120H2*	A	
			100,710710	2NC	HW3L-A102H2*	S PW	
With transformer				2NO-2NC	HW3L-A122H2*	F VV	
(100/110V AC)				1NO-1NC	HW3L-A111M2*		
(200/220V AC	2N0	HW3L-A120M2*		
			200,220710	2NC	HW3L-A102M2*		
				2NO-2NC	HW3L-A122M2*		

- $\bullet \ \, \text{Specify a color code in place of} * \ in \ Part \ No. \ R \ (\text{red}), \ G \ (\text{green}), \ Y \ (\text{yellow}), \ A \ (\text{amber}), \ S \ (\text{blue}), \ PW \ (\text{pure white})$
- Illuminated pushbuttons have an LED lamp installed unless otherwise specified.
- See B-184 for other operating voltage such as 6V AC/DC, 12V AC/DC, and 110V DC.
- \bullet See $\ensuremath{\text{B-184}}$ for other contact configurations and gold-plated silver contacts.
- Illuminated pushbutttons of 24V AC/DC or below with 2 or 4 contact blocks have a dummy block.
- See B-198 for bottom view.

Control Boxes

Emergency
Stop Switches

Enabling
Switches

Safety Products

Explosion Proof

Terminal Blocks

Relays & Sockets

Circuit
Protectors

Power Supplies

LED Illumination

Controllers

Sensors AUTO-ID

Flush Silhouette

ø16

ø30 Miniature Pilot Lights

TW

LED

Mushroom (ø29mm) / Mushroom (ø29mm) with Square Bezel (Marking Type)

							Package Quantity: 1
	Shape	Illumination	Operation	Illumination	Contact	Part No.	Color Code
	ø29mm Mushroom				1NO	HW1L-M310Q4*	
	(Marking type)				1NC	HW1L-M301Q4*	
	HW1L-M3			24V AC/DC	1NO-1NC	HW1L-M311Q4*	
	HW1L-A3			24V AU/DU	2N0	HW1L-M320Q4*	
					2NC	HW1L-M302Q4*	R
					2NO-2NC	HW1L-M322Q4*	G
			Momentary		1NO-1NC	HW1L-M311H2*	Y
_			Williamy	100/110V AC	2N0	HW1L-M320H2*	A
_				100/110V AC	2NC	HW1L-M302H2*	S
;					2NO-2NC	HW1L-M322H2*	PW
_ 					1NO-1NC	HW1L-M311M2*	
_				200/220V AC	2N0	HW1L-M320M2*	
;	(24V AC/DC)			200/220V AC	2NC	HW1L-M302M2*	
_		LED			2NO-2NC	HW1L-M322M2*	
Ī		LED			1NO	HW1L-A310Q4*	
-					1NC	HW1L-A301Q4*	
_	_			041/ AC/DC	1NO-1NC	HW1L-A311Q4*	
3				24V AC/DC	2N0	HW1L-A320Q4*	
- t					2NC	HW1L-A302Q4*	R
3					2NO-2NC	HW1L-A322Q4*	G
-			Maintain ad		1NO-1NC	HW1L-A311H2*	Ϋ́
_			Maintained	100/110/110	2N0	HW1L-A320H2*	Α
1				100/110V AC	2NC	HW1L-A302H2*	S
-					2NO-2NC	HW1L-A322H2*	PW
_	With transformer			200/220V AC	1NO-1NC	HW1L-A311M2*	
r	(100/110V AC)				2N0	HW1L-A320M2*	
_					2NC	HW1L-A302M2*	
3					2NO-2NC	HW1L-A322M2*	
)	ø29mm Mushroom with Square				1NO	HW3L-M310Q4*	
_	Bezel (Marking type)				1NC	HW3L-M301Q4*	
	HW3L-M3			0.41/ 4.0/00	1NO-1NC	HW3L-M311Q4*	
	HW3L-A3			24V AC/DC	2N0	HW3L-M320Q4*	
_					2NC	HW3L-M302Q4*	
) —	_				2NO-2NC	HW3L-M322Q4*	R G
6					1NO-1NC	HW3L-M311H2*	Ϋ́
			Momentary	100/110/110	2N0	HW3L-M320H2*	Α
2				100/110V AC	2NC	HW3L-M302H2*	S
<u> </u>					2NO-2NC	HW3L-M322H2*	PW
_					1NO-1NC	HW3L-M311M2*	
,				000/000// 40	2N0	HW3L-M320M2*	
_	(24V AC/DC)			200/220V AC	2NC	HW3L-M302M2*	
- -		LED			2NO-2NC	HW3L-M322M2*	
		LED			1NO	HW3L-A310Q4*	
					1NC	HW3L-A301Q4*	
				0.41/ 4.0/D0	1NO-1NC	HW3L-A311Q4*	
1	Carried Co.			24V AC/DC	2N0	HW3L-A320Q4*	
_					2NC	HW3L-A302Q4*	R
_					2NO-2NC	HW3L-A322Q4*	G
1			Mainteire		1NO-1NC	HW3L-A311H2*	— u
-	U AS		Maintained	100/110110	2N0	HW3L-A320H2*	Α
				100/110V AC	2NC	HW3L-A302H2*	S
	Mith transfer				2NO-2NC	HW3L-A322H2*	PW
	With transformer (100/110V AC)				1NO-1NC	HW3L-A311M2*	
	(100/110 V AO)			000/000115	2N0	HW3L-A320M2*	
				200/220V AC	2NC	HW3L-A302M2*	
					2NO-2NC	HW3L-A322M2*	
	L			-1			

- Specify a color code in place of * in Part No. R (red), G (green), Y (yellow), A (amber), S (blue), PW (pure white)
- Illuminated pushbuttons have an LED lamp installed unless otherwise specified.
- See B-184 for other operating voltage such as 6V AC/DC, 12V AC/DC, and 110V DC.
- See B-184 for other contact configurations and gold-plated silver contacts.
- Illuminated pushbutttons of 24V AC/DC or below with 2 or 4 contact blocks have a dummy block.
- See B-198 for bottom view.

Control Boxes

Emergency
Stop Switches

Enabling
Switches

Safety Products

Explosion Proof

Terminal Blocks

Relays & Sockets

Circuit
Protectors

Power Supplies

LED Illumination

Controllers

Operator

LED

Mushroom (ø40mm) (Marking Type)

Package Quantity: 1

Shape	Illumination	Operation	Illumination	Contact	Part No.	Color Code
ø40mm Mushroom				1NO	HW1L-M410Q4*	
(Marking type)				1NC	HW1L-M401Q4*	
HW1L-M4			24V AC/DC	1NO-1NC	HW1L-M411Q4*	
HW1L-A4				2N0	HW1L-M420Q4*	
				2NC	HW1L-M402Q4*	
				2NO-2NC	HW1L-M422Q4*	R G
		Momentary		1NO-1NC	HW1L-M411H2*	Ϋ́
		ivioinemaiy	100/110V AC	2N0	HW1L-M420H2*	A
			100/110V AC	2NC	HW1L-M402H2*	S PW
				2NO-2NC	HW1L-M422H2*	F VV
				1NO-1NC	HW1L-M411M2*	
			200/220V AC	2N0	HW1L-M420M2*	
(24V AC/DC)			200/220V AC	2NC	HW1L-M402M2*	
	LED			2NO-2NC	HW1L-M422M2*	
	LED		24V AC/DC	1NO	HW1L-A410Q4*	
				1NC	HW1L-A401Q4*	
				1NO-1NC	HW1L-A411Q4*	
Auto			24V A0/D0	2N0	HW1L-A420Q4*	
				2NC	HW1L-A402Q4*	R
				2NO-2NC	HW1L-A422Q4*	G
		Maintained		1NO-1NC	HW1L-A411H2*	Υ
		Maintaineu	100/110V AC	2N0	HW1L-A420H2*	A
			100/110V AC	2NC	HW1L-A402H2*	S PW
				2NO-2NC	HW1L-A422H2*	1 44
With transformer				1NO-1NC	HW1L-A411M2*	
(100/110V AC)			200/220V AC	2N0	HW1L-A420M2*	
			200/220V AO	2NC	HW1L-A402M2*	
				2NO-2NC	HW1L-A422M2*	

- Specify a color code in place of * in Part No. R (red), G (green), Y (yellow), A (Amber), S (blue), PW (pure white)
- \bullet Illuminated pushbuttons have an LED lamp installed unless otherwise specified.
- See B-184 for other operating voltage such as 6V AC/DC, 12V AC/DC, and 110V DC.
- See B-184 for other contact configurations and gold-plated silver contacts.
- ullet Illuminated pushbutttons of 24V AC/DC or below with 2 or 4 contact blocks have a dummy block.
- See B-198 for bottom view.

Flush Silhouette

ø16

Sensors AUTO-ID

ø30

Miniature

Pilot Lights

HW TW

Control Boxes

Safety Products

Explosion Proof

Terminal Blocks

Relays & Sockets Circuit Protectors **Power Supplies** LED Illumination

> Controllers Operator Interfaces

> > Sensors

AUTO-ID

Flush Silhouette

ø16

ø30 Miniature

> TW YW

Pilot Lights

Dimensions All dimensions in mm.


Illuminated Pushbuttons (Momentary / Maintained)


Round Flush Terminal screws: M3.5, integrated terminal cover


6, 12, 24V AC/DC, Without LED lamp

100/110V AC, 200/220V AC (240V maximum)

110V DC, 380V AC minimum









Round Extended Terminal screws: M3.5, integrated terminal cover


6, 12, 24V AC/DC, Without LED lamp

100/110V AC, 200/220V AC (240V maximum)

110V DC, 380V AC minimum









Round Extended with Full Shroud


6, 12, 24V AC/DC, Without LED lamp

Terminal screws: M3.5, integrated terminal cover 100/110V AC, 200/220V AC (240V maximum)

110V DC, 380V AC minimum









Square Flush Terminal screws: M3.5, integrated terminal cover


6, 12, 24V AC/DC, Without LED lamp

100/110V AC, 200/220V AC (240V maximum)

110V DC, 380V AC minimum









Flush with Square Bezel Terminal screws: M3.5, integrated terminal cover


6, 12, 24V AC/DC, Without LED lamp

100/110V AC, 200/220V AC (240V maximum)

110V DC, 380V AC minimum







Dimensions All dimensions in mm.

Illuminated Pushbuttons (Momentary / Maintained)


Ø29mm Mushroom Terminal screws: M3.5, integrated terminal cover

6. 12. 24V AC/DC. Without LED lamp

100/110V AC, 200/220V AC (240V maximum)

110V DC, 380V AC minimum


110V DC, 380V AC minimum




ø29mm Mushroom with Square Bezel

69.4 (2 or 3 blocks)

6, 12, 24V AC/DC, Without LED lamp





APEM

Enabling Switches

Safety Products

Explosion Proof

Terminal Blocks

Circuit

Protectors

Power Supplies

Controllers

Interfaces

AUTO-ID

Flush Silhouette

ø16

ø30

TW YW

Control Boxes

Emergency Stop Switches

Relays & Sockets


LED Illumination

Operator


Sensors

Miniature


Pilot Lights




Terminal screws: M3.5, integrated terminal cover





Panel Thickness 0.8 to 6













100/110V AC, 200/220V AC

110V DC, 380V AC minimum





Bottom View


6, 12, 24V AC/DC, Without LED lamp



3 contact blocks







 \bullet For DC-DC Converter types, terminal X1 is \oplus , X2 is \ominus .

• See B-227 to B-228 for wiring.

110V DC, 380V AC minimum

Dual Pushbuttons (without Pilot Light)

Specify a button color code in place of 2 and legend code in place of 3 in the Part No.

Package Quantity: 1

APEM
Switches & Pilot Lights
Control Boxes
Emergency
Stop Switches
Enabling
Switches
Safety Products
Explosion Proof
Terminal Blocks
Relays & Sockets
Circuit
Protectors
Power Supplies

LED Illumination
Controllers

Shape

ON.
O OFF



Operation	Button Style	Cor	ntact	Part No.	2 Button Color Code	3 Legend Code
Operation	Dutton Style	Top Button	Bottom Button	raitivo.	Z Button Color Code	S Legella Code
		1NO	1NC	HW7D-B111001 2 3		
	Flush (top)	1NO	1NO	HW7D-B111010 2 3		
	Flush (bottom) Momentary	1NO-1NC	1NO-1NC	HW7D-B111111 2 3		
Momentary Flush (top)		2N0	2NC	HW7D-B112002 2 3		
		1NO	1NC	HW7D-B121001 2 3		
	Flush (top) Extended (bottom)	1NO	1NO	HW7D-B121010 2 3		
		1NO-1NC	1NO-1NC	HW7D-B121111 2 3	GR: Green (top)	Blank: Without legend
		2N0	2NC	HW7D-B122002 2 3	Red (bottom)	1: I / ON (top)
		1NO	1NC	HW7D-B211001 2 3	WB: White (top)	0 / OFF (bottom)
	Flush (top)	1NO	1NO	HW7D-B211010 2 3	Black (bottom)	
	Flush (bottom)	1NO-1NC	1NO-1NC	HW7D-B211111 2 3		
Interlock (*1)		2N0	2NC	HW7D-B212002 2 3		
interiock (1)		1NO	1NC	HW7D-B221001 2 3		
	Flush (top)	1NO	1NO	HW7D-B221010 2 3		
	Extended (bottom)	1NO-1NC	1NO-1NC	HW7D-B221111 2 3		
		2N0	2NC	HW7D-B222002 2 3		

[•] See B-202 for top and bottom button contact mounting positions.

Flush Silhouette

ø16

Operator Interfaces Sensors AUTO-ID

> ø22 ø30

Miniature

Pilot Lights

HW

TW

^{*1)} Interlock: Momentary operation. When one of the buttons is pressed, the other button cannot be operated.

Do not operate top and bottom buttons at the same time. Operating the buttons at the same time may lead to malfunctions.

LED

HW7D

Dual Pushbuttons (with Pilot Light)

Specify a LED color code in place of 1, button color code in place of 2, and legend code in place of 3 in the Part No.

Package Quantity: 1

				CA CONTRACTOR OF THE PARTY OF T	OFF			APEM Switch Pilot Li Contro Emergy Stop S'
Button Style	Illumination	Top Button	tact Bottom Button	Part No.	1LED	2 Button Color Code	3 Legend Code	Enablir Switch Safety
Flush (top) Flush (bottom) Flush (top) Extended (bottom)	24V AC/DC	1N0 1N0-1NC 2N0 1N0-1NO 1N0 1N0-1NC 2N0	1NC 1NO 1NO-1NC 2NC 1NC 1NO 1NO-1NC	HW7D-L111001Q4 1 2 3 HW7D-L111010Q4 1 2 3 HW7D-L111111Q4 1 2 3 HW7D-L112002Q4 1 2 3 HW7D-L121001Q4 1 2 3 HW7D-L121010Q4 1 2 3 HW7D-L121111Q4 1 2 3 HW7D-L122002Q4 1 2 3	G	GR: Green (top) Red (bottom)	Blank: Without legend	Explosi Termin Relays Circuit Protect
Flush (top) Flush (bottom) Flush (top) Extended (bottom)	24V AC/DC	1NO 1NO 1NO-1NC 2NO 1NO	1NC 1NO 1NO-1NC 2NC 1NC	HW7D-L211001Q4 1 2 3 HW7D-L211010Q4 1 2 3 HW7D-L211111Q4 1 2 3 HW7D-L212002Q4 1 2 3 HW7D-L221001Q4 1 2 3 HW7D-L221010Q4 1 2 3	PW	WB: White (top) Black (bottom)	1: I / ON (top) O / OFF (bottom)	Contro Operat Interface Sensor
	Flush (top) Flush (top) Extended (bottom) Flush (top) Flush (top) Flush (top) Flush (bottom)	Flush (top) Flush (bottom) 24V AC/DC Flush (top) Extended (bottom) 24V AC/DC Flush (top) Flush (top) Flush (bottom) 24V AC/DC	Button Style Illumination Top Button	Button Button Button	Button Style Illumination Top Button But	Button Style Illumination Top Button But	Button Style Illumination Top Button Color Code Color Code Color Code Color Code Color Code Color Code Color Color Code Color Code Color Code Color Code Color Code Color Code Color Color Code Color Code Color Code Color Code Color Color Code Color Color Code Code	Button Style Illumination Top Button Color Code 3 Legend Code Color Code Co

- LED lamp code: G (green), PW (pure white)
- Only W (white) lens is available.
- When replacing a G (green) LED, use an LSRD lamp and attachment lens. For details of the part no. see B-221.
- \bullet See B-185 for other operating voltage such as 100/110V AC and 200/220V AC.
- See B-185 for gold-plated silver contacts.
- Illuminated pushbutttons of 24V AC/DC or below with 2 or 4 contact blocks have a dummy block.
- See B-202 for top and bottom button contact mounting positions.
- *1) Interlock: Momentary operation. When one of the buttons is pressed, the other button cannot be operated. Do not operate top and bottom buttons at the same time. Operating the buttons at the same time may lead to malfunctions.

Control Boxes

Emergency Stop Switches Enabling Switches

Safety Products Explosion Proof

Terminal Blocks

Relays & Sockets

Circuit

Protectors Power Supplies

LED Illumination Controllers

Operator

Sensors AUTO-ID

Flush Silhouette

ø16

ø30

Miniature

Pilot Lights

TW YW

Control Boxes Emergency Stop Switches

Enabling

Switches Safety Products

Explosion Proof Terminal Blocks

Relays & Sockets Circuit Protectors **Power Supplies** LED Illumination

Controllers

Flush Silhouette


ø30


TW YW

Miniature Pilot Lights **Dimensions** All dimensions in mm.


Dual Pushbuttons


Without Pilot Light Terminal screws: M3.5, integrated terminal cover Flush (top), Flush (bottom)







Flush (top), Extended (bottom)






Flush (top), Extended (bottom) (with legend)







With Pilot Light Terminal screws: M3.5, integrated terminal cover Flush (top), Flush (bottom) (24V AC/DC)




Flush (top), Flush (bottom) (240V AC maximum)



Flush (top), Flush (bottom) (380V AC minimum)




Bottom View Without Pilot Light





2/4 contact blocks



6, 12, 24V AC/DC







380V AC minimum


- See B-227 to B-228 for wiring.
- Mounting position of the dummy block may change according to the contact configuration of the top and bottom buttons.

Contact Arrangement Chart

	Contact		Contac	t Block	Top B	utton	Bottom	Button
Top Button	Bottom Button	Contact Code	Mounting Position	Contact	Normal	Push	Normal	Push
1NO	1NO	1010	1	NO		•		
INO	TINO	1010	2	NO				•
1NO	1NC	1001	1	NO		•		
INO	INC	1001	2	NC			•	
	1NO-1NC		1)	NO		•		
1NO-1NC		1111	2	NO				•
I INO-INC			3	NC	•			
			4	NC			•	
			1)	NO		•		
2N0	2NC	2002	2	NC			•	
ZNU	ZNU	2002	3	NO		•		
			4	NC			•	

ullet Contact blocks $oldsymbol{@}$ and $oldsymbol{@}$ are actuated by the top button. Contact blocks $oldsymbol{@}$ and $oldsymbol{@}$ are actuated by the bottom button.

Contac	t Block	Top E	Button	Bottom	Button	← Button Position
Mounting Position	Contact	Normal	Push	Normal	Push	← Pushbutton Operation
1	NO		•			
2	NO				•	
3	NC	•				
4	NC			•		



With Pilot Light (Full Voltage Type)



With Pilot Light (Transformer Type)

Part No. Example HW7D-B121111GR

Contact Code

Contact Block Mounting Position

APEM

Control Boxes

Emergency Stop Switches Enabling Switches

Safety Products

Explosion Proof

Terminal Blocks

Relays & Sockets

Circuit Protectors

Power Supplies

LED Illumination

Controllers

Operator Interfaces

Sensors

AUTO-ID

Flush Silhouette

ø16

ø30

Miniature

Pilot Lights

Control Boxes

Emergency
Stop Switches

Enabling
Switches

Safety Products

Explosion Proof

Terminal Blocks

Relays & Sockets

Circuit
Protectors

Power Supplies

LED Illumination

Controllers

Sensors AUTO-ID

Flush Silhouette

ø16

ø30 Miniature Pilot Lights

TW

Selector Switches (Knob Operator)

Package Quantity: 1

Shape	Knob Opera HW1S	ator							>		Ů,
	Contact	Contact	Block	C)pera	itor Po	sition	Maintained (90°)	Spring Return from Right (60°)	_	_
	00114401	Mounting Position	Contact	1	2			1 2	1 >2		
	1NO	0	NO		•			- HW1S-2T10	HW1S-21T10		/
90°	(10)	2			_	nmy B	lock			/	
2-position/ 60°	1NO-1NC	0	NO NO	<u> </u>	•	-		HW1S-2T11	HW1S-21T11		/
2-position	(11)	2	NC	•							
	2N0 (20)	① ②	NO NO		•			HW1S-2T20	HW1S-21T20		
	(20)	0	NO NO		•						
	2NO-2NC	2	NC	•							
	(22)	3	NO		•			HW1S-2T22	HW1S-21T22		
	(/	4	NC	•	Ť						
	Contact	Contact)pera	itor Po	sition	Maintained	Spring Return from Right	Spring Return from Left	Spring Return Two-way
		Mounting Position	Contact	1	0	2			1 2		
	2N0	①									
	(20)	U	NO	•				UW1C_2T20	UW10_21T20	UW1C_22T20	UM1C_22T20
	(20)	2	NO	•		•		HW1S-3T20	HW1S-31T20	HW1S-32T20	HW1S-33T20
	2NC	② ①	NO NC	•	_	•					
	-	② ① ②	NO NC NC	•		•		HW1S-3T20 HW1S-3T02	HW1S-31T20 HW1S-31T02	HW1S-32T20 HW1S-32T02	HW1S-33T20 HW1S-33T02
	2NC (02)	② ① ② ①	NO NC NC NO	•		•					
	2NC (02) 2NO-2NC	② ① ② ① ②	NO NC NC NO			•		HW1S-3T02	HW1S-31T02	HW1S-32T02	HW1S-33T02
450	2NC (02)	② ① ② ① ② ③	NO NC NC NO NO								
45°	2NC (02) 2NO-2NC	② ① ② ① ② ③ ③	NO NC NC NO NO NO	•				HW1S-3T02	HW1S-31T02	HW1S-32T02	HW1S-33T02
45° 3-position	2NC (02) 2NO-2NC (22N1)	② ① ② ① ② ③ ④	NO NC NC NO NO NO NC NC NC NC			•		HW1S-3T02	HW1S-31T02	HW1S-32T02	HW1S-33T02
	2NC (02) 2NO-2NC (22N1)	② ① ② ① ② ③ ④ ①	NO NC NO NO NO NC NC NC NC NC NC NO	•				HW1S-3T02	HW1S-31T02	HW1S-32T02	HW1S-33T02
	2NC (02) 2NO-2NC (22N1)	② ① ② ① ② ③ ④ ① ②	NO NC NO NO NO NC NC NC NC NC NC NO NO NO NO	•		•		HW1S-3T02 HW1S-3T22N1	HW1S-31T02 HW1S-31T22N1	HW1S-32T02 HW1S-32T22N1	HW1S-33T02 HW1S-33T22N1
	2NC (02) 2NO-2NC (22N1)	② ① ② ③ ③ ④ ① ② ③	NO NC NC NO NO NO NO NC NC NC NC NC NC NO NO NO NO NO NO	•		•		HW1S-3T02 HW1S-3T22N1	HW1S-31T02 HW1S-31T22N1	HW1S-32T02 HW1S-32T22N1	HW1S-33T02 HW1S-33T22N1
	2NC (02) 2N0-2NC (22N1) 4N0 (40)	② ① ② ③ ④ ① ② ③ ④ ①	NO NC NO	•		•		HW1S-3T02 HW1S-3T22N1	HW1S-31T02 HW1S-31T22N1	HW1S-32T02 HW1S-32T22N1	HW1S-33T02 HW1S-33T22N1
	2NC (02) 2NO-2NC (22N1) 4NO (40)	② ① ② ③ ④ ① ② ③ ④ ① ②	NO NC NC NO NO NO NC	•		•		HW1S-3T02 HW1S-3T22N1	HW1S-31T02 HW1S-31T22N1	HW1S-32T02 HW1S-32T22N1	HW1S-33T02 HW1S-33T22N1
3-position	2NC (02) 2N0-2NC (22N1) 4N0 (40)	② ① ② ③ ③ ④ ① ② ③ ③ ④ ① ②	NO NC NC NO NO NO NO NC NC NO NO NO NO NO NO NO NO NC NC NC NC NC	•		•		HW1S-3T02 HW1S-3T22N1 HW1S-3T40	HW1S-31T02 HW1S-31T22N1 HW1S-31T40	HW1S-32T02 HW1S-32T22N1 HW1S-32T40	HW1S-33T02 HW1S-33T22N1 HW1S-33T40
3-position	2NC (02) 2NO-2NC (22N1) 4NO (40)	② ① ② ③ ③ ④ ① ② ③ ③ ④ ② ③ ③	NO NC NC NO NO NO NO NC NC NO NO NO NO NO NO NO NC NC NC NC NC NC			•		HW1S-3T02 HW1S-3T22N1 HW1S-3T40	HW1S-31T02 HW1S-31T22N1 HW1S-31T40	HW1S-32T02 HW1S-32T22N1 HW1S-32T40	HW1S-33T02 HW1S-33T22N1 HW1S-33T40
3-position	2NC (02) 2N0-2NC (22N1) 4N0 (40) 4NC (04)	② ① ② ③ ③ ④ ① ② ③ ③ ④ ① ②	NO NC NC NO NO NO NC NC NO NC NC NC NC NC NC NC	•		•		HW1S-3T02 HW1S-3T22N1 HW1S-3T40 HW1S-3T04	HW1S-31T02 HW1S-31T22N1 HW1S-31T40	HW1S-32T02 HW1S-32T22N1 HW1S-32T40	HW1S-33T02 HW1S-33T22N1 HW1S-33T40
3-position	2NC (02) 2N0-2NC (22N1) 4NO (40) 4NC (04)	② ① ② ③ ③ ④ ① ② ③ ③ ④ ② ③ ③	NO NC NC NO NO NO NO NC NC NO NO NO NO NO NO NO NC NC NC NC NC NC			•		HW1S-3T02 HW1S-3T22N1 HW1S-3T40	HW1S-31T02 HW1S-31T22N1 HW1S-31T40	HW1S-32T02 HW1S-32T22N1 HW1S-32T40	HW1S-33T02 HW1S-33T22N1 HW1S-33T40

- Knob operator: white indicator on black body
- On the contact arrangement marked with ★ in the table above, the rated current (load switching current) is reduced to a half of the related current of the contact block. The rated insulation voltage and the rated thermal current remain unchanged.
- For models with ☆, contacts may overlap when the operator position is changed.
- Other contact arrangements are also available. See B-211 to B-213.
- Selector switches with one or three contact blocks contain a dummy block.
- See B-186 for gold-plated silver contacts.
- Turn the operator to each position accurately.

Contact Block Mounting Position






Key Selector Switches (Pin Tumbler Key)

Package Quantity: 1

	No. of		Contact	Block	Opera	ator Po	sition		Maintained	ot Lights
Shape	Positions	Contact	Mounting Position	Contact	1	2		Cam Code	1 2	hts
Pin Tumbler Key		1NC	0	NC	•				LIMAN ODAGA	
HW1K		(01)	2	_	Dur	nmy Bl	ock	_	HW1K-2PA01	APEM
		1NO-1NC	0	NO		•			IIIMAN ODA44	
		(11)	2	NC	•			_	HW1K-2PA11	Switches & Pilot Lights
		2NC	0	NC	•				LIMAN SDAOS	Control Boxes
		(02)	2	NC	•			<u> </u>	HW1K-2PA02	
			0	NO		•		_	HW1K-2PA21	Emergency Stop Switches
		2NO-1NC	2	NC	•					Enabling
	90°		3	NO		•				Switches
	2-position		4	_	Dummy Block		ock			Safety Products
n d ->			①	NC	•					Explosion Proof
The same of the sa		3NC	2	NC	•				LINAL ODAGO	Explosion Floor
		(03)	3	NC	•			_	HW1K-2PA03	Terminal Blocks
			4	_	Dur	nmy Bl	ock			Relays & Sockets
			①	NO		•				
		2NO-2NC	2	NC	•				LIMAN ODAGO	Circuit Protectors
(NC contact only)		(22)	3	NO		•		_	HW1K-2PA22	Power Supplies
(INO COILLACT OILLY)			4	NC	•					- Ower Supplies
Fach calactor key switch is suppl	in all contains to one force							<u>. </u>		LED Illumination

- Each selector key switch is supplied with two keys.
- 15 types of key numbers are available in addition to standard (500) key. See below for details.
- Spring-return type is also available. See below for details.
- Key retained position can be selected. See below for details.

Ordering Information



21: 2-position, spring return from right

Maintained (9	0° 2-position)	Spring Return (60° 2-position)
1 2	2 1	Spring return from right
Cam code: blank	Cam code: J	Cam code: blank

- For more contact arrangement, see B-211 to B-212.
- Key selector switches with one or three contact blocks contain a dummy block.
- See B-186 for gold-plated silver contacts.
- Turn the operator to each position accurately.

Contact Block Mounting Position



Key removable/retained positions

- A: Removable/retained in all positions
- B: Removable in left theft only
- C: Removable in right only

Key Retained Position								
A (removable in all positions)	B (removable in left only)	C (removable in right only)						
0 2	0 0	0 ②						
	Cam code: blank							

Key Retained Position								
A (removable in all positions)	B (removable in left only)	C (removable in right only)						
2 0	2 0	2 ①						
	Cam code: J							

①②: Key removal position **●** ②: Key retained position

Note: The key cannot be removed in a spring return position.

Controllers

Operator Interfaces

Sensors

AUTO-ID

Flush Silhouette

ø30

ø16

Miniature

Pilot Lights

TW

Control Boxes Emergency Stop Switches Enabling Switches Safety Products **Explosion Proof** Terminal Blocks Relays & Sockets Circuit Protectors **Power Supplies** LED Illumination

Key Selector Switches (Pin Tumbler Key)

Package Quantity: 1

	No. of	Contact Configuration				rator Pos	ition	Cam	Maintained
Shape	Positions	Contact Code	Mounting Position	Contact	1	0	2	Code	1 0 2
Pin Tumbler Key		2NC	1	NC					HW1K-3PA02
HW1K		(02)	2	NC					
			1	NO	•				
		2NO-2NC	2	NO			•		HW1K-3PA22N1
		(22N1)	3	NC				_	HWTK-SPAZZIVI
			4	NC					
- 5		4NC (04)	1)	NC					HW1K-3PA04
	45° 3-position		2	NC				_	
			3	NC					
			4	NC					
1 Q			1	NO	•				
		2NO-1NC	2	NO			•	i .	
_		(21N1) ★☆	3	NC		•		J	HW1K-3JPA21N1
		* *	4	_	Du	ımmy Blo	ck		
			1)	NC			•		
		4NC	2	NC	•				LINEALY CODACA
(NC contact only)		(04)	3	NC			•	S	HW1K-3SPA04
(NC contact only)		*	4	NC	•				

- On the contact arrangement marked with \star in the table above, the rated current (load switching current) is reduced to a half of the related current of the contact block. The rated insulation voltage and the rated thermal current remain unchanged.
- For models with ☆, contacts may overlap when the operator is changed.
- For contact block mounting position, see the figure on the right.
- · Each key selector switch is supplied with two keys.
- 15 types of key numbers are available in addition to standard (500) key. See below for details.
- Spring-return type is also available. See below for details.
- Key retained position can be selected. See table below details.

Contact Block Mounting Position



Flush Silhouette

Controllers

Operator

Interfaces

Sensors

AUTO-ID

ø16

ø30

Miniature

Pilot Lights

TW

YW

Ordering Information

Example: HW1K - 3 \$ P A 04 - 501 Not specified: 500 (default key) 501-515: The key number is engraved on the key cylinder. Cam code: Blank, J, or S Operator position code:

- 3: 3-position, maintained 31: 3-position, spring return from right
- 32: 3-position, spring return from left
- 33: 3-position, spring return two way

Maintained (45° 3-position)	Sprir	ng Return (45° 3-pos	ition)
Maintained	Spring Return from Right	Spring Return from Left	Spring Return Two-way
1 0 2	1 0 2	1 0 2	1 0 2
Cam code: blank, J, or S		Cam code: blank	

- For more contact arrangement, see B-211 to B-212.
- · Key selector switches with one or three contact blocks contain a dummy block.
- See B-186 for gold-plated silver contacts.
- Turn the operator to each position accurately.

Key removal/retained positions A: Removable in all positions

- B: Removable in left and center C: Removable in right and center
- D: Removable in center only
- E: Removable in right and left G: Removable in left only
- H: Removable in right only

Note: The key cannot be removed in a spring return position.

Key Retained Position (45° 3-position)									
A (removable in all positions)	B (removable in left and center)	C (removable in right and center)	D (removable in center only)						
0 0 0	0 0 2	0 0 2	0 0 0						
E (removable in right and left only)	G (removable in left only)	H (removable in right only)							
0 2	0	0 0 2							

⊕⊕②: Key removal position

⊙ • • • Exert etained position

Note: The key cannot be removed in a spring return position.

Control Boxes

Stop Switches

Safety Products

Explosion Proof

Terminal Blocks

Relays & Sockets

Power Supplies

LED Illumination

Controllers

Operator

Interfaces

Sensors

AUTO-ID

Flush Silhouette

ø16

ø30

TW

YW

Circuit

Protectors

Emergency

Enabling

Switches

Key Selector Switches (Disc Tumbler Key)

Package Quantity: 1

Disc Tumbler Key HW1K No. of **Positions** (NC contact only) **Contact Configuration Operator Position** Maintained (90°) Spring Return from Right (60°) Cam Code Mounting **Contact Code** Contact 1 2 Position 1 NO 1N0 HW1K-2A10 HW1K-21B10 (10)**Dummy Block** 2 1 1NC NC HW1K-2A01 HW1K-21B01 (01)2 **Dummy Block** NO 1NO-1NC 1 HW1K-2A11 HW1K-21B11 (11)(2) NC • 1 NO 2N0 HW1K-2A20 HW1K-21B20 (20)2 N0 1 NC 2NC HW1K-2A02 HW1K-21B02 (02)2 NC • 90° 1 N0 2-position/ 2 NC 2NO-1NC 2-position HW1K-2A21 HW1K-21B21 (21)3 N0 **Dummy Block** 4 NC 1 2 NC 3NC HW1K-2A03 HW1K-21B03 (03)NC (3) 4 **Dummy Block** N0 1 2 NC 2NO-2NC HW1K-2A22 HW1K-21B22 (22)NO • 3 4 NC


- Each key selector switch is supplied with two keys.
- 3 types of key numbers are available in addition to standard key.
- Key retained position can be selected. See table below for key retained positions.

Contact Block Mounting Position

Miniature

Pilot Lights

Ordering Information




Operator position code: 2: 2-position, maintained

21: 2-position, spring return from right

Maintained (9	Maintained (90° 2-position)					
1 2	2 1	Spring Return from Right				
Cam code: blank	Cam code: J	Cam code: blank				

- For more contact arrangement, see B-211 to B-213.
- Key selector switches with one or three contact blocks contain a dummy block.
- See B-186 for gold-plated silver contacts.
- Turn the operator to each position accurately.



	Key Removal Position	
A (removable in all positions)	B (removable in left only)	C (removable in right only)
2 0	2 0	0 0
	Cam code: J	

①②: Key removal position

● ②: Key retained position

Note: The key cannot be removed in a spring return position.

Key Selector Switches (Disc Tumbler Key)

Package Quantity: 1

APEM

Control Boxes Emergency Stop Switches Enabling Switches

Safety Products **Explosion Proof** Terminal Blocks

Relays & Sockets Circuit Protectors

Power Supplies

LED Illumination

Controllers Operator

Interfaces Sensors

AUTO-ID

Flush Silhouette

ø16

ø30 Miniature

Pilot Lights

TW YW

No. of Positions		Disc Tumbler HW1K	Key							>		
	Contac		Operator Position			Maintained	Spring Return from Right	Spring Return from Left	Spring Return Two-way			
		Contact Code	Mounting Position	Contact	1	0	2	Cam Code	1 0 2	1 0 2	1 2	1 0 2
		2N0 (20)	① ②	NO NO	•		•	-	HW1K-3A20	HW1K-31B20	HW1K-32C20	HW1K-33D20
		2NC	0	NC		•		_	HW1K-3A02	HW1K-31B02	HW1K-32C02	HW1K-33D02
		(02)	2	NC					TIVITY OAGE	TIWTH OTBOZ	11W11C 02002	TIWTH CODOL
		0110 0110	0	NO NO	•			1				
		2NO-2NC (22N1)	2	NO NO				-	HW1K-3A22N1	HW1K-31B22N1	HW1K-32C22N1	HW1K-33D22N1
			<u>3</u>	NC NC	_	_						
ı			0	NO NO	-							
		4N0	©	NO NO			•	-		HW1K-31B40	HW1K-32C40	HW1K-33D40
ı		(40)	3	NO NO	•			 	HW1K-3A40			
	45°	(40)	4	NO			•	1				
ı	3-position		0	NC								
ı		4NC	2	NC				1	1111417 0404	LIMMIK OADOA	1111417 00004	LIMMIK OODOA
İ		(04)	3	NC				1 —	HW1K-3A04	HW1K-31B04	HW1K-32C04	HW1K-33D04
İ			4	NC				1				
		4NC	0	NC			•					
		(04)	2	NC	•			S	HW1K-3SA04			
		★	3	NC			•] 3	11W1K-33A04	_	_	_
			4	NC	•							
		2NO-1NC	0	NO	•			1				
		(21N1)	2	NO			•	J	HW1K-3JA21N1	_	_	_
		(=)	3	NC				"				

- On the contact arrangement marked with 🖈 in the table above, the rated current (load switching current) is reduced to a half of the related current of the contact block. The rated insulation voltage and the rated thermal current remain unchanged.
- For models with ★, contacts may overlap when the operator is changed. Each key selector switch is supplied with two keys.

Dummy Block

- 3 types of key numbers are available in addition to standard key.
- · Key retained position can be selected. See table below for key retained positions.

NC

Contact Block Mounting Position

Ordering Information

Example: HW1K - 3 \$ 4 04 - 1H Not specified: 231 (default key)
The key number is engraved on the key cylinder. 1H 2H ЗН Key removal/retained positions Cam code: Blank, J, or S A: Removable in all positions Operator position code: B: Removable in left and center 3: 3-position, maintained

> 31: 3-position, spring return from right 32: 3-position, spring return from left

33: 3-position, spring return two way

Maintained Spring Return (45° 3-position) (45° 3-position) Spring Return Spring Return Maintained Spring Return from Right from Left Two-way Cam code: Cam code: blank blank, J, or S

- For more contact arrangement, see B-211 to B-213.
- · Key selector switches with one or three contact blocks contain a dummy block.
- See B-186 for gold-plated silver contacts.
- Turn the operator to each position accurately.

E: Removable in right and left

G: Removable in left only

C: Removable in right and center H: Removable in right only

D: Removable in center only

Note: The key cannot be removed in a spring return position.

A (removable in all positions)	B (removable in left and center)	C (removable in right and center)	D (removable in center only)
0 0 2	0 0 2	0 0 2	0 0 0
E (removable in right and left only)	G (removable in left only)	H (removable in right only)	
0 0	0 0	0 ②	

①①②: Key removal position

● ●: Key retained position

Note: The key cannot be removed in a spring return position.

Control Boxes Emergency Stop Switches Enabling Switches Safety Products **Explosion Proof** Terminal Blocks Relays & Sockets Circuit Protectors Power Supplies LED Illumination Controllers Operator Interfaces Sensors AUTO-ID

Flush Silhouette

ø16

ø30 Miniature Pilot Lights

TW

YW

LED

Selector Switches (Knob Operator)

Package Quantity: 1

No. of Positions	Knob Ope HW1F	rator										
	Contac	tact Configuration			Operator Position		Operating	Maintained (90°)	Spring return from right (60°)			Color
	Contact Code	Mounting Position	Contact	1	2		Voltage	1 2	1 2	_		Code
	4110 4110	①	NO		•		24V AC/DC	HW1F-211Q4*	HW1F-2111Q4*			1
90°	1NO-1NC (11)	2	NC	•			100/110V AC	HW1F-211H2*	HW1F-2111H2*			
2-position/	(11)						200/220V AC	HW1F-211M2*	HW1F-2111M2*			_
60°		0	NO		•		24V AC/DC	HW1F-220Q4*	HW1F-2120Q4*			R
2-position	2N0 (20)	2	NO		•		100/110V AC	HW1F-220H2*	HW1F-2120H2*			Ϋ́
	(20)						200/220V AC	HW1F-220M2*	HW1F-2120M2*			Α
		0	NO		•		24V AC/DC	HW1F-222Q4*	HW1F-2122Q4*			S
	2NO-2NC	2	NC	•			100/110V AC	HW1F-222H2*	HW1F-2122H2*			PW
	(22)	3	NO		•		200/220V AC	HW1F-222M2*	HW1F-2122M2*			
		4	NC	•								
	Contact Configuration			Operator Position			Maintained	Spring return	Spring return	Spring Return		
		, c 00, gu	auon	P	ositi	on	Operating		from right	from left	Two-way	Color
	Contact Code	Mounting Position	Contact	1 1	ositi 0	on 2	Operating Voltage	1 0 2	from right	from left	Two-way	Color Code
	Contact Code	Mounting						1 0 2 HW1F-320Q4*	from right 1 0 2 HW1F-3120Q4*	from left 1 0 2 HW1F-3220Q4*	Two-way 1 0 2 HW1F-3320Q4*	
	Contact Code	Mounting Position	Contact	1			Voltage	HW1F-320Q4* HW1F-320H2*	1 0 2	1 0 2	1 2	
	Contact Code	Mounting Position	Contact	1		2	Voltage 24V AC/DC		1 0 2 HW1F-3120Q4*	HW1F-3220Q4*	HW1F-3320Q4*	
	Contact Code 2NO (20)	Mounting Position	Contact	1		2	Voltage 24V AC/DC 100/110V AC	HW1F-320H2*	HW1F-3120Q4* HW1F-3120H2*	HW1F-3220Q4* HW1F-3220H2*	HW1F-3320Q4* HW1F-3320H2*	
	Contact Code 2NO (20)	Mounting Position ① ②	Contact NO NO	1		2	Voltage 24V AC/DC 100/110V AC 200/220V AC	HW1F-320H2* HW1F-320M2*	HW1F-3120Q4* HW1F-3120H2* HW1F-3120M2*	HW1F-3220Q4* HW1F-3220H2* HW1F-3220M2*	HW1F-3320Q4* HW1F-3320H2* HW1F-3320M2*	
	Contact Code 2NO (20)	Mounting Position ① ② ①	NO NO	1		2	Voltage 24V AC/DC 100/110V AC 200/220V AC 24V AC/DC	HW1F-320H2* HW1F-320M2* HW1F-302Q4*	HW1F-3120Q4* HW1F-3120H2* HW1F-3120M2* HW1F-3102Q4*	HW1F-3220U4* HW1F-3220H2* HW1F-3220M2* HW1F-3202Q4*	HW1F-3320Q4* HW1F-3320H2* HW1F-3320M2* HW1F-3302Q4*	
45°	Contact Code 2NO (20)	Mounting Position ① ② ①	NO NO	1		2	Voltage 24V AC/DC 100/110V AC 200/220V AC 24V AC/DC 100/110V AC	HW1F-320H2* HW1F-320M2* HW1F-302Q4* HW1F-302H2*	HW1F-3120Q4* HW1F-3120H2* HW1F-3120M2* HW1F-3102Q4* HW1F-3102H2*	HW1F-3220Q4* HW1F-3220H2* HW1F-3220M2* HW1F-3202Q4* HW1F-3202H2*	HW1F-3320Q4* HW1F-3320H2* HW1F-330M2* HW1F-3302Q4* HW1F-3302H2*	Code
45° 3-position	Contact Code 2NO (20)	Mounting Position ① ② ① ② ②	NO NO NC NC	1		2	24V AC/DC 100/110V AC 200/220V AC 24V AC/DC 100/110V AC 200/220V AC	HW1F-320H2* HW1F-320M2* HW1F-302Q4* HW1F-302H2* HW1F-302M2*	HW1F-3120Q4* HW1F-3120H2* HW1F-3102Q4* HW1F-3102H2* HW1F-3102H2*	HW1F-3220Q4* HW1F-3220H2* HW1F-3220M2* HW1F-3202Q4* HW1F-3202H2* HW1F-3202M2*	HW1F-3320Q4* HW1F-3320H2* HW1F-3302Q4* HW1F-3302Q4* HW1F-3302H2* HW1F-3302M2*	Code
	Contact Code 2NO (20) 2NC (02)	Mounting Position ① ② ① ② ① ② ① ②	NO NO NC NC NO	1		2	Voltage 24V AC/DC 100/110V AC 200/220V AC 24V AC/DC 100/110V AC 200/220V AC 24V AC/DC	HW1F-320H2* HW1F-320M2* HW1F-302Q4* HW1F-302H2* HW1F-302M2* HW1F-322N1Q4*	HW1F-3120Q4* HW1F-3120H2* HW1F-3120M2* HW1F-3102Q4* HW1F-3102H2* HW1F-3102M2* HW1F-3122N1Q4*	HW1F-3220Q4* HW1F-3220H2* HW1F-3220M2* HW1F-3202U4* HW1F-3202H2* HW1F-3202M2* HW1F-3222N1Q4*	HW1F-3320Q4* HW1F-3320H2* HW1F-3302Q4* HW1F-3302H2* HW1F-3302H2* HW1F-3302M2* HW1F-3322N1Q4*	Code
	Contact Code 2NO (20) 2NC (02) 2NO-2NC	Mounting Position ① ② ① ② ① ② ② ② ②	NO NO NO NO NO	1		2	Voltage 24V AC/DC 100/110V AC 200/220V AC 24V AC/DC 100/110V AC 200/220V AC 24V AC/DC 100/110V AC	HW1F-320H2* HW1F-320M2* HW1F-302Q4* HW1F-302H2* HW1F-302M2* HW1F-322N1Q4* HW1F-322N1H2*	HW1F-3120Q4* HW1F-3120H2* HW1F-3120M2* HW1F-3102Q4* HW1F-3102M2* HW1F-3102M2* HW1F-3122N1Q4* HW1F-3122N1Q4*	HW1F-3220Q4* HW1F-3220H2* HW1F-3220M2* HW1F-3202Q4* HW1F-3202H2* HW1F-3202M2* HW1F-3222N1Q4* HW1F-3222N1Q4*	HW1F-3320Q4* HW1F-3320H2* HW1F-3302Q4* HW1F-3302H2* HW1F-3302M2* HW1F-3322N1Q4* HW1F-3322N1Q4*	Code R G Y A
	Contact Code 2NO (20) 2NC (02) 2NO-2NC	Mounting Position ① ② ① ② ① ② ② ③ ③	NO NC NO NO NO NC	1		2	Voltage 24V AC/DC 100/110V AC 200/220V AC 24V AC/DC 100/110V AC 200/220V AC 24V AC/DC 100/110V AC	HW1F-320H2* HW1F-320M2* HW1F-302Q4* HW1F-302H2* HW1F-302M2* HW1F-322N1Q4* HW1F-322N1H2*	HW1F-3120Q4* HW1F-3120H2* HW1F-3120M2* HW1F-3102Q4* HW1F-3102M2* HW1F-3102M2* HW1F-3122N1Q4* HW1F-3122N1Q4*	HW1F-3220Q4* HW1F-3220H2* HW1F-3220M2* HW1F-3202Q4* HW1F-3202H2* HW1F-3202M2* HW1F-3222N1Q4* HW1F-3222N1Q4*	HW1F-3320Q4* HW1F-3320H2* HW1F-3302Q4* HW1F-3302H2* HW1F-3302M2* HW1F-3322N1Q4* HW1F-3322N1Q4*	Code R G Y A S
	Contact Code 2NO (20) 2NC (02) 2NO-2NC	Mounting Position ① ② ① ② ② ② ③ ③ ③ ④	NO NO NO NO NC NC NC	1		2	Voltage 24V AC/DC 100/110V AC 200/220V AC 24V AC/DC 100/110V AC 200/220V AC 24V AC/DC 100/110V AC 200/220V AC	HW1F-320H2* HW1F-320M2* HW1F-302Q4* HW1F-302H2* HW1F-302M2* HW1F-322N1Q4* HW1F-322N1H2* HW1F-322N1M2*	HW1F-3120Q4* HW1F-3120H2* HW1F-3120M2* HW1F-3102Q4* HW1F-3102M2* HW1F-3102M2* HW1F-3122N1Q4* HW1F-3122N1H2* HW1F-3122N1H2*	HW1F-3220Q4* HW1F-3220H2* HW1F-3220M2* HW1F-3202U4* HW1F-3202H2* HW1F-3222N1Q4* HW1F-3222N1H2* HW1F-3222N1M2*	HW1F-3320Q4* HW1F-3320H2* HW1F-3320M2* HW1F-3302U4* HW1F-3302H2* HW1F-3322N1Q4* HW1F-3322N1H2* HW1F-3322N1M2*	Code R G Y A
	Contact Code 2NO (20) 2NC (02) 2NO-2NC (22N1)	Mounting Position ① ② ① ② ② ③ ③ ④ ① ①	NO NO NO NO NO NO NO NO NO NO NO NO NO N	1		2	24V AC/DC 100/110V AC 200/220V AC 24V AC/DC 100/110V AC 200/220V AC 24V AC/DC 100/110V AC 200/220V AC 200/220V AC	HW1F-320H2* HW1F-320M2* HW1F-302Q4* HW1F-302H2* HW1F-302M2* HW1F-322N1Q4* HW1F-322N1H2* HW1F-340Q4*	HW1F-3120Q4* HW1F-3120H2* HW1F-3120M2* HW1F-3102Q4* HW1F-3102M2* HW1F-3122N1Q4* HW1F-3122N1H2* HW1F-3122N1M2* HW1F-3140Q4*	HW1F-3220Q4* HW1F-3220H2* HW1F-322Q4* HW1F-3202H2* HW1F-3202H2* HW1F-3222N1Q4* HW1F-3222N1H2* HW1F-3222N1M2* HW1F-3240Q4*	HW1F-3320Q4* HW1F-3320H2* HW1F-3320M2* HW1F-3302U4* HW1F-3302H2* HW1F-3302M2* HW1F-3322N1Q4* HW1F-3322N1H2* HW1F-3340Q4*	Code R G Y A S
	Contact Code 2NO (20) 2NC (02) 2NO-2NC (22N1)	Mounting Position ① ② ② ② ③ ③ ④ ① ② ②	NO NC NC NC NC NC NC NC NC NC NC NO NO NO	1		2	24V AC/DC 100/110V AC 200/220V AC 24V AC/DC 100/110V AC 200/220V AC 24V AC/DC 100/110V AC 200/220V AC 24V AC/DC 100/110V AC	HW1F-320H2* HW1F-320M2* HW1F-302Q4* HW1F-302H2* HW1F-302M2* HW1F-322N1Q4* HW1F-322N1H2* HW1F-340Q4* HW1F-340H2*	HW1F-3120Q4* HW1F-3120H2* HW1F-3120M2* HW1F-3102Q4* HW1F-3102M2* HW1F-3122N1Q4* HW1F-3122N1H2* HW1F-3122N1M2* HW1F-3140Q4* HW1F-3140Q4*	HW1F-3220Q4* HW1F-3220H2* HW1F-322Q4* HW1F-3202H2* HW1F-3202M2* HW1F-3222N1Q4* HW1F-3222N1H2* HW1F-3222N1M2* HW1F-3240Q4* HW1F-3240Q4*	HW1F-3320Q4* HW1F-3320H2* HW1F-3302Q4* HW1F-3302H2* HW1F-3302M2* HW1F-3322N1Q4* HW1F-3322N1H2* HW1F-3340Q4* HW1F-3340Q4*	Code R G Y A S
	Contact Code 2NO (20) 2NC (02) 2NO-2NC (22N1)	Mounting Position ① ② ① ② ② ③ ③ ④ ① ② ③ ③ ④ ① ② ③ ③ ③ ③ ③ ③ ③ ③ ③ ③ ③ ③ ③ ③ ③ ③ ③ ③	NO NC NC NC NC NC NC NC NC NO NO NO NO NO NO	1		2	24V AC/DC 100/110V AC 200/220V AC 24V AC/DC 100/110V AC 200/220V AC 24V AC/DC 100/110V AC 200/220V AC 24V AC/DC 100/110V AC	HW1F-320H2* HW1F-320M2* HW1F-302Q4* HW1F-302H2* HW1F-302M2* HW1F-322N1Q4* HW1F-322N1H2* HW1F-340Q4* HW1F-340H2*	HW1F-3120Q4* HW1F-3120H2* HW1F-3120M2* HW1F-3102Q4* HW1F-3102M2* HW1F-3122N1Q4* HW1F-3122N1H2* HW1F-3122N1M2* HW1F-3140Q4* HW1F-3140Q4*	HW1F-3220Q4* HW1F-3220H2* HW1F-322Q4* HW1F-3202H2* HW1F-3202M2* HW1F-3222N1Q4* HW1F-3222N1H2* HW1F-3222N1M2* HW1F-3240Q4* HW1F-3240Q4*	HW1F-3320Q4* HW1F-3320H2* HW1F-3302Q4* HW1F-3302H2* HW1F-3302M2* HW1F-3322N1Q4* HW1F-3322N1H2* HW1F-3340Q4* HW1F-3340Q4*	Code R G Y A S
	Contact Code 2NO (20) 2NC (02) 2NO-2NC (22N1)	Mounting Position ① ② ① ② ② ③ ③ ④ ① ② ③ ④ ③ ④ ④ ④ ④ ④ ④ ④ ④ ④ ④ ④ ④	NO NO NO NO NO NO NO NO NO NO NO NO NO N	1		2	Voltage 24V AC/DC 100/110V AC 200/220V AC 24V AC/DC 100/110V AC 200/220V AC 24V AC/DC 100/110V AC 200/220V AC 24V AC/DC 100/110V AC 24V AC/DC 100/110V AC 200/220V AC	HW1F-320H2* HW1F-320M2* HW1F-302Q4* HW1F-302H2* HW1F-302M2* HW1F-322N1Q4* HW1F-322N1H2* HW1F-340M2* HW1F-340M2*	HW1F-3120Q4* HW1F-3120H2* HW1F-3120M2* HW1F-3102Q4* HW1F-3102M2* HW1F-3122N1Q4* HW1F-3122N1H2* HW1F-3122N1H2* HW1F-3140M2*	HW1F-3220Q4* HW1F-3220H2* HW1F-3220M2* HW1F-3202U2* HW1F-3202H2* HW1F-3202M2* HW1F-3222N1Q4* HW1F-3222N1H2* HW1F-3240Q4* HW1F-3240W2*	HW1F-3320Q4* HW1F-3320H2* HW1F-3320M2* HW1F-3302Q4* HW1F-3302H2* HW1F-3322N1Q4* HW1F-3322N1H2* HW1F-3322N1M2* HW1F-3340Q4* HW1F-3340M2*	Code R G Y A S
	Contact Code 2NO (20) 2NC (02) 2NO-2NC (22N1) 4NO (40)	Mounting Position ① ② ① ② ② ③ ③ ④ ① ② ③ ④ ① ② ③ ④ ① ② ③ ④ ① ② ③ ④ ① ② ③ ④ ① ② ③ ④ ① ② ③ ④ ① ② ③ ④ ④ ① ②	NO NO NO NO NO NO NO NO NC	1		2	24V AC/DC 100/110V AC 200/220V AC 24V AC/DC 100/110V AC 200/220V AC 24V AC/DC 100/110V AC 200/220V AC 24V AC/DC 100/110V AC 200/220V AC	HW1F-320H2* HW1F-320M2* HW1F-302Q4* HW1F-302H2* HW1F-302M2* HW1F-322N1Q4* HW1F-322N1H2* HW1F-340Q4* HW1F-340H2* HW1F-340M2* HW1F-304Q4*	HW1F-3120Q4* HW1F-3120H2* HW1F-3120M2* HW1F-3102Q4* HW1F-3102M2* HW1F-3102M2* HW1F-3122N1Q4* HW1F-3122N1H2* HW1F-3140M2* HW1F-3140M2* HW1F-3140M2* HW1F-3104Q4*	HW1F-3220Q4* HW1F-3220H2* HW1F-3202Q4* HW1F-3202H2* HW1F-3202H2* HW1F-3202M2* HW1F-3222N1Q4* HW1F-3222N1H2* HW1F-3240H2* HW1F-3240H2* HW1F-3240H2* HW1F-3240H2* HW1F-3204Q4*	HW1F-3320Q4* HW1F-3320H2* HW1F-3302Q4* HW1F-3302H2* HW1F-3302H2* HW1F-3302M2* HW1F-3322N1Q4* HW1F-3322N1H2* HW1F-3340H2* HW1F-3340H2* HW1F-3340H2* HW1F-3340H2* HW1F-3304Q4*	Code R G Y A S

- Specify a color code in place of * in the Part No. R (red), G (green), Y (yellow), A (amber), S (blue), PW (pure white)
- See B-186 for other operating voltage such as 6V AC/DC and 12V AC/DC.
- ullet Illuminated selector switches of 24V AC/DC or below with 2 or 4 contact blocks have a dummy block.
- See B-211 to B-213 for other contact arrangements.
- See B-186 for gold-plated silver contacts.
- Turn the operator to each position accurately.

Contact Block Mounting Position





LED

No. of **Positions** Lever Operator HW1F⊡L

Selector Switches (Lever Operator)

Package Quantity: 1

APEM

Control Boxes Emergency Stop Switches Enabling Switches

Explosion Proof Terminal Blocks

Safety Products

Relays & Sockets Circuit

Protectors **Power Supplies**

LED Illumination

Controllers Operator Interfaces

Sensors AUTO-ID

Flush Silhouette

ø16

ø30

Miniature

Pilot Lights

TW

									•				
		Contact	Contact Bloc		Operator Position			Operating	Maintained (90°)	Spring Return from Right (60°)			Color
		Code	Mounting Position	Contact	1	2		Voltage	1 2	1 2	_	_	Code
		4110 4110	①	NO		•		24V AC/DC	HW1F-2L11Q4*	HW1F-21L11Q4*			
١	00°	1NO-1NC (11)	2	NC	•			100/110V AC	HW1F-2L11H2*	HW1F-21L11H2*			
2	2-position/	(11)						200/220V AC	HW1F-2L11M2*	HW1F-21L11M2*			R
_	60°	ONIO	①	NO		•		24V AC/DC	HW1F-2L20Q4*	HW1F-21L20Q4*			G
2	2-position	2N0 (20)	2	NO		•		100/110V AC	HW1F-2L20H2*	HW1F-21L20H2*			Ϋ́
		(20)						200/220V AC	HW1F-2L20M2*	HW1F-21L20M2*			A
			①	NO		•		24V AC/DC	HW1F-2L22Q4*	HW1F-21L22Q4*			S PW
		2NO-2NC	2	NC	•			100/110V AC	HW1F-2L22H2*	HW1F-21L22H2*			1 44
		(22)	3	NO		•		200/220V AC	HW1F-2L22M2*	HW1F-21L22M2*			
			4	NC	•								
		Contact	Cont Blo			perat ositio		Operating	Maintained	Spring Return from Right	Spring Return from Left	Spring Return Two-way	Color
		Code	Mounting Position	Contact	1	0	2	Voltage	1 0 2	1 0 2	2	1 2	Code
		ONO	①	NO	•			24V AC/DC	HW1F-3L20Q4*	HW1F-31L20Q4*	HW1F-32L20Q4*	HW1F-33L20Q4*	
		2NO (20)	2	NO			•	100/110V AC	HW1F-3L20H2*	HW1F-31L20H2*	HW1F-32L20H2*	HW1F-33L20H2*	
		(20)						200/220V AC	HW1F-3L20M2*	HW1F-31L20M2*	HW1F-32L20M2*	HW1F-33L20M2*	
		2NC	①	NC				24V AC/DC	HW1F-3L02Q4*	HW1F-31L02Q4*	HW1F-32L02Q4*	HW1F-33L02Q4*	
		(02)	2	NC				100/110V AC	HW1F-3L02H2*	HW1F-31L02H2*	HW1F-32L02H2*	HW1F-33L02H2*	
		(02)						200/220V AC	HW1F-3L02M2*	HW1F-31L02M2*	HW1F-32L02M2*	HW1F-33L02M2*	
	5°		①	NO	•			24V AC/DC	HW1F-3L22N1Q4*	HW1F-31L22N1Q4*	HW1F-32L22N1Q4*	HW1F-33L22N1Q4*	R
l	3-position	2NO-2NC	2	NO			•	100/110V AC	HW1F-3L22N1H2*	HW1F-31L22N1H2*	HW1F-32L22N1H2*	HW1F-33L22N1H2*	G

HW1F-3L40Q4*

HW1F-3L40H2*

HW1F-3L40M2*

HW1F-3L04Q4*

HW1F-3L04H2*

HW1F-3L04M2*

• Specify a color code in place of * in the Part No. R (red), G (green), Y (yellow), A (amber), S (blue), PW (pure white)

200/220V AC

24V AC/DC

100/110V AC

200/220V AC

24V AC/DC

100/110V AC

200/220V AC

- See B-186 for other operating voltage such as 6V AC/DC, 12V AC/DC, and 110V DC.
- Illuminated selector switches of 24V AC/DC or below with 2 or 4 contact blocks have a dummy block.
- See B-211 to B-213 for other contact arrangements.
- See B-186 for gold-plated silver contacts.

(22N1)

4N0

(40)

4NC (04)

3

4

1

2

3

4

1

2

3

NC

NC

NO

NO

NO

NO

NC

NC


NC

NC

• Turn the operator to each position accurately.

Contact Block Mounting Position





HW1F-3L22N1M2* HW1F-31L22N1M2* HW1F-32L22N1M2* HW1F-33L22N1M2*

HW1F-32L40Q4*

HW1F-32L40H2*

HW1F-32L40M2*

HW1F-32L04Q4*

HW1F-32L04H2*

HW1F-32L04M2*

HW1F-31L40Q4*

HW1F-31L40H2*

HW1F-31L40M2*

HW1F-31L04Q4*

HW1F-31L04H2*

HW1F-31L04M2*

Illuminated (transformer)

Α

PW

HW1F-33L40Q4*

HW1F-33L40H2*

HW1F-33L40M2*

HW1F-33L04Q4*

HW1F-33L04H2*

HW1F-33L04M2*

Control Boxes

Emergency Stop Switches

Relays & Sockets
Circuit

Power Supplies

LED Illumination

Controllers

Operator
Interfaces

Sensors

AUTO-ID

Flush Silhouette

ø16

ø30 Miniature Pilot Lights

YW


Protectors

Enabling Switches Safety Products Explosion Proof Terminal Blocks

Dimensions All dimensions in mm.

Selector Switch (Knob Operator)


Terminal Screws M3.5 Integrated Terminal Cover




Key Selector Switch (Knob Operator)

Terminal Screws M3.5 Integrated Terminal Cover

Disc Tumbler Type





Pin Tumbler Type

Illuminated Selector Switch (Knob Operator) Terminal Scre


Terminal Screws M3.5 Integrated Terminal Cover

6, 12, 24V AC/DC, Without LED lamp

100/110V AC, 200/220V AC (240V AC maximum)

110V DC, 380V AC minimum


110V DC, 380V AC minimum




Illuminated Selector Switch (Lever Operator)


Terminal Screws M3.5 Integrated Terminal Cover

 $6,\,12,\,24V\,AC/DC,\,Without\,\,LED\,\,lamp$




100/110V AC, 200/220V AC (240V AC maximum)






Bottom View

Non-illuminated










1 contact block


3 contact blocks

2/4 contact blocks


Illuminated

6, 12, 24V AC/DC, Without LED lamp






3 contact blocks




2/4 contact blocks

100/110V AC, 200/220V AC (240V AC maximum)



110V DC, 380V AC minimum



 \bullet For DC-DC Converter types, terminal X1 is \oplus , X2 is \ominus .

IDEC

Circuit
Protectors

Power Supplies

LED Illumination

Controllers

Operator

Sensors AUTO-ID

Flush Silhouette

ø16

ø30 Miniature Pilot Lights

TW

Control Boxes

Emergency
Stop Switches
Enabling
Switches

Safety Products

Explosion Proof

Terminal Blocks

Selector Switch Contact Arrangement

90° 2-position (Spring Return 60° 2-position) < Maintained/Spring Return from Right>

		(-10-11-19		_		,				
			Operator Operation and Circuit Availability							
					Mainta	ined	Spring	Spring Return from Right		
П					1	2	1 >2			
		Contact Block								
u	0			I/ l- /			Knob/			
٠	Contact Code			Knob/ Lever	Key	Illuminated	Lever Key Illumina		Illuminated	d Cam
	code		Level			LEVEI			Code	
П		Mounting Position	Contact		Opera		Operator			
╹					Posit		Position			
				1		2	1		2	
٠)	\mathscr{D})	Ø	
.	1NO	1	NO			•			•	
ı	(10)	2	_	Dummy Block			Dummy Block			1 —
- [1NC	1	NC	•			•			
ı	(01)	2	_	D	ummy	Block	D	ummy	Block	1 —
۱ ٔ	1NO-1NC	1	NO		T	•		T	•	
.	(11)	2	NC	•			•			1 —
ĺ	2N0	1	NO			•			•	
-	(20)	2	NO			•			•	1 —
ſ	2NC	1	NC	•			•			
۱ -	(02)	2	NC	•			•			_
ſ		1	NO			•			•	
٠	2NO-2NC	2	NC	•			•			
.	(22)	3	NO			•			•	
		4	NC	•			•			
- [1	NC	•			•			
	3NO-1NC	2	NO			•			•	
٠	(31N1)	3	NO			•			•] —
.		4	NO			•			•	
		1	NO			•			•	ļ
-	4NO	2	NO			•			•	
	(40)	3	NO			•			•	
•		4	NO			•			•	
	1NO-1NC ★	1	EM		_					!
	(7S)	2	LB							
		1	NC	•			•			
.	3NC	2	NC	•			•			_
	(03)	3	NC	•			•			
ļ		4			ummy			ummy		
		1	NO			•			•	
	2NO-1NC	2	NC	•			•			l
	(21)	3	NO			•			•	
		4	<u> </u>		ummy	Block	Dummy Block			

90° 2-position Cam Reversed (Maintained)

			Operator Operation a	and Circuit Availability			
	Contact Block		Maintained				
Contact			2 1				
Code			Knob/Key/	Cam Code			
			Operator Position				
	Mounting Position	Contact	2	1			
2NC	1	NC		•] _		
(02)	2	NC		•	٦		
	1	NC		•			
3NC	2	NC		•	١.		
(03)	3	NC		•	ا ا		
	4	_	Dumm	y Block			

[•] On the contact arrangement marked with \star in the table above, the rated current (load switching current) is reduced to a half of the related current of the contact block. The rated insulation voltage and the rated thermal current remain unchanged.

45° 3-position

<Maintained>

	Contact Block		Operator Position			Cir			
Contact Code	Mounting Position	Contact	1	0	2	Knob/ Lever	Key	Illuminated	Cam Code
1NO-1NC ★	1	NC		•		×	×	×	
(11N1) ☆	2	NO			•	_ ^	^	^	J
*	1	NC			•				
4NC	2	NC	•			×	×	×	S
(04)	3	NC			•				
	4	NC	•						
2NO-1NC ☆	1	NO	•			×	×	×	J
2NO-1NC ☆ (21N1)	2	NO			•				
(21111)	3	NC		•					
	4	_	Dummy Blo		ock				

45° 3-position

<Maintained/Spring Return from Right/Spring Return from Left/Spring Return Two-way>

	Contact Block		Operator Position			Circuit Availability			
Contact Code	Mounting Position	Contact	1	0	2	Knob/ Lever	Key	Illuminated	Cam Code
1NO-1NC	1	NO	•			×	×	×	
(11)	2	NC				_^_		^	
1NO-1NC	1	NC				×	×	×	_
(11N1)	2	NO			•				
2N0	1	NO	•			×	×	×	_
(20)	2	NO			•				
2NC	1	NC				×	×	×	_
(02)	2	NC							
	①	NO NO	•			×	×	×	_
2NO-2NC	2	NO NO			•				
(22N1)	3	NC							
	4	NC							
	1	NC				×	×	×	_
2NO-2NC	2	NO NO			_				
(22N2)	3	NC NO							
	4		•		•				
440	1	NO NO	•			×	×	×	
4NO	3	NO NO			•				_
(40)	4	NO NO							
	1	NC	\vdash			-			
4NC	2	NC NC				×	×	×	
(04)	3	NC		_					
(04)	4	NC							

• On the contact arrangement marked with ★ in the table above, the rated current (load switching current) is reduced to a half of the related current of the contact block. The rated insulation voltage and the rated thermal current remain unchanged.

 \bullet For models with \diamondsuit , contacts may overlap when the operator is changed.

APEM

Switches & Pilot Lights

Control Boxes

Emergency Stop Switches Enabling Switches

Safety Products

Explosion Proof

Terminal Blocks

Relays & Sockets

Circuit Protectors

Power Supplies

LED Illumination

Controllers Operator

Interfaces

Sensors

AUTO-ID

Flush Silhouette

ø16

122

ø30

Miniature

Pilot Lights

IW

TW

Control Boxes

Emergency
Stop Switches

Enabling
Switches

Safety Products

Explosion Proof

Terminal Blocks

Relays & Sockets
Circuit
Protectors

Power Supplies

LED Illumination

Controllers

Operator
Interfaces

Sensors

AUTO-ID

ø30

Miniature

Pilot Lights

45° 4-position, except for Key Selector, Illuminated Selector

				Operator	Position		Maintained	
Contact Code	Contac	Contact Block		2	3	4	1 3	Cam Code
	Mounting Position	Contact			Ø		Knob Operator	
★☆	1	NO	•					
1NO-2NC ☆	2	NC		•			×	_
(12)	3	NC			•		^	_
, ,	4	_		Dumm				
*	1	LB				1		
1NO-3NC ☆	2	NC		•			×	
(13N6)	3	NC			•		^	_
	4	NO				•		
*	1	NO	•					
2NO-2NC ☆	2	NC		•			×	
(22N3)	3	NC			•		^	_
. ,	4	NO				•		

30° 5-position, except for Key Selector, Illuminated Selector

				Ор		Maintained			
Contact Code	Contact Block		1 2 3		4	5	2 3 4 5	Cam Code	
	Mounting Position	Contact				(2)	9	Knob Operator	
*	1	NO	•						
2NO-2NC [☆]	2	NC		•				×	
(22N3)	3	NC				•		_ ^	
, ,	4	NO					•		

- On the contact arrangement marked with \star in the table above, the rated current (load switching current) is reduced to a half of the related current of the contact block. The rated insulation voltage and the rated thermal current remain unchanged.

22: 2-position/spring return from left

Flush Silhouette Part No. Development

ø16 Example 1: Knob Operator 2-position

HW1S - 2 T 11

Contact code


"T" for knob operator

No. of position/Operator Position


2: 2-position/maintained

21: 2-position/spring return from right

Example 3: Illuminated Selector 3-position



Example 2: Key Selector 3-position



No. of position/Operator Position

3: 3-position/maintained

31: 3-position/spring return from right 32: 3-position/spring return from left

33: 3-position/spring return two-way

33: 3-position/spring return two-way

Full Voltage Adapter

Contact Block Mounting Position

Illuminated Selector (Full Voltage)



Illuminated Selector (Transformer)



Non-illuminated Selector



(1)


Pushbutton Selectors

Package Quantity: 1

Shape	Circuit	Contact Code	Contac	t Block	(((Ring Operator	Button
	Category	Code	Mounting Position	Contact	Normal	Depressed	Normal	Depressed	Part No.	Color Code
HW1R		1NO-1NC	1	NO		•		•	HW1R-2A11*	
		(11)	2	NC	•				IIWIII ZATT	
		2N0	1	NO		•		•	HW1R-2A20*	
	Α —	(20)	2	NO		•				
		2NO-2NC	1	NO		•		•		
			2	NC	•			_	HW1R-2A22*	 - -
		(22)	3	NO	_	•		•		
			4	NC	•					
		2NO	1	NO		•			HW1R-2D20*	
		(20)	2	NO NO				•		_
	D		1	NO NO		•			_	
		2NO-2NC (22N1)	2	NO NO				•	HW1R-2D22N1*	B G R Y S
		★	3 4	NC						
			1	NC NO			•			
	E		2	NO NO				•	- HW1R-2E22N1*	
W Comments			3	NC						
			4	NC						
		*	1	NO				•		-
		★ 2NO-2NC	2	NO		•				
	F	(22N1)	3	NC			•		HW1R-2F22N1*	
		, ,	4	NC	•					
		★	1	NC			•			1
		2N0-2NC ☆	2	NO		•		•	LINKED ON COME	
	N	(22N2)	3	NC			•		HW1R-2N22N2*	
			4	NO		•		•		
			1	NO		•	•			1
	_	T 2NO-2NC (22N1)	2	NO		•	•	Blooked	LIMAD OTOONA	
	'		3	NC	•			ыоскей	ocked HW1R-2T22N1*	
			4	NC	•			1		

- Specify a button color code in place of * in the Part No. B (black), G (green), R (red), Y (yellow), S (blue), W (white)
- When operating the pushbutton selector, do not turn the operator ring or the lock lever while the button is depressed. Otherwise the pushbutton selector may be damaged.
- On the contact arrangement marked page with \bigstar in the table above, the rated current (load switching current) is reduced to a half of the related current of the contact block. The rated insulation voltage and the rated thermal current remain unchanged.
- ullet For models with $\noinde{\text{$\sigma$}}$, contacts may overlap when the operator is changed.

All dimensions in mm.



• See B-210 for the bottom view.

Dimensions

Contact Block Mounting Position



		Le	ft	Rig	ht	← Ring Position
Mounting Position	Contact	Normal	Push	Normal	Push	← Button
1	NO				•	
2	NO		•			
3	NC			•		
4	NC	•				

APEM

Switches &

Control Boxes

Emergency Stop Switches Enabling Switches

Safety Products

Explosion Proof

Terminal Blocks

Relays & Sockets

Circuit Protectors Power Supplies

LED Illumination

Controllers
Operator

Interfaces
Sensors

AUTO-ID

Flush Silhouette

ø16

ø30

Miniature

Pilot Lights

LIM

TW YW

Circuit

Protectors
Power Supplies

LED Illumination

Controllers

Operator

Interfaces

Sensors

AUTO-ID

Flush Silhouette

ø16

ø30

TW

YW

Miniature Pilot Lights

Control Boxes

Emergency
Stop Switches

Enabling
Switches

Safety Products

Explosion Proof

Terminal Blocks

Relays & Sockets

Mono-Lever Switches

Package Quantity: 1

	Shape	Positions	Part No. (Ordering No.)
	HW1M		HW1M-1010-20
	Standard Lever		HW1M-2020-20
		2-position	HW1M-0101-20
		2-position	HW1M-0202-20
			HW1M-0101-40
			HW1M-0202-40
		4-position	HW1M-1111-22N9
		4-position	HW1M-2222-22N9
Ì	HW1M-L		HW1M-L1010-20
٠	Interlocking Lever	O maritima	HW1M-L2020-20
			HW1M-L0101-20
		2-position	HW1M-L0202-20
۱			HW1M-L0101-40
			HW1M-L0202-40
		4 manihina	HW1M-L1111-22N9
		4-position	HW1M-L2222-22N9

On all mono-lever switches, the rated current (load switching current) is reduced to a half of the rated current of the contact block.
 The rated insulation voltage and the rated thermal current remain unchanged.

Contact Arrangement Chart

2-position (Right/Left)

Contact Lever Operator Contact Code Mounting Contact Left Center Right Position 1 2 NO 1 NO • 2 NO • 3 NO • 4


2-position (Up/Down)

Contact	Cont Blo		Lever Operator Position			
Code	Mounting Position	Contact	Left	Center	Right	
20	1	NO	•			
20	2	NO			•	
	1)	NO	•			
40	2	NO			•	
40	3	NO	•			
	4	NO			•	

4-position

Contact	Cont Blo	Lever Operator Position					
Code	Mounting Position	Contact	Down	Left	Center	Up	Right
	1	NC					•
22N9	2	NC	•				
22119	3	NO		•			
	4	NO				•	

Part No. Development



The lever operator of the interlocking type HW1M-L is locked only in the center position.
 Pull on the interlocking lever before operating the lever up/down/right/left.

Contact Block Mounting Position and Lever Operation Position




DimensionsAll dimensions in mm.

Standard Lever

Locking Ring Panel Thickness 0.8 to 6 49.4 (1 or 2 blocks) 69.4 (3 or 4 blocks) 72

Interlocking Lever



Terminal Screws M3.5

Integrated Terminal Cover

See B-210 for the bottom view.

Nameplates

Package Quantity: 1

Description	Legend	Material	Part No.	Ordering No.	Package Quantity	Dimensions (mm)
HWAM	Order marking plate	Plastic (black)	HWAM	HWAM	1	HWNP-□ marking plate (sold separately) is necessary.
HVVAIVI	(round) separately.	Flashic (Diack)	NWAW	HWAMPN10	10	R14.9 4.5 1.5 1.5 1.1
HWAQ	UWAO Order marking plate Plactic (black)		HWAQ	1	HWNP-□ marking plate (sold separately) is necessary.	
nwaq	(square) separately.	Plastic (black)	HWAQ	HWAQPN10	10	R14.9 4.9 4.5 1.9 1.1
HIMAC	Blank	Plastic (black)	HWAS-0	HWAS-0	1	□45 <u>1.6 0.9</u>
HWAS	ышк		UMA9-U	HWAS-0PN10	10	022

• Nameplates cannot be used on HW series control stations (HW1X).

Marking Plates for HWAM/HWAQ

Description	Material	Part No.	Ordering No.	Package Quantity	Dimensions (mm)
LIMAID	Aluminum (black)	HWNP-□	HWNP-□	1	White legend on black background. Engraving area: W25×H7
HWINP	HWNP Aluminum (black) Thickness = 1.0mm	nwnr-⊔	HWNP-□PN10	10	27 21 21

 \bullet Specify a legend code in place of \square in the Ordering No.

Legends

Code	Legend
0	(blank)
1	ON
2	0FF
3	START
4	STOP STOP
31	OFF-ON
35	HAND-AUTO
53	HAND-OFF-AUTO

• See B-226 for how to install nameplates/marking plates, and how to remove marking plates.

APEM

Switches &

Control Boxes

Emergency Stop Switches Enabling Switches

Safety Products

Explosion Proof

Terminal Blocks

Relays & Sockets

Circuit Protectors

Power Supplies

LED Illumination

Controllers

Operator Interfaces

Sensors

AUTO-ID

Flush Silhouette

ø16

ø30

Miniature

Pilot Lights

HW TW YW

Control Boxes

Emergency
Stop Switches

Enabling
Switches

Safety Products

Explosion Proof

Terminal Blocks

Relays & Sockets

Circuit
Protectors

Power Supplies

LED Illumination

Controllers

Operator
Interfaces

Sensors

AUTO-ID

Flush Silhouette

ø16

ø30 Miniature Pilot Lights

TW

Accessories All dimensions in mm.

When ordering, specify the Ordering No.

ſ						Package	when ordering, specify the Ordering No.
		Shape	Material	Part No.	Ordering No.	Quantity	Dimensions (mm)
		Locking Ring Wrench	Metal (brass) (weight: approx. 150g)	MW9Z-T1	MW9Z-T1	1	Used to tighten the locking ring when installing the HW switch onto a panel. 110 08 108 110 110 110 110 110 110 110 110 110 110 110 110
	Tool	A B B	Nitrile rubber (black)	OR-55	OR-55	1	Used to install and remove the LED lamps. See B-223 to B-224 for how to install. A : BA9S OR-55 59
		Contact Block Removal Tool	Zinc-plated metal Nitril rubber	TW-KC1	TW-KC1	1	Used to remove the contact block and transformer, and also to install/remove the pilot light and illuminated pushbutton lens. See B-224.
	Anti-	erotation Ring	Ring: polyamide Gasket: nitril rubber	HW9Z-RL	HW9Z-RLPN10	10	Used to prevent the operator from turning. Generally used when using no nameplates on selector switches and pushbutton selectors. TOP 1.5
H	Rubb	per Mounting Hole Plug	Nitril rubber (black)	0B-31	0B-31PN05	5	Used to plug the unused ø22.2 mm mounting holes. Degree of protection: IP65 (round hole) IP40 (with anti-rotation function) ### Page 1
	Rubb	per Mounting Hole Plug	Plug: chrome-plated zinc diecast Locking ring: polyamide Gasket: nitril rubber	LW9Z-BM	LW9Z-BM	1	Used to plug the unused ø22.2 mm mounting holes. Degree of protection: IP66 (round hole) IP40 (with anti-rotation function) Tightening torque: 1.2 N·m Ostale Panel Thickness Ostale Ostale
	Meta	allic Mounting Hole Plug	Polyamide	LW9Z-BP1	LW9Z-BP1	1	Used to plug the unused ø22.2 mm mounting holes. Degree of protection: IP65 Tightening torque: 2.0 N·m
	Barri	ier	Polyamide	HW-VU1	HW-VU1PN10	10	Used to prevent contact between adjacent lead wires when units are mounted closely (see B-227 for details). Barriers should always be used in close mounting.

Control Boxes

Emergency
Stop Switches

Enabling
Switches

Safety Products

Explosion Proof

Terminal Blocks

Relays & Sockets

Circuit
Protectors

Power Supplies

LED Illumination

Controllers

Operator
Interfaces

Sensors

AUTO-ID

Flush Silhouette

ø16

ø30 Miniature Pilot Lights

TW

Accessories All dimensions in mm.

				· · · · · · · · · · · · · · · · · · ·		When ordering, specify the Ordering No.
Shape		Material	Part No.	Ordering No.	Package Quantity	Dimensions (mm)
Switch Guard	Spring Return	Guard: polyacetal Cover:	HW9Z-K1	HW9Z-K1	1	Used to prevent inadvertent operation for flush pushbuttons and illuminated pushbuttons. IP65 Maintained type stops at 90° and 180°. Agy Agy Agy Agy Agy Agy Agy Agy Agy
	Maintained	polyarylate Gasket: nitril rubber	HW9Z-K11	HW9Z-K11	1	0.8 to 5 0.8 to 5 2 1 1 1 1 1 1 1 1 1 1 1 1
Button Clear Boot	For flush pushbuttons	Rubber	0C-31	0C-31	1	Used to cover and protect pushbuttons where units are subject to watersplash. Not suitable for outdoor use or where the units are
	For extended pushbuttons	(EPDM)	0C-32	0C-32	1	subject to oil splash. • Cannot be used with nameplates HWAM, HWAQ, HWAS, or HWAV. 18 (0C-31) 22 (0C-32)
Padlock Cover		Polyarylate (gasket: nitryl rubber)	HW9Z-KL1	HW9Z-KL1	1	Used to protect pushbuttons, illuminated pushbuttons, selector switches, and key selector switches. Rey hole on the selector switches. Panel Thickness 0.8 to 3.2
Rubber Boot for Dual Push Switches	abutton	Clear Silicon Rubber	HW9Z-D7D	HW9Z-D7D	1	• IP65 33 22.5
Ring Adapter		Nitryl rubber	HW9Z-A25	HW9Z-A25PN05	5	Used to install the HW series units into Ø25 mm mounting holes. IP65 Cannot be used with anti-rotation, nameplate, and rubber boot for dual pushbutton switches. Mounting panel thickness: 1.2 to 6.0 mm See B-225 for details.
Ring Adapter		Gasket: polyamide Washer: metal (brass)	HW9Z-A30	HW9Z-A30PN02	2	Used to install the HW series units (round type) into ø30 mm mounting holes (except for HW1P-5, HW1B-M5/V5, HW7D, and HW1Z). IP65 Cannot be used with anti-rotation ring, nameplate, full-shroud illuminated pushbuttons, pushbutton selectors, and mono-lever switches. Mounting panel thickness: 1.6 to 4.0 mm
Ring Adapter		Gasket: rubber Washer: metal	HW9Z-A30E	HW9Z-A30EPN02	2	Used to install jumbo dome pilot light HW1P-5Q units into ø30 mm mounting holes. IP65



Control Boxes

Emergency
Stop Switches
Enabling
Switches

Safety Products

Explosion Proof

Terminal Blocks

Relays & Sockets

Circuit
Protectors

Power Supplies

LED Illumination

Controllers

Operator
Interfaces

Sensors

AUTO-ID

Flush Silhouette

ø16

ø30 Miniature Pilot Lights

TW

Maintenance Parts

All dimensions in mm.

When ordering, specify the Ordering No.

	Shape	Material	Part No.	Ordering No.	Package Quantity	Remarks
	Contact Block	NO contact	HW-U10	HW-U10	1	Housing color: blue/Push rod color: green
	HW-U	140 Contact	HW-U10-MAU	HW-U10-MAU	'	MAU has gold contacts
-		NC contact	HW-U01	HW-U01	1	Housing color: reddish purple/Push rod color: red
		NO CONTACT	HW-U01-MAU	HW-U01-MAU	ı	MAU has gold contacts
		EM (early make)	HW-U10R	HW-U10R	1	Housing color: blue/Push rod color: black
		contact	HW-U10R-MAU	HW-U10R-MAU	Į.	MAU has gold contacts
-		LB (late break)	HW-U01R	HW-U01R	1	Housing color: reddish purple/Push rod color: white
-	Weight: 11g (approx.)	contact	HW-U01R-MAU	HW-U01R-MAU	1	MAU has gold contacts
-	Dummy Block Weight: 3.5g (approx.)	Polyamide	HW-DB	HW-DBPN10	10	For HW-U contact blocks Used when the number of contact blocks and full voltage adapters is odd number.
	Full Voltage Adapter for Illuminated (*1) Weight: 12g (approx.)	Polyamide	HW-GA1N	HW-GA1NPN02	2	Applicable model: Illuminated pushbuttons Illuminated selector switches Applicable load (LED lamp) LSRD-6, LSTD-6 (6V AC/DC) LSRD-1, LSTD-1 (12V AC/DC) LSRD-2, LSTD-2 (24V AC/DC)
	Transformer Unit (*1)	100/110V AC	HW-T16	HW-T16	1	Applicable model: Illuminated pushbuttons Illuminated selector switches
-	Weight: 12g (approx.)	200/220V AC	HW-T26	HW-T26	1	Applicable load (LED lamp) LSRD-6, LSTD-6 (6V AC/DC)

^{*1)} Maintenance parts are used for maintenance parts only. Do not use these parts for expansion or remodeling purpose.

When ordering, specify the Ordering No. $\,$

	Shape		Material/Dimensions	Part No.	Ordering No.	Package Quantity	Color Code *
	Lens ① ②	①Round flush	Polyarylate ø23.5 H4.2	HW9Z-L11*-K	HW9Z-L11*-KPN05	5	
		©Square flush	Polyarylate ø24.6 H4	HW9Z-L21*-K	HW9Z-L21*-KPN05	5	R (red), G (green), Y (yellow), A (amber), C (clear), S (blue) (*2)
	3	③Round extended	Polyarylate ø23.3 H10	HW9Z-L12*-K	HW9Z-L12*-KPN05	5	
	5	 	AS, marking type ø29 H12.7	ALW31LD-*-K	ALW31LD-*-KPN02	2	R (red), G (green),Y (yellow), A (amber), S (blue), C (clear) (*2)
	(6)	⑤ø40 mushroom	AS, marking type ø40 H12.7	ALW41LD-*-K	ALW41LD-*-K	1	R (red), G (green), Y (yellow), A (amber), S (blue), C (clear) (*2)
	0	©Jumbo dome	Polycarbonate ø66 H50	HW1A-P5*	HW1A-P5*	1	R (red), G (green), Y (yellow), A (amber), W (white), S (blue)
.		⑦Dome for pilot light	AS ø23.5 H15.1	HW1A-P2*-K	HW1A-P2*-KPN05	5	R (red), G (green), Y (yellow), A (amber), W (white), S (blue) (*3)
	Button ① ②	①Round flush with round or square bezel	Polyacetal ø23.6 H3	HW1A-B1*	HW1A-B1*PN05	5	
		②Round extended with round or square bezel	Polyacetal ø23.6 H9.2	HW1A-B2*	HW1A-B2*PN05	5	
	3	3Square flush	Polyacetal □24.8 H3	HW2A-B1*	HW2A-B1*PN05	5	Use ① for pushbutton selectors.
	Square extended Sø29 mushroom		Polyacetal □24.5 H9.2	HW2A-B2*	HW2A-B2*PN05	5	B (black), G (green), R (red), Y (yellow), S (blue), W (white)
			Polyacetal ø29 H12.7(M18P1.0)	HW1A-B3*	HW1A-B3*PN02	2	
		©ø40 mushroom	Polyacetal ø40 H12.7(M18P1.0)	HW1A-B4*	HW1A-B4*PN02	2	

 $[\]ensuremath{^{\star}}\xspace$ 2) Use C (clear) lens for PW (pure white) illumination.

^{*3)} Use W (white) lens for PW (pure white) illumination.



Maintenance Parts

All dimensions in mm.

When ordering, specify the Ordering No.

						,	When ordering, specify the Ordering No.	<u> </u>
	Shape		Material/Dimensions	Part No.	Ordering No.	Package Quantity	Remarks	ilot Lights
	Round flush		Acrylic ø21.5 Thickness = 1	HW9Z-P11	HW9Z-P11PN05	5	White See B-225 for dimensions and engraving area.	ts
g Plate	Round extended		Acrylic ø21.3 Thickness = 6.5	HW9Z-P12	HW9Z-P12PN05	5	- Gilgi avilig alba.	APEM Switches &
Marking Plate	Square flush		Acrylic 22.7 Thickness = 1	HW9Z-P21	HW9Z-P21PN05	5		Pilot Lights Control Boxes
	ø29/40 mm mushroom		Acrylic ø15.7 H3.4	ALW3B	ALW3BPN05	5		Emergency Stop Switches Enabling Switches
	rator Knob for Illumina	ated					Specify a color code in place of *.	Safety Products
Sele	ctor Switch			HW9Z-FDY*-K	HW9Z-FDY*-K	1	R (red), G (green), Y (yellow), A (amber), W (white), S (blue) • Use W (white) knob/lever for pure white	Explosion Proof
000	rator Lever for Illumin	atad	AS resin				illumination.	Terminal Blocks
	ctor Switch	ateu		HW9Z-FDL*-K	HW9Z-FDL*-K	1		Relays & Sockets Circuit Protectors
								Power Supplies
Spar (Disc	re Key c Tumber Key)	\cap	Martel					LED Illumination
			Metal (nickel-plated brass)	HW9Z-SK-231	HW9Z-SK-231PN02	2		Controllers
	6							Operator Interfaces
	e Key Tumber Key)			LW9Z-SK-500	LW9Z-SK-500PN02		Standard key number	Sensors
	9-50	6	Metal (nickel-plated brass)	LW9Z-SK-	LW9Z-SKPN02	2	• Key number : 501 to 503	AUTO-ID
	12			LW9Z-SK-	LW9Z-SK- PN02		• Key number : 504 to 515	Flush Silhouette
Lock	kig Ring							ø16
			Polyamide (black) ø28.4 H5 M22P1	HW9Z-LN	HW9Z-LNPN05	5		ø22
Can	for Mono-lever							ø30 ————————————————————————————————————
Swit		Standard	Nitryl rubber ø10 L20	HW9Z-CPM	HW9Z-CPM	1		Miniature Pilot Lights
Boot Mon	for o-lever		Nitral rubbor					
Swit	ch S	Standard	Nitryl rubber ø29.2 L34.4	HW9Z-BLM	HW9Z-BLM	1		HW
D:44.	ning Long						a Hood for LED time imposed dome wildt	TW
Dillic			Polycarbonate ø22.2 H21	HW9Z-PP5C	HW9Z-PP5C	1	Used for LED type jumbo dome pilot lights only. Do not use for incandescent lamp illumination.	TVV
Safe	Safety Lever Lock Polyacetal (Polyacetal (yellow)	HW9Z-LS	HW9Z-LSPN10	10	A safety lever lock is supplied with a standard HW series switch/pilot light.	
Gasket		Nitryl rubber (black)	HW9Z-WM	HW9Z-WMPN10	10	Thickness = 0.5 6 *0.15		

Control Boxes

Emergency
Stop Switches

Enabling
Switches

Safety Products

Explosion Proof

Terminal Blocks
Relays & Sockets
Circuit
Protectors
Power Supplies
LED Illumination
Controllers

Operator

Sensors
AUTO-ID

Flush Silhouette

ø16

ø30

TW

Miniature

Pilot Lights

Maintenance Parts All dimensions in mm.

LEDs

Except HW Jumbo Dome Pilot Lights (except colors R, A, and G)

When ordering, specify the Ordering No.

Shape/Dimensions	Operating	Current Draw		Part No.	Ordering No.	Package	Base
Silape/Difficisions	Voltage	DC	AC	i ait ivo.	Ordering No.	Quantity	Dase
LSRD	6V AC/DC	10mA	14mA	LSRD-6	LSRD-6	1	
	OV AC/DC				LSRD-6PN10	10	BA9S/13
73 (2)	12V AC/DC	7mA	8mA	LSRD-1	LSRD-1	1	
					LSRD-1PN10	10	
	0.41/.40/D0	7	04	1000 0	LSRD-2	1	
	24V AC/DC	7mA	8mA	LSRD-2	LSRD-2PN10	10	

- Only one color is available for LSRD so there are no codes to specify the color in the part no.
- Use a LSRD-2 lamp for dome pilot lights with Y (yellow), S (blue), or PW (pure white) illumination.
- When replacing the LSTD lamp to LSRD lamp, the lens should also be replaced (see B-219). (except dome pilot lights and dual pushbuttons with pilots)

Accessory for green dual pushbutton (with pilot light)

Package Quantity: 5

Shape	Ordering No.	Dimensions
Attachment lens		
	1.000.1.0	For PW (pure white) illumination, use only a LSRD lamp and not an attachment lens. The attachment lens is available with 5 pieces connected as shown on the right.

• See B-227 for the installation method.

For HW Jumbo Dome Pilot Lights

Package Quantity: 1

Shape	Operating Voltage	Current Draw		Ordering No.	Dimensione	
эпаре	Operating Voltage	DC	AC	Ordering No.	Dimensions	
LSTDB		A: 14mA	A: 14mA	LSTDB-2AN	20.5	
()	24V AC/DC	G: 8mA	G: 8mA	LSTDB-2GN	Eyelet (X1) Base (X2) Voltage	

- Use an A (amber) LED for (R) red illumination.
- Use a LSRD-2 lamp for dome pilot lights with Y (yellow), S (blue), or PW (pure white) illumination.

LED Lamps (LED Lamps for replacing incandescent lamps)

- Use the following replacement LED lamps to replace incandescent lamps.
- See HW series LED lamps shown above for ordering.
- LED lamps may have different brightness/color hue compared with incandescent lamps.

Incandescent Lamp						
Model (din	nensions in mm)	Part No.	Rated Voltage	Lamp Ratings	Base	
LS		LS-6	6V AC/DC	1W(6V)		İ
		LS-8	12V AC/DC	1W(18V)	DAOC/12	İ
	Glass bulb: ø11	LS-2	AC/DC18V	1W(24V)	BA9S/13	
	Length: 23	LS-3	24V AC/DC	1W(30V)		
LSB (For Jumbo D	Oome Pilot Lights) Glass bulb: ø10 Length: 27	LSB-2	24V AC/DC	28V/0.17A	BA9S/13	

Replacement LED Lamp					
Ordering No.	Rated Voltage	Base			
LSRD-6	6V AC/DC				
LSRD-1	12V AC/DC	BA9S/13			
LSRD-2	24V AC/DC	DA93/13			
LSRD-2	24V AC/DC				
LSTDB-2*	24V AC/DC	BA9S/13			

- Specify a color code in place of *. R (red), G (green), A (amber), S (blue), PW (pure white)
- Use a PW (pure white) LED lamp for Y (yellow) illumination.
- When replacing the incandescent lamp with LSRD, the lens must also be replaced (see B-219).

Transformer

Package Quantity: 1


Shape	Operating Voltage	Operating Voltage Range	Ordering No.	Applicable Load	
6V 100/110V AC		100/110V AC ±10% TWR51		LSRD-6 (6V AC/DC, LED lamp)	
	200/220V AC	200/220V AC ±10%	TWR526	LSTD-6* (6V AC/DC, LED lamp) Specify a color code in place of * in Part No.	
	400/440V AC	400/440V AC ±10%	TWR546	R (red), G (green), A (amber), S (blue), PW (pure white)	
24V	100/110V AC	100/110V AC ±10%	TWR512	LSRD-2 (24V AC/DC, LED lamp)	
	200/220V AC	200/220V AC ±10%	TWR522	LSTD-2* (24V AC/DC, LED lamp) or LSTDB-2* (24V AC/DC, LED lamp) Specify a color code in place of * in Part No.	
40	400/440V AC	400/440V AC ±10%	TWR542	R (red), G (green), A (amber), S (blue), PW (pure white)	

- Terminal cover (TWR-VL3) is installed on transformers as standard.
- Transformer is installed to one HW series unit.

Specifications

Part No.	TWR5□6	TWR5□2		
Operating Voltage	100/110V AC, 200/220V AC 400/440V AC (50/60Hz)			
Current Draw	2.4VA			
Rated Insulation Voltage	600V			
Insulation Resistance	100MΩ minimum (500V [OC megger)		
Operating Temperature	-30 to +60°C (no freezing)			
Operating Humidity	35 to 85% RH (no condensation)			
Storage Temperature	-40 to +80°C (no freezing)			
Vibration Resistance	Damage limits: 30Hz, amplitude 1.5 mm Operating extremes: 5 to 55Hz, amplitude 0.5 mm			
Shock Resistance	Damage limits: 1,000 m/s ² Operating extremes: 100 m/s ²			
Dielectric Strength	2500V AC, 1 minute			
Terminal Screw	M3.5			
Applicable Wire	2mm² maximum, 2 wires maximum			
Weight (approx.)				

Dimensions



All dimensions in mm.

ø22

Accessories

When ordering, specify the Ordering No.

Shape	Material	Part No.	Ordering No.	Package Quantity	Dimensions (mm)
DIN 35 mm Rail Weight: 200g approx.	Aluminum Length: 1000 mm	BAA1000	BAA1000PN10	10	12.5 1.7 12.5 1.7 12.5 1.7 12.5 1.7 12.5 1.7 12.5 1.7 12.5 1.7 12.5 12.5 12.5 12.5 12.5 12.5 12.5 12.5
End Clip Weight: 15g approx.	Metal (zinc-plated steel) Applicable rail: AA1000	BNL6	BNL6PN10	10	M4 Screws

• See H-071 for DIN rail products.

APEM Switch

Switches & Pilot Lights

Control Boxes

Emergency Stop Switches Enabling Switches

Safety Products

Explosion Proof

Terminal Blocks

Relays & Sockets

Circuit Protectors

Power Supplies

LED Illumination

Controllers

Operator Interfaces

Sensors

AUTO-ID

Flush Silhouette

ø16

22

ø30

Miniature

Pilot Lights

HW

TW ------YW

Pilot Lights

Control Boxes

Emergency
Stop Switches

Enabling Switches

Safety Products

Explosion Proof

Terminal Blocks

Relays & Sockets

Circuit Protectors

Power Supplies

LED Illumination

Controllers

Operator Interfaces

Sensors

AUTO-ID

Flush Silhouette

ø16

ø30

Miniature

Pilot Lights

HW
TW
YW

Safety Precautions


- Turn off the power to the HW series switches & pilot lights before starting installation, removal, wiring, maintenance, and starting installation, removing, wiring, maintenance, and inspection of the products. Failure to turn power off may cause electrical shocks or fire hazard.
- To avoid a burn on your hand, use the lamp holder tool when replacing lamps.
- For wiring, use wires of a proper size to meet the voltage and current requirements. Tighten the terminal screws to the recommended tightening torque (see B-228). Failure to tighten terminal screws may cause overheat and fire.

Operating Instructions

Panel Mounting

Remove the contact block from the operator (for transformer type pilot lights, remove the transformer from the illumination unit).
 Remove the locking ring from the operator (for pilot lights, remove the locking ring from the

locking ring from the illuminated unit). Insert the operator into the panel cut-out from the front. Tighten the locking ring from the back to install the contact block to the operator.



Mounting panel thickness is reduced by 1.5 mm when using a nameplate.

Removing the Contact Block

Non-illuminated switches


- Remove the operator from the contact block by pushing in the direction shown in ① and then turn the lever to the left shown in ②.
 Then the operator can be pulled out.
- 2) To reinstall, place the TOP marking on the operator and the lock lever in the same direction, and insert the operator into the contact block mounting adapter. Then turn the locking lever in the opposite direction.





Illuminated switches

 Remove the safety lever lock (yellow) from the lock lever by inserting a flat screwdriver into the safety lever lock and push upwards.



 Remove the operator from the contact block by turning the locking lever in the direction of the arrow shown below. Then the operator can be pulled out.



- To reinstall, place the TOP marking on the operator and the lock lever in the same direction, and insert the operator into the contact block mounting adapter. Then turn the locking lever in the opposite direction.
- Install the safety lever lock (yellow) on the lock lever. The safety lever lock cannot be installed when the lock lever is not upright.

Safety Lever Lock

IDEC strongly recommends using the safety lever lock (HW9Z-LS, yellow) to ensure that lock lever is locked, or to prevent maintenance personnel from unlocking contacts during wiring.



How to install

 Mount the HW series onto the panel, lock the lever, and push in the safety lever lock.

Spacing in Vertical Direction

 Be sure to take the space required for installing/removing the safety lever lock into consideration. When the spacing is narrower than the recommended value, install the HW series units in the order of low to high. When removing, do so in the opposite direction.

Notes for Panel Mounting

Locking ring wrench recommended torqueTighten the bezel to a tightening torque of 2.0 N·m.

Locking ring wrench

Locking ring wrench (MW9Z-T1) can be used to tighten the bezel. Do not use pliers. Excessive tightening will damage the locking ring.



Locking ring wrench (MW9Z-T1)

Panel Thickness

HW series can be mounted on a panel with thickness of 0.8 to 6.0 mm. Take the thickness of nameplate and/or switch guard into consideration.

Replacement of LED Lamps

LED lamps can be replaced by using the lamp holder tool (OR-55) from the front of the panel, or by removing the contact block from the operator unit. (See B-217 for lamp holder tool.)

How to Remove

To remove, slip the lamp holder tool onto the lamp head lightly. Then push slightly, and turn the lamp holder tool counterclockwise.




Photo: Extended pilot light


Operating Instructions

How to Install

Insert the lamp head into the lamp holder tool.



Place the pins on the lamp base to the grooves in the lamp socket. Insert the lamp and turn it clockwise.



Installing/Removing the Buttons and Lenses

<To install>

<To remove>

Pushbutton Button

Flush/Extended

Push in the button to install.



Insert a flat screwdriver between the button and the bezel to remove the button.



Mushroom/Jumbo Mushroom

Button has threads. Turn clockwise to install the button.



Turn the button counterclockwise to remove.

Note: Jumbo mushroom button cannot be removed.



Illuminated Pushbutton Lens

Flush/Extended

Push in the lens holder into the operator unit.



Insert a flat screwdriver between the button and the bezel to remove the lens holder.



• Mushroom/Jumbo Mushroom

Lens has threads. Turn clockwise to install the lens.



Lens has threads. Turn





counterclockwise to remove the lens.

Pilot Light Lens

• Extended/Mushroom

Lens has threads. Turn clockwise to install the lens.



Turn the lens counterclockwise to



• Round Flush/Square Flush

Push in the lens holder into the operator unit.



Insert a flat screwdriver between the lens and the bezel to remove.



Removing the Contact Blocks/Full Voltage Adapters

Insert a flat screwdriver (4 to 6 mm) into the snap-fit latches of the contact block or full voltage adapter and lift to remove.




- Make sure to lift both latches. Contact blocks cannot be removed by lifting one latch only.
- Do not apply excessive force to the latches, otherwise damage maybe caused.

Transformer Units and DC-DC Converters

Insert the end of the contact block removal tool (TW-KC1) into the snap-fit latch of the transformer units or DC-DC converter and pull the tool forward.

The contact block removable tool cannot be used to remove the HW-U contact blocks (HW-U), full voltage adapters (HW-GA1N), or dummy blocks (HW-DB).



Transformer Units and DC-DC Converters for Pilot Lights

Insert a flat screwdriver into the snap-fit latch on the contact block and lift to remove.



Mhen replacing parts (contact block, dummy block, full voltage adapter, transformer) for maintenance, make sure to install the parts to the original position. Otherwise proper operation cannot be guaranteed.

APEM

Control Boxes

Emergency Stop Switches Enabling Switches

Safety Products

Explosion Proof Terminal Blocks

Relays & Sockets

Circuit Protectors

Power Supplies LED Illumination

Controllers

Operator Interfaces

Sensors

AUTO-ID

Flush Silhouette ø16

ø30

Miniature

Pilot Lights

TW

YW

Control Boxes

Emergency Stop Switches

Enabling

Switches

Safety Products

Explosion Proof

Terminal Blocks

Relays & Sockets

Circuit

Protectors

Power Supplies

LED Illumination

Controllers

Operator

Sensors

AUTO-ID

Flush Silhouette

ø16

ø30 Miniature Pilot Lights

Interfaces

Operating Instructions

Using a Ring Adapter

HW9Z-A25


Install the ring adapter between the HW series unit and panel. Make sure that the side with ridges face the panel.

Dimensions Nitryl Rubber

Installation




Panel Cut-out



HW9Z-A30

The ring adapter HW9Z-A30 consists of a washer and adapter. Install adapter between the HW series unit and panel. Install washer between the locking ring and panel.





Replacement of Lens and Marking Plate

Removing the Lens Unit


Remove the lens unit (color lens, marking plate, and lens holder) by inserting a small flat screwdriver into the recess of the lens through the bezel. Knob on illuminated selector switches can be removed by tilting sideways. No tool is required.



Removing the Lens

Remove the lens by pushing the lens from the rear to disengage the latches between the lens and the lens holder, using a flat screwdriver as shown below. Marking plate can be removed after the lens is removed from the lens holder.





Note: The translucent filter in the lens holder cannot be removed because this filter is sealed to make the unit waterproof and oiltight.

Installing

[For Round Lens]

Lens Marking Plate Lens Holder

- 1. Place the marking plate on the lens holder with the anti-rotation projection engaged and press the lens onto the lens holder to engage the latches.
- 2. Place the marking plate in the correct orientation.

[For Square Lens]

Lens Marking Plate Lens Holder

- 1. Place the marking plate on the lens holder and press the lens onto the lens holder to engage the latches.
- orientation (note the directionality of marking plate).





Marking Plate

2. Place the marking plate in the correct

Marking


For HW series illuminated pushbuttons and pilot lights, legends and symbols can be engraved on the built-in marking plates, or printed film can be inserted under the lens for labeling purposes. Films are not cumplied with illuminated puchbuttons, and may be provided by the user

supplied with illuminated pushbuttons, and may be provided by the user.						
Lens Style	Round Lens (Round Flush/Round Flush with Square Bezel)	Square Lens (Square Flush)				
Built-in Marking Plate	Outside diameter ø21.5	Engraving Area				
	 Engraving must be made on the engraving area within 0.5 mm deep. The marking plate is made of white acrylic resin. 					
Applicable Marking	97 19.4	22.7				
Film	Two 0.1 mm-thick films or one 0.2 mm-thick film can be installed in the lens (marking film is not supplied and must be provided by the user). Recommended marking film: polyester					

Operating Instructions


Insertion Order of Marking Plate and Film

[Round Lens]



Note: Films are not supplied.

[Square Lens]



Note: Films are not supplied. When inserting a film, make sure that the marking plate is installed with its uneven side facing the lens holder.

Nameplate

Mounting panel thickness is reduced by 1.5 mm when using a nameplate.


Installing a Marking Plate

Insert a marking plate tin the direction of the arrow $\ensuremath{\mathbb{O}},$ and press in as shown $\ensuremath{\mathbb{Q}}.$



Removing a Marking Plate

Insert a flat screwdriver into the upper middle part of the marking plate and remove. When anti-rotation is not required, remove the projection from the nameplate using pliers.



Replacing the Lens of Dual Pushbuttons Removing

Remove the lens by inserting a small flat screwdriver into the recess of the lens through the bezel.



Installing

Install the lens in the recess between the buttons by pressing against the bezel.

Selector Switches


Turn the operator such as knob, lever, and key to each position accurately. Releasing halfway may cause the operator to return to the former position, or to get stuck between. On spring return two-way types, the center of operators may be misaligned slightly.

Key Selector Switches

Insert the key completely before turning. Failure to do so may cause failures


Anti-rotation Ring and Panel Cut-out

Align the TOP marking on the operator, TOP marking on the antirotation ring with the recess in the mounting panel.



Dual Pushbutton Switches

The pushbuttons cannot be removed or replaced. Do not attempt to remove using a flat screwdriver or pincers, otherwise the pushbuttons may be damaged.




Installing the Rubber Boot for Dual Pushbuttons

When using the HW7D pushbuttons in places where the pushbuttons are subject to water splash or an excessive amount of dust, make sure to use the HW9Z-D7D rubber boot (IP65) which is ordered separately. Recombs the rubber gasket pre-installed on the operator, and install the rubber boot from the front of buttons.

Notes for Installing the Rubber Boot

Remove the gasket from the operator, and install the rubber boot on the operator. Pull out the seals of the rubber boot and place them around the operator sleeve as shown. Make sure that the seals are not twisted or tucked inside and that the gasket does not remain, otherwise the normal waterproof and dustproof characteristics are not ensured.



Rubber Boot Installed



APEM

Pilot Lights

Control Boxes

Emergency Stop Switches Enabling

Switches

Safety Products

Explosion Proof

Terminal Blocks
Relays & Sockets

Circuit

Protectors

Power Supplies

LED Illumination

Controllers

Operator Interfaces

Sensors

AUTO-ID

Flush Silhouette

ø16

ø30

Miniature

Pilot Lights

HW


TW

YW

Operating Instructions

Close Mounting


When mounting the units closely in a horizontal row on 30 mm centers, use optional barriers to prevent interconnection between adjoining terminals, and to increase the creepage distance. The barriers can be attached simply by pressing them onto the sides of contact blocks.




Use a barrier (HW-VU1) between the contact blocks.

Note: Sufficient insulation distance cannot be obtained if barriers are not installed, or when other barriers such as HW-VG1 is used.

When using transformer type illuminated HW series of 240V AC maximum closely in a horizontal row on 30 mm centers, insert straight the solid wires or stranded wires into inside of the terminal screw on the transformer (see figure below) to prevent short circuit between adjoining terminals.






When using transformer type pilot lights closely mounted in horizontal and vertical rows on 30 mm centers, keep the ambient temperature below 40°C.

Installing the attachment lens

Install the lens on to the LED lamp with the lens remaining on the runner. (The lens will be cut off when installed). Note the front and back sides of the lens.



Applicable Wiring


(1) Contact Block 0.3 to 3.5 mm² (solid wire Ø0.5 to 2.0 mm)

Pushbutton/illuminated pushbutton/dual pushbuttons (without pilot light), selector switch, illuminated selector switch, pushbutton selector, mono-lever switch

(A) and (B) show the wiring direction to the terminals.

<Contact Block>


Terminal screws M3.5 (spring-up)




Applicable Crimping Terminal


Be sure to use an insulation tube or cover on the crimping part of the crimping terminal to prevent electrical shocks.

Crimping terminal for (A)







IP20 crimping terminal



Crimping terminal for (B) (IP20)



Solid wire



- . Strip the wire insulation 8 to 9 mm from the end.
- Insert the wire until the insulation comes into contact with the terminal metal part.

(1)-1 IP20 Degree of Protection

The terminal of HW-U contact block has IP20 degree of protection. When IP20 is required for wiring, observe the followings. Make sure to insert the crimping terminal or wire to the terminal straight and fully.

When using a crimping terminal

Use IP20 crimping terminals.

When using a solid wire

Strip the wire insulation 8 to 9 mm from the end and insert the wire to the terminal fully.

When using a stranded wire

Strip the wire insulation 8 to 9 mm from the end and insert the wire to the terminal fully. Make sure that the wires are not loosened.

Control Boxes Emergency

APEM

Stop Switches Enabling Switches

Safety Products

Explosion Proof

Terminal Blocks Relays & Sockets

Circuit Protectors

Power Supplies LED Illumination

Controllers

Operator Interfaces

Sensors

AUTO-ID

Flush Silhouette

ø16

ø30

Miniature Pilot Lights

TW

YW

Operating Instructions


(2) Power Unit 0.3 to 2 mm² (solid wire Ø0.5 to 1.6 mm)

Illuminated pushbutton/illuminated selector switch

(A) and (B) show the wiring direction to the terminals.


<Full Voltage Adapter>

Terminal screws M3.5 (spring-up)




<Transformer Unit>

100/110V AC, 200/220V AC Terminal screws M3.5 (spring-up)



<DC-DC Convertor Unit/Transformer Unit>


110V DC, 380V AC minimum Terminal screws M3.5 (spring-up)





Applicable Crimping Terminal

Be sure to use an insulation tube or cover on the crimping part of the crimping terminal to prevent electrical shocks.


Crimping terminal for $\ensuremath{\text{\textcircled{A}}}$







Solid wire



- Strip the wire insulation 7 to 8 mm from the end.
- Insert the wire until the insulation comes into contact with the terminal metal part.

Terminal cover is integrated in the full voltage adapter and transformer unit. Note that the connection terminal is not IP20.

(2) Pilot Light 0.3 to 2 mm² (solid wire Ø0.5 to 1.6 mm)

(Arrows show the wiring direction)


<Full Voltage Adapter>

6, 12, 24V AC/DC

Terminal screws M3.5 (spring-up)




<Transformer, DC-DC Converter> 100/110V AC, 200/220V AC 110V DC, 380V AC minimum Terminal screws M3.5 (spring-up)



Applicable Crimping Terminal

Be sure to use an insulation tube or cover on the crimping part of the crimping terminal to prevent electrical shocks.



Solid Wire

- Strip the wire insulation 8 to 9 mm from the end.
- Inset the wire until the insulation comes into contact with the terminal metal part.
- · Terminal cover is integrated but not IP20.
- When selecting mounting centers and crimping terminals, take sufficient insulation distance into consideration.

%5.0 max

Cautions for Wiring

About DC-DC Converter Unit

1. Note the polarity for wiring when connecting to the DC-DC converter.

Terminal No.	Polarity
X1	Positive
X2	Negative

- 2. Incandescent lamps cannot be used in DC-DC converter unit.
- DC-DC converters are equipped with an electric circuit and noise may be heard inside the unit, which does not affect the performance of DC-DC converters.

Recommended Tightening Torque Number of Wires

Unit	Wire		Number of Wires	Recommended Tightening Torque	Terminal Screw
	Crimping Terminal		2	1.0 to 1.3	
HW-U Wir Contact Block Strand	Solid Wire	ø0.5 to 1.6 mm (AWG14 to 22)	2	1.0 to 1.3	M3.5
		ø1.7 to 2.0 mm (AWG12)	1	1.2 to 1.3	
	Stranded	0.3 to 2.0 mm ² (AWG14 to 22)	2	1.0 to 1.3	
	Wire	2.1 to 3.5 mm ² (AWG12)	1	1.2 to 1.3	
Illuminated Unit (*1)	Crimping Terminal				
	Solid Wire	ø0.5 to 1.6 mm (AWG14 to 22)	2	1.0 to 1.3	M3.5
	Stranded Wire	0.3 to 2.0 mm ² (AWG14 to 22)			
Pilot Light St	Crimping Terminal				
	Solid Wire	ø0.5 to 1.6 mm (AWG14 to 22)	2	1.0 to 1.3	M3.5
	Stranded Wire	0.3 to 2.0 mm ² (AWG14 to 22)			

 *1) Lamp terminal of illuminated pushbuttons, illuminated selector switches, dual pushbuttons with pilot lights



Switches
Safety Products

Enabling

Explosion Proof

Terminal Blocks

Relays & Sockets

Circuit Protectors

Power Supplies

LED Illumination

Controllers
Operator

Interfaces

Sensors
AUTO-ID

A010 ID

Flush Silhouette ø16

> ø30 Miniature

Pilot Lights

HW TW

SAPEN01A_B HW July 2024

Ordering Terms and Conditions

Thank you for using IDEC Products.

By purchasing products listed in our catalogs, datasheets, and the like (hereinafter referred to as "Catalogs") you agree to be bound by these terms and conditions. Please read and agree to the terms and conditions before placing your order.

1. Notes on contents of Catalogs

- (1) Rated values, performance values, and specification values of IDEC products listed in this Catalog are values acquired under respective conditions in independent testing, and do not guarantee values gained in combined
 - Also, durability varies depending on the usage environment and usage
- (2) Reference data and reference values listed in Catalogs are for reference purposes only, and do not guarantee that the product will always operate appropriately in that range.
- (3) The specifications / appearance and accessories of IDEC products listed in Catalogs are subject to change or termination of sales without notice, for improvement or other reasons.
- (4) The content of Catalogs is subject to change without notice.

2. Note on applications

- (1) If using IDEC products in combination with other products, confirm the applicable laws / regulations and standards.
 - Also, confirm that IDEC products are compatible with your systems, machines, devices, and the like by using under the actual conditions. IDEC shall bear no liability whatsoever regarding the compatibility with IDEC products.
- (2) The usage examples and application examples listed in Catalogs are for reference purposes only. Therefore, when introducing a product, confirm the performance and safety of the instruments, devices, and the like before use. Furthermore, regarding these examples, IDEC does not grant license to use IDEC products to you, and IDEC offers no warranties regarding the ownership of intellectual property rights or non-infringement upon the intellectual property rights of third parties.
- (3) When using IDEC products, be cautious when implementing the following.
 - Use of IDEC products with sufficient allowance for rating and performance
 - Safety design, including redundant design and malfunction prevention design that prevents other danger and damage even in the event that an IDEC product fails
 - Wiring and installation that ensures the IDEC product used in your system, machine, device, or the like can perform and function according to its specifications
- (4) Continuing to use an IDEC product even after the performance has deteriorated can result in abnormal heat, smoke, fires, and the like due to insulation deterioration or the like. Perform periodic maintenance for IDEC products and the systems, machines, devices, and the like in which they are used.
- (5) IDEC products are developed and manufactured as general-purpose products for general industrial products. They are not intended for use in the following applications, and in the event that you use an IDEC product for these applications, unless otherwise agreed upon between you and IDEC, IDEC shall provide no guarantees whatsoever regarding IDEC products.
 - Use in applications that require a high degree of safety, including nuclear power control equipment, transportation equipment (railroads / airplanes / ships / vehicles / vehicle instruments, etc.), equipment for use in outer space, elevating equipment, medical instruments, safety devices, or any other equipment, instruments, or the like that could endanger life or human health
 - ii. Use in applications that require a high degree of reliability, such as provision systems for gas / waterworks / electricity, etc., systems that operate continuously for 24 hours, and settlement systems
 - Use in applications where the product may be handled or used deviating from the specifications or conditions / environment listed in the Catalogs. such as equipment used outdoors or applications in environments subject to chemical pollution or electromagnetic interference If you would like to use IDEC products in the above applications, be sure to consult with an IDEC sales representative.

3. Inspections

We ask that you implement inspections for IDEC products you purchase without delay, as well as thoroughly keep in mind management/maintenance regarding handling of the product before and during the inspection.

4. Warranty

(1) Warranty period

The warranty period for IDEC products shall be one (1) year after purchase or delivery to the specified location. However, this shall not apply in cases where there is a different specification in the Catalogs or there is another agreement in place between you and IDEC.

(2) Warranty scope

Should a failure occur in an IDEC product during the above warranty period for reasons attributable to IDEC, then IDEC shall replace or repair that product, free of charge, at the purchase location / delivery location of the product, or an IDEC service base. However, failures caused by the following reasons shall be deemed outside the scope of this warranty.

- The product was handled or used deviating from the conditions / environment listed in the Catalogs
- The failure was caused by reasons other than an IDEC product
- Modification or repair was performed by a party other than IDEC
- The failure was caused by a software program of a party other than iv **IDEC**
- v. The product was used outside of its original purpose
- Replacement of maintenance parts, installation of accessories, or the like was not performed properly in accordance with the user's manual and
- vii. The failure could not have been predicted with the scientific and technical standards at the time when the product was shipped from
- viii. The failure was due to other causes not attributable to IDEC (including cases of force majeure such as natural disasters and other disasters) Furthermore, the warranty described here refers to a warranty on the IDEC product as a unit, and damages induced by the failure of an IDEC product are excluded from this warranty.

5. Limitation of liability

The warranty listed in this Agreement is the full and complete warranty for IDEC products, and IDEC shall bear no liability whatsoever regarding special damages, indirect damages, incidental damages, or passive damages that occurred due to an IDEC product.

6. Service scope

The prices of IDEC products do not include the cost of services, such as dispatching technicians. Therefore, separate fees are required in the following cases.

- (1) Instructions for installation / adjustment and accompaniment at test operation (including creating application software and testing operation, etc.)
- (2) Maintenance inspections, adjustments, and repairs
- (3) Technical instructions and technical training
- (4) Product tests or inspections specified by you

The above content assumes transactions and usage within your region. Please consult with an IDEC sales representative regarding transactions and usage outside of your region. Also, IDEC provides no guarantees whatsoever regarding IDEC products sold outside your region.

IDEC CORPORATION

Head Office 6-64, Nishi-Miyahara-2-Chome, Yodogawa-ku, Osaka 532-0004, Japan ☐ www.idec.com

USA **EMEA**

IDEC Corporation APEM SAS

Singapore Thailand India

IDEC Izumi Asia Pte. Ltd IDEC Asia (Thailand) Co., Ltd. IDEC Controls India Private Ltd. China

IDEC (Shanghai) Corporation IDEC Izumi (H.K.) Co., Ltd. **IDEC Taiwan Corporation** Taiwan

IDEC Corporation

Specifications and other descriptions in this brochure are subject to change without notice.

