



# Certificate of Compliance

**Certificate:** 1403577 (LR 84913)

**Master Contract:** 166730

**Project:** 2254814

**Date Issued:** December 24, 2009

**Issued to:** IDEC Corporation  
7-31 Nishimiyahara 1-chome  
Yodogawa-Ku, Osaka 532-8550  
Japan

*The products listed below are eligible to bear the CSA Mark shown*



*Jelena Maksimovic*

**Issued by:** Jelena Maksimovic

## **PRODUCTS**

**CLASS 3211 07 - INDUSTRIAL CONTROL EQUIPMENT - Miscellaneous Apparatus**

Relay Sockets for use with Submitter's Certified relays, open type. Cat No. SU2S-11L (2-pole), rated 10A, 250V ac per pole; Cat No. SU4S-11L (4-pole), rated 6A, 250V ac per pole.

Accessory module type pilot lights for use with SU2S and SU4S relay sockets, open type, Cat No. SU9Z-D11 rated 6-220V ac/dc; Cat No. SU9Z-D12 rated 6-220V dc; Cat No. SU9Z-R21 rated 6-240V ac; Cat No. SU9Z-L31 rated 6-12V ac/dc; Cat No. SU9Z-L32 rated 24-48V ac/dc; Cat No. SU9Z-L33 rated 100-125V ac/dc and Cat No. SU9Z-L34 rated 200-240V ac/dc.

## **Notes:**

Note: Open type devices are Certified as components for use only in other Certified equipment where the suitability of the combination is to be determined by the CSA International.

## **APPLICABLE REQUIREMENTS**

C22.2 No.14 - Industrial Control Equipment